

DFA

C/43

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SCHOOL/SZ/2024/ 202

Dated: 14/03/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Sai Public School Located at Ground Floor WZ-86A, Todapur Village, New Delhi-110012 in a building comprised of ground + 2 upper floors was issued Fire Safety Certificate vide Letter No. F.6/DFS/MS/School/2021/SZ/226, dated 16/03/2021 (for ground floor only). The premises was re inspected by the officer concerned of this department on 04/03/2024 in the presence of Smt. Babita (Cashier) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262-362 Dated 17/01/2005 and that the building is\ fit for occupancy class "Educational" Group B(At Ground Floor) with effect from 14/03/2024 for a period of three years.

Issued on ...14/03/2024.... at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
6/3/24

Copy to:

1. The Directorate of Education Old Secretariat Delhi - 110054.
2. The Principal, Sai Public School Located at Ground Floor WZ-86A, Todapur Village, New Delhi-110012.

Following fire safety directives must be adhered to:-

1. The FSC shall be null & void if upper floors is used for school activities.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: Sai Public School Located at Ground Floor WZ-86A, Todapur Village, New Delhi-110012.
2. Type of Occupancy : Educational (**Running at Ground floor only in a building comprised of Ground + 2 Upper Floors**)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2021/SZ/226, dated 16/03/2021 (**Issued for Ground floor only**)
5. Fire Safety directives Letter No. : 262-362 Dated 17/01/2005
6. Date of inspection : 04/03/2024
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Smt. Babita (Cashier)
9. Year of Construction : Before 2005
10. Applicant's letter No. : Form J, dated 04/03/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/10, N/11 & N/12	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Varies from 2.65 to 3.70 m	MR (Being old case)
	• Gate width	4.5mtrs	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	01 mtr	1 mtr	MR (Being old case)
	f. Door Size			
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

5.	Fire Extinguishers			
	• Total numbers	12 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	Required	Provided	MR

Provision of Lifts			
	Pressurization of Lift Shaft	NA	
	Pressurization of lift lobby	NA	NA
	Communication in lift Car	NA	NA
	Fireman's Grounding Switch	NA	NA
	Lift Signage	NA	NA
17.	Standby power supply	NA	NA
18.	Refuge Area	NA	NA
	Total area		
	Location	NA	NA
19.	Fire control room	NA	NA
	Detector system panel	NA	NA
	Flow Switch Panel	NA	NA
	PA System Panel	NA	NA
	Battery backup	NA	NA
	Building Floor Plans	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F.6/DFS/MS/School/2021/SZ/226, dated 16/03/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved FSC may be issued.

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation AO/1 AWP

14/3/21
14/3/21
CFO (S2)
14/3/2021
Director
MHS