



No. F6/DFS/MS/School/NDZ/2024/222

Dated: 20/03/2024

FIRE SAFETY CERTIFICATE

Certified that the Akash Deep Model School located at Nehru Vihar, Dayalpur Extn., Delhi-110094, comprised of basement, ground plus one upper floor only owned/occupied by Akash Deep Model School, was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2018/98 dated 17/01/2018. The School building was re-inspected by the officer concerned of this department on 13/03/2024 in presence of Mr. Mr. Ajay Veer Singh (Manager) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262-362 dated 17/01/2005 issued by Director of Education and found that the school building is fit for occupancy of class Group B "Educational Building" for ground plus One upper floor with effect from 20/03/2024 for a period of three years, in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 20/03/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.
2. The Manager, Akash Deep Model School, located at Nehru Vihar, Delhi - 110094.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/11

INSPECTION REPORT

1	Name & address of the building	Akash Deep Model School located at Nehru Vihar Dayalpur Extn., Delhi-110094.		
2	Building is comprised of	Small basement, ground plus first floor only (School is running on ground and first floor only)		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2018/98 dated 17/01/2018		
6	Fire safety directives letter no.	Circular letter No. 262-362 dated 17/01/2005.		
7	Date of inspection	13/03/2024.		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr.Ajay Veer Singh (Manager)		
10	Year of construction	2006		
11	Applicant's letter no.	Outdoor dairy no.13898 dated 05/03/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement Circular	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	6.0 mtrs.	10 mtrs.	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	01 no.	02 nos. ✓	MR
c	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.50 mtrs	1.00 mtr 1.06 mtr ✓	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	01 no	01 no ✓	MR
E	Width of corridor	1.50 mtrs.	2.00 mtrs ✓	MR
F	Door size	1.0 mtr.	1.0 mtr ✓	MR
3	Compartmentation:			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

W

5.	Fire Extinguisher:				
	A	Total numbers	04 nos.	12 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI marked	ISI marked	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	01 no	01 no	MR
	B	Length of hose reel hose	30 mtr	30 mtr	MR
	C	Nozzle diameter	6.5 mm	6.5 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		N/A	N/A	N/A
9	Public Address System:		N/A	N/A	N/A
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	220 LPM	220 LPM	MR
	B	Head of the pump	40 m	40 m	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

W

so,

N/13

Akash Deep Model School loketed at Nehru Vihar, Dayalpur Extn., Delhi-110094.

14	Captive Water Storage for Fire Fighting:						
	A	Underground tank capacity	N/A	N/A	N/A		
	B	Draw-off connection	N/A	N/A	N/A		
	C	Fire service inlet	N/A	N/A	N/A		
	D	Access to tank	N/A	N/A	N/A		
	E	Overhead tank capacity	2500 ltr	5000 ltr	MR		
15	Exit Signage:				N/A	N/A	N/A
16	Provision of Lifts:						
	A	Pressurization of lift shaft	N/A	N/A	N/A		
	B	Pressurization of lift lobby	N/A	N/A	N/A		
	C	Communication in lift car	N/A	N/A	N/A		
	D	Firemen's grounding switch	N/A	N/A	N/A		
	E	Lift signage	N/A	N/A	N/A		
17	Standby Power Supply:				N/A	N/A	N/A
18	Refuge Area:						
	A	Total area	N/A	N/A	N/A		
	B	Location	N/A	N/A	N/A		
19	Fire Control Room:						
	A	Detector system panel	N/A	N/A	N/A		
	B	Flow switch panel	N/A	N/A	N/A		
	C	PA system panel	N/A	N/A	N/A		
	D	Battery backup	N/A	N/A	N/A		
	E	Building floor plans	N/A	N/A	N/A		
20	Special Fire Protection systems for protection of special Risks, if any:				N/A	N/A	N/A

The fire protection systems provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Circular No. 262-362 dated 17/01/2005 issued by Director of Education, the FSC issued vide letter no. F6/DFS/MS/School/2018/98 dated 17/01/2018, renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended to be renewed.



Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (L.N)

DY.CFO (NDZ)

C.F.O.

15/03/2024

18/01/2024

Director

10/03/24

ms

ADOLN

R.F.O