



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/School/2024/SZ/217

Dated: 20/03/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Kendriya Vidyalaya** at Pragati Vihar, Lodhi Road, New Delhi-110003, comprised of Ground & Two Upper Floor only, owned/occupied by Kendriya Vidyalaya Sangathan, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/SZ/2021/59 dated 25/01/2021. The premise was re-inspected by the officer concerned of this department on 13/03/2024 in the presence of Ms. Sangeeta Aggarwal (Principal) and observed that said building have deemed complied with the fire prevention and fire safety requirement in accordance with rule 33 of Delhi Fire Services Rules, 2010 and that the school building/premises is fit for occupancy class "Educational" (Group 'B') with effect from 20/03/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/03/2024 at New Delhi by

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Principal, Kendriya Vidyalaya, Pragati Vihar, New Delhi-110003
2. The Asst. Commissioner, Kendriya Vidyalaya Sangathan, Delhi Region, JNU Campus, New Mehrauli Road, New Delhi-110067

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times as seen during inspection. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".



N/22

INSPECTION REPORT				
1.	Name & address of the building	Kendriya Vidyalaya, Pragati Vihar, Lodhi Road, New Delhi-110003		
2.	Type of Occupancy	Educational Group-B (School)		
3.	Building Comprised of	Ground & two upper floors.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/School/SZ/2021/59 dt.25/01/2021		
6.	Fire Safety directives Letter No.	F.6/DFS/MS/BP/99/2563 dated 15/01/1999		
7.	Date of inspection	13/03/2024		
8.	Name of the Inspecting Officer	Santosh Kumar (ADO/SJ)		
9.	Name and designation of Officer from the building side	Ms. Sangeeta Aggarwal (Principal)		
10.	Year of Construction	2003		
11.	Applicant's letter No	Outdoor Diary No. 12170 dated 23/01/2024		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Requirements/ Existing Fire Protection System	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	12m	MR
	• Gate width	Required	5m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 nos.	03 Nos	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m (each)	1.50m (each)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	One	MR
	e. Width of Corridor	1.5m	1.5m	MR
	f. Door Size	1m	1m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	13 Nos	13 Nos	MR
	• Types	ABC/CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	03 Nos	03 Nos	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR

84

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	100mm	NA
	• Number of hydrants per floor	NA	03 Nos	NA
	• Hose Box	NA	03 Nos	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM x 2	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 Ltrs	10,000 Ltrs	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA



N/24

19.	Fire control room			
	> Detector system panel	NA	NA	NA
	> Flow Switch Panel	NA	NA	NA
	> PA System Panel	NA	NA	NA
	> Battery backup	NA	NA	NA
	> Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/SZ/2021/59 dated 25/01/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Kumar*  
14.03.24  
Signature of the Inspecting Officer  
Name: Santosh Kumar  
Designation: ADO (SJ)

DO (SD)

*mukh*  
15/3

*CP*  
15/3/2024

Director

*15/03/24*

*1800/SJ*

Sir, F-6 letter is put up for your long pr.

*Kumar*  
19.03.24

*Director*  
19/3/24