

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2024/ 183

Dated 20/03/2024

FIRE SAFETY CERTIFICATE

Certified that the **Videsh Sanchar Bhawan** located at **Bangla Sahib Road, New Delhi** comprised of **Basement + Ground + 7 Upper floors** owned/occupied by **Videsh Sanchar Bhawan** was earlier granted FSC by this department vide letter No.F6/DFS/MS/NDZ/2021/375 dated 04/08/21. Now, the premises was re-inspected by the officers concerned of this department on **11.03.24** in the presence of **Sh. Rajeev Kumar** and found that the said building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Business, Sub Division-E** with effect from **20/03/2024**.....for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued **20/03/2024**.....at New Delhi by.

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to: -

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. The General Manager, Videsh Sanchar Bhawan, Bangla Sahib Road, New Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. The flammable material use for interior decoration, if any, shall strictly be prohibited.

INSPECTION REPORT

1. Name & address of the building : Videsh Sanchar Bhawan, Bangla Sahib Road, New Delhi.
2. Type of occupancy : Business Building
(B + Gr. + 07 Upper floors)
3. Type of case:- : Renewal 12 point
4. Details of previous FSC : F6/DFS/MS/NDZ/2021/375 dated 04/08/21.
5. Fire safety directives No. : NA
6. Date of inspection:- : 11/03/24
7. Name of the inspecting officer : Sh. Ravinder Singh ADO/CC
Sh. Rajinder Atwal, DO (CD)
8. Name & designation of officer
From the building side : Sh. Rajeev Kumar
9. Year of construction : 1976
10. Applicant's letter No : e-mail < sunil.jha@contractor.tatacommunication.com>
dated 19/02/2024.

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Approach to Building			
	1) Road width	06 mtr.	06 mtr.	MR
	2) Gate width	05 mtr.	05 mtr. ✓	MR
	3) Width of internal road	N/A	06 mtr. (two side)	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 No.	02 No. ✓	MR
	2. Basements	02 No	02 No. & 01 Ramp ✓	MR
	B. Width of staircase			
	1. Upper floors	1.25 & 0.80 mtr.	1.35 & 1.15 mtr. ✓	MR
	2. Basements	1.25 mtr.	1.35 & 1.15 mtr. 01 ramp 3.5 mtr. ✓	MR
	C. Protection of exits			
	1. Fire check door (fire escape)	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 No	01 No	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 Mtr.	1 Mtr. ✓	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	12 ACPH	Provided/ exhaust fan	MR
	2) Upper floors	12 ACPH	Provided	MR
5.	Fire Extinguishers			
	1) Total numbers	54 Nos.	60 Nos.	MR

N/55

	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 No.	01 No.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Gr. Floor	Provided	MR
	3) Location of repeater panel	Required	Provided 4 th floor	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided Every / floor Near S/case	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	Provided	N/A
	3) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 MM	150 MM	MR
	2) Number of hydrants per floor	01	01	MR
	3) Hose box each floor	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	04	04	MR
	2) Hose box	04	04	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2850 LPM	2850 LPM	MR
	b) Head of main pump	80 mtr.	80 mtr.	MR
	c) Number of main pump	01	01	MR
	d) Jockey pump out put (2 Nos.)	220 LPM	220 LPM	MR
	e) Jockey pump head	80 mtr.	80 mtr.	MR
	f) Stand by pump output	2800 LPM	2800 LPM	MR
	g) Stand by pump head	80 mtr.	80 mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A

- 56 -

14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	1,00,000 ltr.	1,00,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	20,000 Ltrs.	20,000 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	Required	Provided	MR
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risk, if any: Total flooding system is provided at server room			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. Further, requirements of fire extinguishers as per IS 2190 is 5-6 extinguishers at each floor. Accordingly, inspection note has been amended from previous report.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/NDZ/2021/375 dated 04/08/21, under rule 35 of the Delhi Fire Service rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name: - Sh. Rajinder Atwal
Designation: - DO (CD)

Name: - Sh. Ravinder Singh
Designation: ADO (CC)

By: C.F.O. (DOZ)
C.F.O.

15/3/2024
14/03/24
15/3/2024

Director
18/03/24

Anyu

END