



FIRE SAFETY CERTIFICATE

Certified that the M/s A1 Food Factoryy located at Shop no. SG 40-41, 52 Plot No. 09D Aditya Mega Mall, CBD Ground, Shahdara, Delhi - 110032, building comprised of basement, ground plus two upper floor owned/occupied by M/s A1 Food Factory was granted FSC vide letter no. F6/DFS/MS/EH/2019/1878 dated 30/09/2019. The premises was re-inspected by the officer concerned of this department on 08.03.2024 in the presence of Mr. Ashmeet Singh Sikka (Owner) and found that the restaurant building have deemed complied with the Fire prevention and fire safety requirement in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and found that restaurant is fit for occupancy class "Assembly Building" Group D "Ground floor only" with effect from 20/03/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 of sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 and also conditions printed below.

Issued 20/03/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
o/c DELHI FIRE SERVICE
u

Copy to:-

1. The Owner, A1 Food Factoryy located at Shop no. SG40-41,52 Plot No. 09D Aditya Mega Mall, CBD Ground, Shahdara, Delhi - 110032.
2. The Joint Commissioner of police (Lic.), Ist Floor, P.S Defence Colony, New Delhi - 110024 w.e.f. - MHA portal ID - 2024022402109 dated 01/03/2024.

Conditions for the validity of Fire Safety Certificate:

1. Fire Safety Certificate is valid for ground floor only.
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT 14/7

1	Name & address of the building	A1 Food Factoryy located at Shop no. SG 40- 41, 52 Plot No. 09D Aditya Mega Mall, CBD Ground, Shahdara, Delhi - 110032.
2	Building is comprised of	Basement + Ground + 03 upper floors only. (Restaurant is running at ground floor only)
3	Type of occupancy	Assembly Building
4	Type of case	Renewal
5	Details of previous FSC	F6/DFS/MS/EH/2019/1878 dated 30.09.2019.
6	Fire safety direction letter no.	NBC Part - IV
7	Date of inspection	08.03.2024
8	Name of the inspecting officers	Yashwant Singh Meena (ADO/LN)
9	Name of the designation of officer From the building side	Mr. Ashmeet Singh Sikka (Owner)
10	Year of construction	2000
11	Applicant's letter no	MHA Application No. 2024022402109 dated 01/03/2024.

S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR		
1	Access to building					
	a	Road width	9.0 mtrs.	9.0 mtrs	MR	
	b	Gate width	NA	NA	NA	
	c	Width of internal road	NA	NA	NA	
2	Number, Width, Type and Arrangement of Exits					
	A	Number of staircases				
		a	Upper floor	NA	NA	NA
		b	Basement	NA	NA	NA
	B	Width of staircases				
		a	Upper floor	NA	NA	NA
		b	Basement	NA	NA	NA
	C	Protection of exits				
		a	Fire check door	Required	Provided	MR
		b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace	NA	NA	NA	
	E	Width of corridor	NA	NA	NA	
	F	Door size	2.0 mtrs. & 1.50 mtrs.	2.0 mtrs. & 1.50 mtrs.	MR	
3	Compartmentation					
	a	Fire check door	Required	Provided	MR	
	b	Sealing of electrical shafts	N/A	N/A	N/A	
	c	Fire rating of shaft door	N/A	N/A	N/A	
	d	Water curtain	N/A	N/A	N/A	
	e	Fire dampers	N/A	N/A	N/A	
4	Smoke Management System.					
	a	Basement	NA	NA	NA	
	b	Upper floor	NA	NA	NA	

W

11/8

5.	Fire Extinguisher			
	a	Total numbers	05 nos.	06 nos. ✓ MR
	b	Types	CO ₂ & ABC	CO ₂ & ABC MR
	c	ISI marking	ISI marked	ISI marked MR
6	First-aid-Hose Reels.			
	a	Total numbers	01 no.	01 no. MR
	b	Length of hose reel hose	30 mtrs.	30 mtrs. MR
	c	Nozzle diameter	05 mm	05 mm MR
7	Automatic fire detection and alarming system.			
	a	Type of detectors	NA	NA MR
	b	Location of main panel	NA	NA NA
	c	Location of repeater panel	NA	NA NA
	d	Alternate source of power	NA	NA NA
	e	Hooter	Required	Provided MR
8	MOEFA		Required	Provided MR
9	Public address System.		NA	NA NA
10	Automatic Sprinkler System.			
	a	Basement	NA	Provided MR
	b	Upper floors	NA	Provided MR
	c	Sprinkler above false ceiling	NA	Provided MR
11	Internal Hydrants			
	a	Size of riser	100 mm	100 mm MR
	b	Number of hydrants per floor	01 no.	01 no. ✓ MR
	c	Hose Box	01 no.	01 no. ✓ MR
12	Yard Hydrants.			
	a	Total number of hydrants	NA	Provided MR
	b	Hose Box	NA	Provided MR
13	Pumping Arrangements.			
	A	Ground Level		
	a	Discharge of main Pump	NA	NA NA
	b	Head of Main Pump	NA	NA NA
	c	Number of main pumps	NA	NA NA
	d	Jockey pump out put	NA	NA NA
	e	Jockey pump head	NA	NA NA
	f	Standby pump out put	NA	NA NA
	g	Standby pump head	NA	NA NA
	h	Auto starting /manual stopping	NA	NA NA
	i	Pump House Access	NA	NA NA
	B	Terrace Level (Restaurant Self Arrangement)		
	a	Discharge of pump	450 LPM	450 LPM x 02 nos. ✓ MR
	b	Head of the Pump	40 mtrs.	40 mtrs. MR
	c	Power supply	Required	Provided MR
	d	Auto Starting of pump	Required	Provided MR

10

A1 Food Factory located at Shop no. SG 41, Plot No. 09D Aditya Mega Mall, CBD Ground, Shahdara, Delhi - 110032.

14	Captive Water Storage for Fire Fighting. (Restaurant Self Arrangement)				
	a	Underground tank capacity	NA	NA	NA
	b	Draw-off connection	NA	NA	NA
	c	Fire service inlet	NA	NA	NA
	d	Access to tank	NA	NA	NA
	e	Overhead Tank capacity	20,000 liters.	20,000 liters.	MR
15	Exit Signage.		Required	Provided	MR
16	Provision of Lifts.				
	a	Pressurization of Lift Shaft	NA	NA	NA
	b	Pressurization of Lift lobby	NA	NA	NA
	c	Communication in lift car	NA	NA	NA
	d	Firemen's grounding switch	NA	NA	NA
	e	Lift Signage	NA	NA	NA
17	Standby power supply		Required	Provided	MR
18	Refuge Area.				
	a	Total area	NA	NA	NA
	b	Location	NA	NA	NA
19	Fire Control Room				
	a	Detector system panel	NA	NA	NA
	b	Flow switch panel	NA	NA	NA
	c	PA system panel	NA	NA	NA
	d	Battery backup	NA	NA	NA
	e	Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:		NA	NA	NA

Note: - Previous restaurant was running name of M/s Mehkana Bar (A unit A P Hospitality) at same address now owner and name of restaurant has been changed.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in NBC Part - IV, the FSC issued vide letter no. F6/DFS/MS/EH/2019/1878 dated 30.09.2019 is recommended to be renewed

[Signature]
14/3/2024

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (L.N)

~~DY. CFO NDZ~~

[Signature]
15/03/24

~~C.F.O.~~

[Signature]
15/03/2024

[Signature]
15/03/24

[Signature]
ADO/LN

P.T.O