

C 39

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
 [Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI

No. F6/DFS/MS/2024/School/215

Dated: 20/03/2024

FIRE SAFETY CERTIFICATE

Certified that the building of St. Thomas School, Located at Goyala Vihar, Near Sector-19, Dwarka, New Delhi-110074, comprised of basement, Ground + 03 Upper Floors owned/occupied by St. Thomas School was issued FSC vide Letter No. F6/DFS/MS/2021/SZ/49, dated 20-01-2021. The premises was re inspected by the officer concerned of this department on 05/03/2024 in the presence of Sh. Naresh Sharma and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Educational" Group B with effect from 20/03/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/03/2024 at New Delhi by.

(Atul Garg)
 Director
 Delhi Fire Service.

Copy to:-

1. The Principal, St. Thomas School, Goyala Vihar, Near Sector-19, Dwarka, New Delhi-110074
2. Director of Education Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. A temporary structure / rooms created at terrace shall not be used for school activity.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per building by laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expired.

N/IS-

INSPECTION REPORT

1. Name & address of the building: St. Thomas School, Goyala Vihar, Near Sector-19, Dwarka, New Delhi-110074.
2. Type of Occupancy : Educational (Basement + Ground + 3 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2021/SZ/49, dated 20-01-2021
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 05-03-2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Naresh Sharma
9. Year of Construction : 2005
10. Applicant's letter No. : STS/2024, dated 20-01-2024

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement as per N/11, N/12 & N/13	Provided at site	Remarks MR/NMR
1	Access of building			
	• Road width	Accessible 06 mtr	15	MR
	• Gate width	4.5mtr	5.9	MR
	• Width of internal road	NA	NA	NA
2	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 No's	04 No's	MR
	• Basements	03 No's	04 No's	MR
	b. Width of staircases			
	• Upper floors	150 cms	150 cmsX4	MR
	• Basements	150 cms	150 cmsX4	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Two	MR
	e. Width Of Corridor	150 cms	200 cms	MR
	f. Door Size	100 cms	110 cms (single)	MR
3	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	Required	Exhaust fans are provided	MR
	• Upper floors	Required	Natural ventilation provided	MR
5	Fire Extinguishers			
	• Total numbers	30 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	ISI marked	MR

N/15

6.	First – Aid Hose Reels			
	• Total numbers on each floor	02 no's	Provided	MR
	• Length of hose reel hose	30mtr	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	100mm	NA
	• Number of hydrants per floor	NA	02	NA
	• Hose Box	NA	02	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm & 180lpm	Provided	MR
	➤ Head of the pump	40Mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	50,000ltrs	Provided	MR
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15,000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR

N/17

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	NA	Provided	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F5/DFS/MS/2021/SZ/49, dated 20-01-2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note; - The temporary structure / rooms created at terrace shall not be used for school activity. This instruction has been given to school Management.

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation ADP/1005

12/13/24
12/13/24
 CFo/(S2)
14/07/2024
 Director 15/07/24
ADP/1005