



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



C-42

No. F6/DFS/MS/2024/Cinema/ 192

Dated: 26/03/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Amba Cinema** located at **Subzi Mandi, Ganta Ghar, Delhi-110007** comprised of **basement, ground & 02 upper floors** owned/ occupied by **Amba Cinema** was issued fire safety certificate vide letter no. **F6/DFS/MS/2021/343 Dated 23.07.2021** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety accordance with rule 33 of the Delhi Fire Service rule 2010 and verified by the officer concerned of Delhi Fire Service on **18.03.2024** in the presence of **Sh. K.P. Siddiqui (Manager)** and that the premises is fit for occupancy class "**Group D Assembly (Cinema Hall)**" for **ground & two upper floors only** with effect from **26/03/2024** for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules, 2010.

Issued on **26/03/2024** at New Delhi by

(Anil Garg)  
Director  
Ph:-011-23414000

Copy to :-

1. The Manager, Amba Cinema located at Subzi Mandi, Ganta Ghar, Delhi-110007.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : Amba Cinema at Subzi Mandi, Ganta Ghar, Delhi-110007.
2. Type of Occupancy : Assembly
3. Composition of building : Basement, Ground & 02 upper floors
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2021/343 Dated: 23.07.2021
6. Fire Safety directives letter No : --
7. Date of inspection : 18.03.2024 **Basement- Vacant/locked**
8. Name of the Inspecting Officers : ADO/RN **Ground floor- cinema hall**
9. Name and designation of officers **First floor- cinema hall**  
from the building side : Sh. K.P. Siddiqui (Manager) **Second floor- cinema hall**
10. Year of Construction : --
11. Applicant's letter No. : Letter no. Nil dated 22.02.2024

S. No	Minimum Standards on fire prevention and fire safety U/R 33	Delhi Cinematograph Rules	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	09m 06m NA	12m 06m NA	MR MR NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02, Old case NA	02, Old case NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	Old case NA	1.50m each NA	MR (old case) NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	Required Required	Provided Provided	MR MR
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	Old case	1.50m	MR (old case)
	f. Door Size	Old case	1.50m	MR(old case)
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Required Required Required NA NA	Provided Provided Provided NA NA	MR MR MR NA NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA Required	NA Provided	NA MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	25nos CO2, WCO2, DCP type ISI marked	31nos 11-CO2, 17- WCO2 & 03- DCP type Yes	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	Required	03, Provided	MR

		N(12)		
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	30m	Provided	MR
		5mm	Provided	
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	4"	Provided	MR
		One	Provided	MR
		Required	Provided	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	Required	Provided	MR
		Required	Provided	MR
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul>	2280 LPM	2280 LPM	MR
		60m	60m	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
		450 LPM	450 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> </ul>	50,000 LTR	50,000 LTR	MR
		Required	Provided	MR
		Required	Provided	MR

*Signature*

	• Overhead Tank capacity	20,000 LTR	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room.			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. F6/DFS/MS/2021/343 dated 23.07.2021 under rule 37 of the Delhi Fire Service Rules 2010.

Dy. Chief Fire Officer (WZ)

Signature of the Inspecting Officer

Name :- C.L. Meena

Designation:- ADO/RN

DCFO/.....762.....  
Dated...19/3/2024

*[Signature]*  
19/3/2024

*[Signature]*  
19/3/2024

Director  
*[Signature]*  
20/3/24