

C/14

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/2024/ C.C. | 21

Dated: 27/03/2024

**FIRE SAFETY CERTIFICATE**

Certified that building of Coaching center Located at Ground, 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> floor on Plot No. 50, Sector-12B, Dwarka, New Delhi – 110075 in the building **comprised of Basement + Ground + 03 Upper Floors owned/ occupied by Raghav Education Foundation** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 06/03/2024 in the presence of Sh Krishan Bansal (Director) and found that the said building is fit for occupancy class "Educational" Group B Sub Division B – 1( **Coaching Centre**) with effect from 27/03/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/03/2024 at New Delhi.

  
(Atal Garg)  
Director  
Delhi Fire Service  
8/c  
27/3/24

Copy to:

1. Sh. Krishan Bansal (Director), Coaching center Located at Ground, 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> floor Plot No. 50, Sector-12B, Dwarka, New Delhi – 110075.
2. The Executive Engineer (Bldg.) HQ, Muncipal Corporation of Delhi, 9<sup>th</sup> floor, Minto Road New Delhi – 110002.

**Following fire safety directives must be adhered to:-**

1. **All the exits passage leading to stairs shall be kept clear and free from lock & keys.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. Basement shall be used strictly as per building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building: Coaching center Located at Ground, 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> floor Plot No. 50, Sector-12B, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Educational ,(Basement + Ground +03 UFs)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 06-03-2024
7. Name of the Inspecting Officer :DO/SW & ADO (DWK)
8. Name and designation of Officer  
from the building side : Sh Krishan Bansal (Director)
9. Year of Construction : 2022-23
10. Applicant's letter No. : DFS Outdoor diary No. 13449, dated 22/02/2024

| S No | Minimum standards on fire prevention and fire safety U/R 33 | As per NBC           | Provided at site | Remarks MR/NMR |
|------|---|----------------------|------------------|----------------|
| 1.   | Access of building  |                      |                  |                |
|      | • Road width  | 06mtrs               | Provided         | MR             |
|      | • Gate width  | 6 mtrs               | On Road          | MR             |
|      | • Width of internal road                                    | NA                   | NA               | NA             |
| 2.   | Number, width, Type & Arrangements of exits                 |                      |                  |                |
|      | a. Number of staircases                                     | 02 Nos.              | Provided         | MR             |
|      | • Upper floors  | 2                    | Provided         | MR             |
|      | • Basements   |                      |                  |                |
|      | b. Width of staircases                                      |                      |                  |                |
|      | • Upper floors  | 1.5m                 | Provided         | MR             |
|      | • Basements   | 1.5m                 | Provided         | MR             |
|      | c. Protection of exits                                      |                      |                  |                |
|      | • Fire check door   | Required             | Provided         | MR             |
|      | • Pressurization  | NA                   | NA               | NA             |
|      | d. No of continuous staircase to terrace                    | Required             | 01 Provided      | MR             |
|      | e. Width Of Corridor  | 1.5 m                | Provided         | MR             |
|      | f. Door Size  | 01 mtr               | Provided         | MR             |
| 3.   | Compartmentation  |                      |                  |                |
|      | • Fire check door   | Required in basement | Provided         | MR             |
|      | • Sealing of electrical shafts                              | NA                   | NA               | NA             |
|      | • Fire Rating of shaft door                                 | NA                   | NA               | NA             |
|      | • Water Curtain   | NA                   | NA               | NA             |
|      | • Fire Dampers  | NA                   | NA               | NA             |



|     |  |                        |                              |    |
|-----|--|------------------------|------------------------------|----|
| 4.  | Smoke managements System                     |                        |                              |    |
|     | • Basements                                  | 30 a/c charge per hour | Provided                     | MR |
|     | • Upper floors                               | 12 a/c charge per hour | Natural ventilation          | MR |
| 5.  | Fire Extinguishers                           |                        |                              |    |
|     | • Total numbers                              | 14 nos.                | Provided                     | MR |
|     | • Types                                      | ABC & CO <sub>2</sub>  | DCP, CO <sub>2</sub> & Water | MR |
|     | • IS marking                                 | ISI marked             | Provided                     | MR |
| 6.  | First – Aid Hose Reels                       |                        |                              |    |
|     | • Total numbers on each floor                | 01 No.                 | Provided                     | MR |
|     | • Length of hose reel hose                   | 30m                    | Provided                     | MR |
|     | • Nozzle diameter                            | 5mm                    | Provided                     | MR |
| 7.  | Automatic fire detection and alarming system |                        |                              |    |
|     | • Type of detectors                          | NA                     | NA                           | NA |
|     | • Location of Main Panel                     | NA                     | NA                           | NA |
|     | • Location of Repeater Panel                 | NA                     | NA                           | NA |
|     | • Alternate source of power                  | NA                     | NA                           | NA |
|     | • Hooters' Location                          | NA                     | NA                           | NA |
| 8.  | MOEFA  | NA                     | Provided                     | NA |
| 9.  | Public Address System                        | NA                     | Provided                     | NA |
| 10. | Automatic Sprinkler System                   |                        |                              |    |
|     | • Basements                                  | Required               | Provided                     | MR |
|     | • Upper Floor                                | NA                     | NA                           | NA |
|     | • Sprinkler above false ceiling              | NA                     | NA                           | NA |
| 11. | Internal Hydrants:                           |                        |                              |    |
|     | • Size of riser/down- comer                  | NA                     | NA                           | NA |
|     | • Number of hydrants per floor               | NA                     | NA                           | NA |
|     | • Hose Box                                   | NA                     | NA                           | NA |
| 12. | Yard Hydrants                                |                        |                              |    |
|     | • Total number of hydrants                   | NA                     | NA                           | NA |
|     | • Hose Box                                   | NA                     | NA                           | NA |
| 13. | Pumping Arrangements                         |                        |                              |    |
|     | • Ground Level                               |                        |                              |    |
|     | • Discharge of main pump                     | NA                     | NA                           | NA |
|     | ➤ Head of main pump                          | NA                     | NA                           | NA |
|     | ➤ Number of main pumps                       | NA                     | NA                           | NA |
|     | ➤ Jockey pump out put                        | NA                     | NA                           | NA |
|     | ➤ Jockey pump head                           | NA                     | NA                           | NA |
|     | ➤ Standby Pump out put                       | NA                     | NA                           | NA |
|     | ➤ Standby Pump Head                          | NA                     | NA                           | NA |
|     | ➤ Auto Staring/Manual stopping               | NA                     | NA                           | NA |
|     | ➤ Pump House Access                          | NA                     | NA                           | NA |
|     | • Terrace level                              |                        |                              |    |
|     | ➤ Discharge of pump                          | 900 lpm                | Provided                     | MR |
|     | ➤ Head of the pump                           | 30Mtr                  | 30 mtr                       | MR |
|     | ➤ Power supply                               | Required               | Provided                     | MR |
|     | ➤ Auto starting of pump                      | Required               | Provided                     | MR |

*[Handwritten marks]*

M/4

|    |  |          |          |    |
|----|--|----------|----------|----|
| 14 | Captive water Storage for fire fighting:                                 |          |          |    |
|    | • Underground tank capacity  | NA       | NA       | NA |
|    | ➤ Draw off connection  | NA       | NA       | NA |
|    | ➤ Fire service inlet   | Required | Provided | MR |
|    | ➤ Access to tank   | NA       | NA       | NA |
|    | • Overhead Tank capacity   | 15,000 L | Provided | MR |
| 15 | Exit Signage   | Required | Provided | MR |
| 16 | Provision of Lifts   |          |          |    |
|    | ➤ Pressurization of Lift Shaft   | NA       | NA       | NA |
|    | ➤ Pressurization of lift lobby   | NA       | NA       | NA |
|    | ➤ Communication in lift Car  | Required | Provided | MR |
|    | ➤ Fireman's Grounding Switch   | Required | Provided | MR |
|    | ➤ Lift Signage   | Required | Provided | MR |
| 17 | Standby power supply   | Required | DG Set   | MR |
| 18 | Refuge Area  |          |          |    |
|    | ➤ Total area   | NA       | NA       | NA |
|    | ➤ Location   | NA       | NA       | NA |
| 19 | Fire control room  |          |          |    |
|    | 1. Detector system panel   | NA       | NA       | NA |
|    | 2. Flow Switch Panel   | NA       | NA       | NA |
|    | 3. PA System Panel   | NA       | NA       | NA |
|    | 4. Battery backup  | NA       | NA       | NA |
|    | 5. Building Floor Plans  | NA       | NA       | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any; | NA       | NA       | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010. If approved, the FSC may be issued.

*[Handwritten Signature]*  
15/3/24

Sign of Inspecting Officer  
Name: Sh. Vedpal  
Designation: DO/SW

*[Handwritten Signature]*  
15/3/24

Sign of Inspecting Officer  
Name: Udai vir Singh  
Designation: ADO/DWK

CFO (S2) *[Handwritten Signature]*  
18/3/2024  
Director *[Handwritten Signature]*

what about the Banker *[Handwritten Signature]*

*[Handwritten Signature]*