



No. F6/DFS/MS/School/NDZ/2024/ 249

Dated: 27/03/2024

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Girls Sr. Sec. School No-2, located at New Seelampur, Delhi-110053,** comprised of **Ground plus three upper floors & Ground plus one upper floor (Two separate blocks)** owned/occupied by **Govt. Girls Sr. Sec. School No-2,** was issued FSC vide letter No. F6/DFS/MS/School/2021/NDZ/257 dated 26/03/2021. The School building have complied with the fire prevention and fire safety requirements in accordance with NBC Part-IV and re-inspected by the officer concerned of this department on 18/03/2024 in presence of Mr. Rakesh Kumar (Principal) of the school and found that the school building is fit for occupancy class **“Educational Building” (Group-B)** with effect from 27/03/2024 for a period of **three years** in accordance with Rule 36 unless renewal under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed bellow.

Issued on 27/03/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi-110053.
2. The Principal, Govt. Girls Sr. Sec. School No-2, New Seelampur, Delhi-110032.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/26

INSPECTION REPORT

01.	Name & address of the building	Govt. Girls Sr. Sec. School No-2, located at New Seelampur, Delhi-110053.			
02.	Building is comprised of	Ground + 03 & Ground + 01 (in two separate block)			
03.	Type of occupancy	Educational Building			
04.	Type of case	Renewal			
05.	Details of previous FSC	F6/DFS/MS/School/2021/NDZ/257 dated 26/03/2021.			
06.	Fire safety directives letter no.	NBC Part-IV			
07.	Date of inspection	18/03/2024			
08.	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)			
09.	Name of the designation of officer from the building side	Mr.Rakesh Kumar (Principal)			
10.	Year of construction	1984			
11.	Applicant's letter no.	Outdoor dairy no. 13969 dated 07/03/2024			
SNo	Minimum standard of fire prevention and fire safety U/R 33	Requirement NBC Part-IV	Provided at site	Remarks MR/NMR	
01.	Access to Building:				
	A	Road width	06 mtrs.	06mtrs.	MR
	B	Gate width	4.5 mtrs	4.5 mtrs	MR
	C	Width of internal road	NA	NA	NA
02.	Number, Width, Type and Arrangement of Exits:				
	A	Number of staircases			
	a	Upper floor (G+3)	02 nos. ✓	02 nos. ✓	MR
		Upper floor (G+1)	01 no ✓	01 no ✓	MR
	b	Basement	NA	NA	NA
	B	Width of staircases			
	a	Upper floor	1.50 mtrs ✓	1.50 mtrs. each block ✓	MR
	b	Basement	NA	NA	NA
	C	Protection of exits			
	a	Fire check door	NA	NA	NA
	b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace	01 no.	01 no ✓	MR
	E	Width of corridor	1.50 mtrs.	2.50 mtrs. ✓	MR
	F	Door size	1.0 mtr.	1.0 mtr. ✓	MR
03.	Compartmentation:				
	A	Fire check door	NA	NA	NA
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft door	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
04.	Smoke Management System:				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA

(u)

05.	Fire Extinguisher:				
	A	Total numbers	12 nos.	12 nos. ✓	MR
	B	Types	ABC/CO ₂	ABC/CO ₂	MR
	C	ISI marking	ISI Marked	ISI Marked	MR
06.	First-Aid-Hose Reel:				
	A	Total numbers of each floor	01 nos.	01 nos. ✓	MR
	B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	C	Nozzle diameter	05 mm	05 mm	MR
07.	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	NA	NA	NA
	B	Location of main panel	NA	NA	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	NA	NA	NA
	E	Hooters	NA	NA	NA
08.	MOEFA:				
			NA	NA	NA
09	Public Address System:				
			NA	NA	NA
10.	Automatic Sprinkler System:				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:				
	A	Size of riser/down-comer	NA	NA	NA
	B	Number of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12.	Yard Hydrants:				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13.	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	NA	NA	NA
	B	Head of main pump	NA	NA	NA
	C	Number of main pumps	NA	NA	NA
	D	Jockey pump out put	NA	NA	NA
	E	Jockey pump head	NA	NA	NA
	F	Standby pump out put	NA	NA	NA
	G	Standby pump head	NA	NA	NA
	H	Auto starting /manual stopping	NA	NA	NA
2	Terrace Level				
	A	Discharge of pump	450 LPM	2 X 450 LPM ✓	MR
	B	Head of the pump	40 mtrs.	40 mtrs.	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR


①





90/


14. Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	NA	NA
B	Draw-off connection	NA	NA
C	Fire service inlet	NA	NA
D	Access to tank	NA	NA
E	Overhead tank capacity	10,000 liters.	10,000 liters. MR
15. Exit Signage:		Required	Provided MR
16. Provision of Lifts:			
A	Pressurization of lift shaft	NA	NA
B	Pressurization of lift lobby	NA	NA
C	Communication in lift car	NA	NA
D	Firemen's grounding switch	NA	NA
E	Lift signage	NA	NA
17. Standby Power Supply:		NA	NA
18. Refuge Area:			
A	Total area	NA	NA
B	Location	NA	NA
19. Fire Control Room:			
A	Detector system panel	NA	NA
B	Flow switch panel	NA	NA
C	PA system panel	NA	NA
D	Battery backup	NA	NA
E	Building floor plans	NA	NA
20. Special Fire Protection systems for protection of special Risks, if any:		NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in NBC (Part-IV) the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2021/NDZ/257 dated 26/03/2021 is recommended to be renewed


 Signature of the Inspecting Officer
 Name:- Yashwant Singh Meena
 Designation:- ADO (L.N)

Dy. CFO (NDZ)

 C.F.O.

 Director

 Sir,
 F. T Letter is Autup for sign. Please
 Director



 21/3/2024