

C-34

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/School/256

Dated: 28/03/2024

FIRE SAFETY CERTIFICATE

Certified that the Building Mount Carmel Nursery School Located at, HAF Plot No 3, Sector - 22, Dwarka, New Delhi - 110077 comprised of Basement + Ground + 02 Upper Floor was issued Fire Safety Certificate by this department vide Letter No. F6/DFS/MS/SZ/2021/833, Dated 07/10/21. The premises was re inspected by the officer concerned of this department on 20/03/2024 in the presence of Ms. Anju (Admin Officer). All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with DOE 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class B "Educational" with effect from 28/03/24 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/03/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service.
O/c
28/3/24

Copy to:

1. Directorate of Education Old Secretariat Delhi - 110054.
2. The Principal, Mount Carmel Nursery School HAF Located at, Plot No 3, Sector - 22, Dwarka, New Delhi - 110077.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N/19

INSPECTION REPORT

1. Name & address of the building: Mount Carmel Nursery School HAF
Located at, Plot No 3, Sector - 22, Dwarka, New Delhi - 110077.
2. Type of Occupancy : Educational (Basement + Ground+ 2 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SZ/2021/833, Dated 07/10/21
5. Fire Safety directives L. No. : DOE 3298-3398 dated 1-3-2011
6. Date of inspection : 20/03/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer from the building side : Ms. Anju (Admin Officer)
9. Year of Construction : 2012
10. Applicant's letter No. : MCS-DW/Jr.Sch/Fire Cert/2024/1130 Dated 31/01/24

No. of Students=418
No. of class rooms=12
Plot area=520 sqm
Covered area=300 sqm

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/3, N/4 & N/5	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Approachable F E	18 mtr	MR (being old case)
		Old case	04 mtr	MR (being old case)
		NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	Old case	1.40 mtr each (Including Railing)	MR (old case)
	• Basements	Old case	1.40 mtr each(Including Railing)	MR (old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	2 Nos, Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1m	01 mtr	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c charge	Exhaust fans provided	MR
	• Upper floors	12 a/c charge	Natural ventilation	MR

(Handwritten signature)

N/20

5.	Fire Extinguishers			
	• Total numbers	06 nos.	06 Nos.	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	Required	01 Provided	MR
		30 mtr	Provided	MR
	• Length of hose reel hose	05 mm	Provided	MR
	• Nozzle diameter			
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	Old case	450 LPM Provided	MR
	➤ Head of the pump	Old case	40 mtr Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	Provided	MR
	• Overhead Tank capacity	.15,000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR



16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F6/DFS/MS/SZ/2021/833, Dated 07/10/21 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved FSC may be issued.

[Handwritten Signature]
21/3/24

Signature of the Inspecting Officer
Name *Uday Vir Singh*
Designation *ADP/OWR*

[Handwritten Signature]
21/3/24

[Handwritten Signature]
22/3/2024

[Handwritten Signature]
25/3/24

[Handwritten Signature]

[Handwritten Signature]
26/3/24

[Handwritten Signature]
26/3/24