



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 234

Dated: 22/03/2024

FIRE SAFETY CERTIFICATE

Certified that the **Springdales School** located at Benito Juarez Marg, Dhaula Kuan, New Delhi-110021 comprised of Basement, Ground +3 Upper Floors (Two Blocks) has already been issued **Fire Safety Certificate** vide letter No F.6/DFS/MS/School/SZ/2021/97 dated 03/02/2021. The premise was re-inspected by the officer concerned of this department on 11/03/2024 in the presence of Sh. Arjun Singh (Admin Officer) and observed that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular No. 262-362 dated 17/01/2005 and that the building/premises is fit for occupancy class "**Educational**" (Group-B) with effect from 22/03/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/03/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
01/03/24

Copy to: -

1. The Principal Springdales School at Benito Juarez Marg, Dhaula Kuan, New Delhi-110021
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. **An additional staircase in the senior (new) wing shall be provided within a period of 06 (Six) months, else this Fire Safety Certificate shall stand withdrawn/cancelled.**
2. All the means of escape / entry / exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1.	Name & address of the building	Springdales School, Benito Juarez Marg, Dhaula Kuan, New Delhi-110021		
2.	Type of Occupancy	Educational		
3.	Building Comprised of	Basement, Ground +3 Upper Floors (Two Blocks)		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/School/SZ/2021/97 dt.03/02/2021		
6.	Fire Safety directives Letter No.	DOE Circular dated 17.01.2005		
7.	Date of inspection	11/03/2024		
8.	Name of the Inspecting Officer	Santosh Kumar (ADO/SJ)		
9.	Name and designation of Officer from the building side	Sh. Arjun Singh (Admin Officer)		
10.	Year of Construction	2006		
11.	Applicant's letter No	Outdoor Diary No. 11719 dated 10/01/2024		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Requirements/ DOE Circular dated 01/03/2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Required Required N/A 	<ul style="list-style-type: none"> 12m 5mtr N/A 	<ul style="list-style-type: none"> MR MR N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> Required Required 	<ul style="list-style-type: none"> 1 in 1st Block 3 in 2nd Block 1 (each Basement) 	<ul style="list-style-type: none"> MR (Old case) MR (Old case)
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 1.50 / 0.75m 1.50 / 0.75m 	<ul style="list-style-type: none"> 1.35m (1st Blk) & 1.75m, 1.30m & 1.50 (2nd Blk) 0.80m in 1st Blk 1.4m in 2nd Blk 	<ul style="list-style-type: none"> MR (Old case) MR (Old case)
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A
	d. No of continuous staircase to terrace	Required	1 in 1 st Block 2 in 2 nd Block	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00m	1.00m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> Required NA 	<ul style="list-style-type: none"> Exhaust Fan NA 	<ul style="list-style-type: none"> MR NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	<ul style="list-style-type: none"> 40 Nos ABC/CO₂ ISI Marked 	<ul style="list-style-type: none"> 40 Nos ABC & CO₂ Provided 	<ul style="list-style-type: none"> MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	<ul style="list-style-type: none"> 1 in 1st Block 2 in 2nd Block 30m 5mm 	<ul style="list-style-type: none"> 1 in 1st Block 2 in 2nd Block 30m 5mm 	<ul style="list-style-type: none"> MR MR MR

80

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	100mm	NA
	• Number of hydrants per floor	NA	1 in 1 st Blk & 2 in 2 nd Blk	NA
	• Hose Box	NA	1 in 1 st Blk & 2 in 2 nd Blk	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM x 2	450 LPM x 3	MR
	➤ Head of the pump	40m each	40m each	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltr each x 2	10,000 ltr each x 3	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA


19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note: The requirement of an additional staircase in the senior (new) wing was observed/recommended by this department vide letter No. F6/DFS/MS/2010/2168 dated 22/07/2010 (at N/29). Further, FSC was issued by this department on the basis of request letter of Dr. (Mrs.) Jyoti Bose, the then principal of Springdales School, Dhaula Kuan (at C/51) regarding giving time to provide the required additional staircase. The same has not been provided till date. We may ask the school management to provide an additional staircase within a period of 06 (Six) months, else the FSC being issued shall stand withdrawn/cancelled.

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter No F.6/DFS/MS/School/SZ/2021/97 dt.03/02/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.



 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (SJ)

DO (SD)

Mull
14/3/24

c/o Mull
 18/3/2024
 Director [Signature] 19/03/24
[Signature] (AD)

Sir, F.T letter is put up for your sig. pl.

Director [Signature]
 M,

 20.03.24