

436

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2024/SZ/ 261

Dated: 01/04/2024

FIRE SAFETY CERTIFICATE

Certified that the **Aakash International School**, G-2 Block, Jai Vihar, New Delhi-110043, comprised of basement having storage in hall, ground floor plus three upper floors, was issued Fire Safety Certificate vide letter no. F.6/DFS/MS/School/2020/SZ/474 dated 05.11.2020. The school building was re-inspected by the officer concerned of this department on 20.03.2024 in the presence of Smt. Deepa Rani (Vice Principal) and found that the Aakash International School have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" with effect from ..01/04/2024.. for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on...01/04/2024..... at New Delhi.


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Principal, Aakash International School, G-2 Block, Jai Vihar, New Delhi-110043
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/LG

INSPECTION REPORT

1. Name & address of the building : Aakash International School, G-2 Block, Jai Vihar, New Delhi-110043.
2. Building Comprised of : Basement, ground plus three upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2020/SZ/474 dated 05.11.2020
6. Fire Safety directives letter No : N/A
7. Date of inspection : 20.03.2024
8. Name of Inspecting Officer : R.K. Yadav, ADO (JKP)
9. Name and designation of officers
From the building side : Smt. Deepa Rani (Vice Principal)
10. Year of Construction : 2005 & 2016-17
11. Applicant's letter No. : AIS/F-Safety/New/2024 dated 05.03.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/UBBL requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 4.5 mtrs N/A	5.5 mtrs 4.65 mtrs N/A	M/R, being old case MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 no.'s	02 no.'s	M/R
	• Basements	02 no.'s	03 no.'s	M/R
	b. Width of staircases			
	• Upper Floor	150 cms	180 & 150 cms	M/R
	• Basements	150 cms	275, 180 & 155 cms	M/R
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
	Required		One	M/R
	e. Width of Corridor	150 cms.	300 cms.	M/R
	f. Door Size	100 cms	100 cms (Double door)	M/R
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	Required	Exhaust fans are provided	M/R
	• Upper floors	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	• Total numbers	10 no's	Provided	M/R
	• Types	ABC/CO ₂ type	Provided	M/R
	• IS marking	ISI marked	Provided	M/R

h/

N/17

6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30 mtrs 5 mm	<ul style="list-style-type: none"> Provided Provided Provided 	<ul style="list-style-type: none"> M/R M/R M/R
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A
8.	MOEFA	N/A	Provided	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	<ul style="list-style-type: none"> Required N/A N/A 	<ul style="list-style-type: none"> Provided N/A N/A 	<ul style="list-style-type: none"> M/R N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	<ul style="list-style-type: none"> N/A N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 900 LPM 40 mtrs Required Required 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A Provided Provided Provided Provided 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A M/R M/R M/R M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	<ul style="list-style-type: none"> N/A N/A N/A N/A 15000 ltrs Required 	<ul style="list-style-type: none"> N/A N/A N/A N/A Provided Provided 	<ul style="list-style-type: none"> N/A N/A N/A N/A M/R M/R
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A 	<ul style="list-style-type: none"> N/A N/A N/A N/A N/A


Rg

W


17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/School/2020/SZ/474 dated 05.11.2020, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.



 Signature of Inspecting Officer
 Name:- R.K. Yadav
 Designation:- ADO (JKP)

DO (South West)


21/11/24

CFO (S2) 
22/11/2024

Director


21/11/24

