

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2024/SZ/ 262

Dated: 01/04/2024

FIRE SAFETY CERTIFICATE

Certified that the **Ambience Public School**, located at **Plot No- A-1, Safdarjung Enclave, New Delhi - 110029** comprised of 2 tier Basement, Ground and Four upper floors (lower basement & caretaker room at terrace floor are sealed) owned/ occupied by Ambience Education Society was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2021/SZ/221 Dt. 12/03/2021. The said premises was re-inspected by officer concerned of this department on 19/03/2024 in presence of Sh. Manoj Shah of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building (**one basement, ground plus four upper floors only**) is fit for occupancy class "**Educational Building Group - B**" with effect from 01/04/2024 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 01/04/2024 at New Delhi by


**(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE**

Copy to: -

1. The Principal, Ambience Public School, at Plot No- A-1, Safdarjung Enclave, New Delhi - 110029.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi -54

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/25

INSPECTION REPORT

1	Name & Address of the Building	Ambience Public School, at Plot No A-1, Safdarjung, Enclave, New Delhi 110029		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	(Basement-1, Sealed) & B-2 + Ground + Four Upper Floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2021/SZ/221 Dt. 12/03/2021		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2011/1093 Dated 03/06/2014		
7	Date of Inspection	19-03-2024		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Manoj Shah		
10	Year of construction	2014		
11	Applicant letter No.	Outdoor diary no 14083 dated 11/03/2024		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	6 mtr	6 mtr	MR
	• Width of internal road	6 mtr	6 mtr	MR
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	03 No's	03 No's	MR
	➤ Basement floor.	03 No's	03 No's + 01 Ramp	MR
	b) Width of Staircase			
	➤ Upper floors	2.0 mtr each	2.0 mtr each	MR
	➤ Basement floor	2.0 mtr & 1.5 mtr	2 x 2 mtr, 1.50 mtr & ramp 2 way, 6 mtr	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	Required	Provided	MR
	d) No. of continuous staircase to terrace	03 Required	03 Provided	MR
	e) Width of corridor	1.5 m	Provided	MR
	f) Door size	1 mtr	1 mtr	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	Required	Provided	MR
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	Required	Provided	MR
4.	Smoke Management system.			
	• Basement	30 ACPH	Provided	MR
	• Upper floors	12 ACPH	Provided	MR
5.	Fire Extinguishers.			
	• Total numbers	40 Required	46 Nos	MR
	• Types	ABC / wco2	ABC / wco2 Type	MR
	• ISI Marking	ISI mark	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	Three Nos	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

N/26

7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	NA	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		NA	Provided	NA
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	Required	150 mm	MR
		Required	03 No's	MR
		Required	03 No's	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting / Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		900 LPM	900 LPM x 2 Nos	MR
		40 mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
		50,000 ltrs	50,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	Fire Control Room.			

M27

<ul style="list-style-type: none"> • Detector system panel. • Flow switch panel. • PA system panel. • Battery backup. • Building floor plan. 	-NA-	-NA-	-NA-
	Required	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
20. Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 74 dated 22/02/2024.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DPS/MS/School/2021/SZ/221 Dt. 12/03/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Manoj Kumar Sharma
Signature of the Inspecting Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

Sh. Rajesh Kumar
Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

CFO (HQ)

Manoj
22/02/2024

Director
20/09/20

Manoj

As approved, F.T letter is put up for your signature pl.

Director
20/09/20
M

Manoj
28/3/2024