



No. F6/DFS/MS/WZ/2023/CNG/ 202

Dated:- 01/04/2024

**FIRE SAFETY CERTIFICATE**

Certified that the CNG Dispensing Station Located at Lok Nayak Puram, Plot No. -3, Site No. -1, Bakkarwala, New Delhi-110041, comprised of Ground Floor only, owned / occupied by Indraprastha Gas Limited, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/2020/CNG/367 Dated 16/09/2020. The said premise was re-inspected by the officer concerned of this department on 14/03/2024 in the presence of Sh. Jogender Singh, (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Hazardous Building" Group - J with effect from 01/04/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 01/04/2024 at New Delhi by.

(Arul Garg)  
Director

Tel. No. 011-23414000

Copy to: -

1. Sh. Ajay Khatri, GM (Fire & Safety), IGL Bhawan, Plot no. 4, Community Centre, Sector-9, R.K. Puram, New Delhi-110022.

**Conditions for the validity of Fire Safety Certificate:-**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of authorized construction or alteration (Clause of 1.4.3 of UBBL-2016), if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

### INSPECTION REPORT

1	Name & Address of the Building	CNG Dispensing Station at Lok Nayak Puram, Plot No. 3, Site No. 1, Bakkarwala, New Delhi-110041		
2	Type of Occupancy	Hazardous "Group- J"		
3	Type of Case	Renewal (Ground Floor only)		
4	Details of Previous NOC	F6/DFS/MS/2020/CNG/367 dated 16.09.2020		
5	Fire Safety Directives Letter No	OISD-179		
6	Date of Inspection	14/03/2024		
7	Name of the Inspecting Officers	Aman Kumar Lathar, ADO (JWP)		
8	Name & Designation of Officers from the building side	Sh. Jogender Singh (Manager)		
9	Year of construction	2012		
10	Applicant letter No.	IGL/F&S/2024/15/93/1 dated 20/02/2024		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>NFPA/CCOE/OISD etc. requirements</b>	<b>Provided at Site</b>	<b>Remarks NR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	• Road width	06 m	30 m	MR
	• Gate width	-N/A-	Direct accessible from road	-N/A-
	• Width of internal road	-N/A-	-N/A-	-N/A-
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	-N/A-	-N/A-	-N/A-
	➤ Basement floor.	-N/A-	-N/A-	-N/A-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	-N/A-	-N/A-	-N/A-
	➤ Basement floor	-N/A-	-N/A-	-N/A-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-N/A-	-N/A-	-N/A-
	➤ Pressurization	-N/A-	-N/A-	-N/A-
	<b>d) No. of continuous staircase to terrace</b>	-N/A-	-N/A-	-N/A-
	<b>e) Width of corridor</b>	-N/A-	-N/A-	-N/A-
	<b>f) Door size</b>	01 m	Provided	MR
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door.	-N/A-	-N/A-	-N/A-
	• Sealing of electrical shafts.	-N/A-	-N/A-	-N/A-
	• Fire rating of shaft door.	-N/A-	-N/A-	-N/A-
	• Water curtain	-N/A-	-N/A-	-N/A-
	• Fire dampers.	-N/A-	-N/A-	-N/A-
<b>4.</b>	<b>Smoke Management system.</b>			
	• Basement	-N/A-	-N/A-	-N/A-
	• Upper floors	-N/A-	-N/A-	-N/A-
<b>5.</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	14	17	MR
	• Types	DCP & CO <sub>2</sub>	DCP 75kg-04, 10kg-10 & CO <sub>2</sub> 4.5kg - 03	MR
	• ISI Marking	ISI marked	Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor	-N/A-	-N/A-	-N/A-
	• Length of hose-reel hose.	-N/A-	-N/A-	-N/A-
	• Nozzle Diameter	-N/A-	-N/A-	-N/A-

<b>7</b>	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Gas and flame detectors in compressor packages area</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Hooter's location</li> </ul>	Required	Provided	MR
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	-N/A-	-N/A-	-N/A-
<b>10.</b>	<b>CO<sub>2</sub> Flooding System</b>			
	<ul style="list-style-type: none"> <li>Ground floor</li> </ul>	Required in compressor Area	Provided	MR
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
<b>11.</b>	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser / Down-comer</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Number of Hydrant per floor</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	-N/A-	-N/A-	-N/A-
<b>12.</b>	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	-N/A-	-N/A-	-N/A-
<b>13.</b>	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>			
	Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> </ul>			
	➤ Discharge of pump.	-N/A-	-N/A-	-N/A-
	➤ Head of pump.	-N/A-	-N/A-	-N/A-
	➤ Power supply.	-N/A-	-N/A-	-N/A-
	➤ Auto starting of pump.	-N/A-	-N/A-	-N/A-
<b>14.</b>	<b>Captive water storage for firefighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> </ul>	-N/A-	-N/A-	-N/A-
	➤ Draw-off connection.	-N/A-	-N/A-	-N/A-
	➤ Fire Service Inlet.	-N/A-	-N/A-	-N/A-
	➤ Access to tank.	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Overhead tank capacity.</li> </ul>	-N/A-	-N/A-	-N/A-
<b>15.</b>	<b>No Smoking Signage</b>	Required	Provided in Hindi & English	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Pressurization of lift lobby.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Communication in lift car.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Fireman's switch.</li> </ul>	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> <li>Lift signage.</li> </ul>	-N/A-	-N/A-	-N/A-

17	Standby Power Supply	-N/A-	Provided (DG Set)	-N/A-
18.	Refuge Area			
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A-
19.	Fire Control Room.			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	N/A-	N/A-	N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.	DCP flooding system for roof mounted cascades & advance fire water mist cum foam trolley	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection. Shortcomings issued vide letter no. F6/DFS/MS/WZ/2023/1578 dated 27/07/2023 are rectified.

In View of the deemed compliance of the minimum standards of fire prevention and fire safety requirements under the rules, renewal of FSC issued vide letter no. F6/DFS/MS/2020/CNG/367 dated 16.09.2020 is recommended under the rule 37 of the Delhi Fire Service rule, 2010 under the DFS Act 2009.

Accordingly DFA is put up for approval and signature please.

*Amith*  
15/03/24  
Aman Kumar Lathar  
ADO (JWP)

*DCFO/WZ*

*18/03*

*CFO*  
*18/03/2024*

*Director*  
*18/03/24*

FOI...199  
Dated...15/03/2024

*Amith*

Sir,  
F.T. letter is added for your signature for!

*Director*  
*28/09/24*

*Amith*  
26/03/24  
Amo (JWP)