



No. F6/DFS/MS/School/NDZ/2024/ 263

Dated: 01/04/2024

**FIRE SAFETY CERTIFICATE**

Certified that the East Point School, Located at FC-26, Dallupura, Vashundhara Enclave, Delhi-110096, building comprised of basement, ground plus three upper floors was granted owned/occupied by East Point School, was issued FSC vide letter No. F6/DFS/MS/School/NDZ/2021/300 dated 05/04/2021. The School building was re-inspected by the officer concerned of this department on 07/03/2024 in presence of Mrs. Archana Shrivastava (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational Building" (Group-B) with effect from 01/04/2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 01/04/2024 at New Delhi by.

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

**Copy to:-**

1. The Joint Director of Education (Land & Eatate), Director of Education, Lucknow Road, Delhi-110054.
2. The Principal, East Point School, Located at FC-26, Dallupura, Vashundhara Enclave, Delhi - 110096.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

**INSPECTION REPORT**

01.	Name & address of the building	East Point School, Located at FC-26, Dallupura, Vashundhara Enclave, Delhi-110096.		
02.	Building is comprised of	Basment, Ground plus Three upper floors (building divide in 4 block)		
03.	Type of occupancy	Educational Building		
04.	Type of case	Renewal		
05.	Details of previous FSC	F6/DFS/MS/School/NDZ/2021/300 dated 05/04/2021		
06.	Fire safety directives letter no.	F6/DFS/MS/BP/2017/189 dated 21/06/2017		
07.	Date of inspection	07/03/2024		
08.	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
09.	Name of the designation of officer from the building side	Mrs. Archana Shrivastava (Principal)		
10.	Year of construction	Old Building		
11.	Applicant's letter no.	Outdoor Diary no.13704dated 29/02/2024		
S.No	<b>Minimum standard of fire prevention and fire safety U/R 33</b>	<b>Requirement</b>	<b>Provided at site</b>	<b>Remarks MR/NMR</b>
01.	<b>Access to Building:</b>			
	A Road width	6.0 mtrs.	9.0 mtrs. ✓	MR
	B Gate width	4.5 mtrs	5.0 mtrs ✓	MR
	C Width of internal road	NA	NA	NA
02.	<b>Number, Width, Type and Arrangement of Exits:</b>			
	A Number of staircases			
	a Upper floor	07nos.	07 nos. ✓	MR
	b Basement	07nos.	07 nos. ✓	MR
	B Width of staircases			
	a Upper floor	1.50 mtrs (each block)	04 nos of 1.50 mtrs ✓ 02 nos of 1.8 mtrs ✓ 01 no of 02.0 mtrs ✓	MR
	b Basement	1.50 mtrs (each block)	04 nos of 1.50 mtrs ✓ 02 nos of 1.8 mtrs ✓ 01 no of 02.0 mtrs ✓	MR
	C Protection of exits			
	a Fire check door	Required	Provided ✓	MR
	b Pressurization	Required	Provided ✓	MR
	D No. of continuous staircases to terrace	02 nos.	02 nos. ✓	MR
	E Width of corridor	1.50 mtrs.	1.50 mtrs. ✓	MR
	F Door size	01 mtrs	01 mtrs	MR
03.	<b>Compartmentation:</b>			
	A Fire check door	Required	Provided	MR
	B Sealing of electrical shafts	Required	Provided	MR
	C Fire rating of shaft door	2 hrs	Provided	MR
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
04.	<b>Smoke Management System:</b>			
	A Basement	Required	Provided	MR
	B Upper floor	Required	Provided	MR

N/28

East Point School, Located at FC-26,dallupura, Vashundhara Enclave, Delhi-110096.

<b>05. Fire Extinguisher:</b>				
A	Total numbers	24 nos.	30 nos.	MR
B	Types	ABC/CO <sub>2</sub>	ABC/CO <sub>2</sub>	MR
C	ISI marking	Required	Provided	MR
<b>06. First-Aid-Hose Reel:</b>				
A	Total numbers of each floor	01 no.(each block)	Provided	MR
B	Length of hose reel hose	30 m	30 m.	MR
C	Nozzle diameter	05 mm	05 mm	MR
<b>07. Automatic Fire Detection and Alarming System:</b>				
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters	NA	NA	NA
08.	<b>MOEFA:</b>	NA	NA	NA
09	<b>Public Address System:</b>	NA	Provided	MR
<b>10. Automatic Sprinkler System:</b>				
A	Basement	Required	Provided	MR
B	Upper floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
<b>11. Internal Hydrants:</b>				
A	Size of riser/down-comer	100 mm	100 mm	MR
B	Number of hydrants per floor	01 (each block)	Provided	MR
C	Hose box	01 (each block)	Provided	MR
<b>12. Yard Hydrants:</b>				
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
<b>13. Pumping Arrangements:</b>				
<b>1</b> <b>Ground level</b>				
A	Discharge of main pump	NA	NA	NA
B	Head of main pump	NA	NA	NA
C	Number of main pumps	NA	NA	NA
D	Jockey pump out put	NA	NA	NA
E	Jockey pump head	NA	NA	NA
F	Standby pump out put	NA	NA	NA
G	Standby pump head	NA	NA	NA
H	Auto starting /manual stopping	NA	NA	NA
<b>2</b> <b>Terrace Level</b>				
A	Discharge of pump	900 LPM	Provided	MR
B	Head of the pump	40 m	Provided	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR


W

80/

<b>14. Captive Water Storage for Fire Fighting:</b>				
A	Underground tank capacity	NA	NA	NA
B	Draw-off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
D	Access to tank	NA	NA	NA
E	Overhead tank capacity	15,000 liters in each block ✓	Provided ✓	MR
<b>15. Exit Signage:</b>		Required ✓	Provided ✓	MR
<b>16. Provision of Lifts:</b>				
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Firemen's grounding switch	NA	NA	NA
E	Lift signage	NA	NA	NA
<b>17. Standby Power Supply:</b>		NA	NA	NA
<b>18. Refuge Area:</b>				
A	Total area	NA	NA	NA
B	Location	NA	NA	NA
<b>19. Fire Control Room:</b>				
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	PA system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
<b>20. Special Fire Protection systems for protection of special Risks, if any:</b>		NA	NA	NA


The fire protection systems provided in the school building were tested, checked at random and found functional at the time of inspections.


In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/DFS/MS/School//NDZ/2021/300 dated 05.04.2021, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed.

  
 22/3/2024  
 Signature of the Inspecting Officer  
 Name: - Yashwant Singh Meena  
 Designation: - ADO (L.N)

DY CFO NDZ

CFO  
  
 26/03/24

Director  
  
 28/03/24

F.T Letter is Auteip for Sign. Please  
 Director  
  
 28/03/24

  
 28/3/2024