

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2024/101

Dated: 04/04/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Caffe Tonino (A Unit of Pyramids) located at 9, H-Block, Mezzanine floor, Plaza Cinema Building, Connaught Place, New Delhi in a building comprised of Ground + Mezzanine + 02 Upper floor and Restaurant running at Mezzanine floor only owned /occupied by M/s Caffe Tonino (A Unit of Pyramids), was earlier issued fire safety certificate vide letter No. F6/DFS/MS/EH/2018/NDZ/2021/143 dated 20/07/21. Now, the premises has been re-inspected by the officers concerned of this department in presence of Manager on dated 22/03/24 and found that the said restaurant has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the said building / premises, is fit for occupancy class **Assembly Building (Group-D)** of Sub-Division D-5, Restaurant at Mezzanine floor only and valid up to 31.03.2027 from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on ...04/04/2024... at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Officer

Copy to:-

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. ID No 2024021801815 dated 14/03/24.
2. The Chief Medical Officer (Lic-II), NDMC, Palika Kendra, New Delhi - 110001.
3. The Manager, M/s Caffe Tonino 9, H-Block, Mezzanine floor, Plaza Cinema Building, Connaught Place, New Delhi

Condition for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. This FSC is valid for restaurant at mezzanine floor only.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
8. The means of escape shall be kept unobstructed / unlocked & remain available to the occupants for uninterrupted evacuation in case of an emergency.
9. Any flammable material for interior decoration shall strictly prohibited.

2/12
INSPECTION REPORT

1. Name & address of the building M/S Caffè Tonino (A Unit of Pyramids) at 9, H- Block, Mezzanine floor, Plaza Cinema Building, Connaught Place, New Delhi.
Gr. + Mezzanine + 02 Upper floors
2. Type of occupancy:- Assembly Building Group-D
, Restaurant is running at Mezzanine/first floor only
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/EH/2018/NDZ/2021/143 dated 20/07/21
5. Fire safety directives No.- N/A
6. Date of inspection:- 22/03/24
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
Sh. Rajinder Atwal , DO/CD
8. Name & designation of officer from the building side:- (Manager)
9. Year of construction:- Old Heritage
10. Applicant's letter No:- ID No 2024021801815 dated 14/03/24.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	06 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	03	03	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	0.80, 1.25 mtr.	1.80, 1.09 & 0.90 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	02 mtr.	02 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	09 Nos.	10 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			

	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Gr. Floor	Provided	MR
	3) Location of repeater panel	Gr. Floor	Provided	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Office main lobby	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System	Mezz. Floor	Provided	MR
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 mm	150 mm	MR
	2) Number of hydrants per floor	01	01	MR
	3) Hose box	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	02	02	MR
	2) Hose box	02	02	MR
13.	Pumping Arrangement	F/F System exiting with Plaza Cinema		
	1) Ground level			
	a) Discharge of main pump	2800 LPM	2800 LPM	MR
	b) Head of main pump	89 mtr.	89 mtr.	MR
	c) Number of main pump	01	01	MR
	d) Jockey pump out put	280 LPM	280 LPM	MR
	e) Jockey pump head	89 mtr.	89 mtr.	MR
	f) Stand by pump output	2800 LPM	2800 LPM	MR
	g) Stand by pump head	89 mtr.	89 mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltr.	10,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/EH/2018/NDZ/2021/143 dated 20/07/21, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended for approval.

Signature of the Inspecting Officer

[Handwritten Signature]
26/3/24

Name :- Rajinder Atwal
Designation :- DO (CD)

Signature of the Inspecting Officer

[Handwritten Signature]
26/3/24

Name :- Ravinder Singh
Designation :- ADO (CC)

[Handwritten Signature]
Dy. C.O. (AD2)

[Handwritten Signature]
C.F.O.
28/3/2024

[Handwritten Signature]
27/03/24

[Handwritten Signature]
Director

[Handwritten Signature]
Am/CC

As approved by put up for ICAO personnel and by
value please

[Handwritten Signature]
Director

Uploaded
27/3/24

[Handwritten Signature]
27/3/24