



No. F6/DFS/MS/School/NDZ/2024/275

Dated: 04/04/2024

**FIRE SAFETY CERTIFICATE**

Certified that Lavkush Public Secondary School located at A-281, Gharauli Extn., Mayur Vihar, Phase - III, Delhi - 110096, building comprised of Ground plus two upper floors, owned / occupied by Lavkush Public Secondary School, was issued Fire Safety Certificate vide letter No F6/DFS/MS/School/2018/NDZ/2560 dated 27.11.2018. The school building was re-inspected by the officer concerned of this department on 30/03/2024 in presence of Mrs. Bivha Khanna (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the Fire Prevention and Fire Safety requirements in accordance with Circular No. 262-362 dated-17/01/2005 issued by Director of Education and that the building is fit for occupancy class "Educational Building" (Group - B) with effect from 04/04/2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 04/04/2024 at New Delhi by.

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

**Copy to: -**

1. The Director of Education, Yamuna Vihar, Delhi -110054.
2. The Principal Lavkush Public Secondary School located at A - 281, Gharauli Extn., Mayur Vihar, Phase - III, Delhi - 110096.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

**INSPECTION REPORT**


1	Name & address of the building	Lav kush Public Secondary School located at A-281, Gharauli Extn., Mayur Vihar, Phase-III, Delhi-110096.		
2	Building is comprised of	Ground + 02 upper floors.		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2018/NDZ/2560 dated 27.11.2018		
6	Fire safety directives letter no.	Circular No.262 - 362 dated 17/01/2005		
7	Date of inspection	30/03/2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mrs. Bivha Khanna (Principal)		
10	Year of construction	2000		
11	Applicant's letter no.	Email. dated 29/02/2024		
S.No	<b>Minimum standard of fire prevention and fire safety U/R 33</b>	<b>Requirement</b>	<b>Provided at site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to Building:</b>			
A	Road width	06 mtrs.	06 mtrs. ✓	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
A	Number of staircases			
a	Upper floor	02 nos.	02 nos.	MR
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.5 mtrs.	1.15 mtrs. & 1.0 mtrs. & 0.75 mtrs ✓	MR (old accepted)
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	02 nos.	02 nos. ✓	MR
E	Width of corridor	1.50 mtrs.	1.50 mtrs. ✓	MR
F	Door size	1.0 mtrs.	1.0 mtrs. ✓	MR
3	<b>Compartmentation:</b>			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management System:</b>			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

<b>5. Fire Extinguisher:</b>				
A	Total numbers	08 nos.	08 nos.	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
C	ISI marking	ISI Marked	Provided	MR
<b>6 First-Aid-Hose Reel:</b>				
A	Total numbers of each floor	01 no.	Provided	MR
B	Length of hose reel hose	30 mtrs	Provided	MR
C	Nozzle diameter	5 mm	Provided	MR
<b>7 Automatic Fire Detection and Alarming System:</b>				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	<b>MOEFA:</b>	Required	Provided	MR
9	<b>Public Address System:</b>	N/A	N/A	N/A
<b>10 Automatic Sprinkler System:</b>				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11 Internal Hydrants:</b>				
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
<b>12 Yard Hydrants:</b>				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
<b>13 Pumping Arrangements:</b>				
<b>1 Ground level</b>				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
<b>2 Terrace Level</b>				
A	Discharge of pump	450 LPM	Provided	MR
B	Head of the pump	40 mtrs	Provided	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR



<b>14 Captive Water Storage for Fire Fighting:</b>				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	5,000 ltrs.	provided	MR
<b>15 Exit Signage:</b>		Required	provided	MR
<b>16 Provision of Lifts:</b>				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
<b>17 Standby Power Supply:</b>		N/A	N/A	N/A
<b>18 Refuge Area:</b>				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
<b>19 Fire Control Room:</b>				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
<b>20 Special Fire Protection systems for protection of special Risks, if any:</b>		N/A	N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The earlier shortcomings issued vide letter no. F6/DFS/MS/School/2023NDZ/499 dated 18.10.2023 by this department have been rectified by the management.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measured as required under the rules. The FSC issued vide letter no. F6/DFS/MS/School/2018/NDZ/2560 dated 27.11.2018 renewal under the circular no.262-362 dated 17/01/2005 is recommended

  
 Signature of the Inspecting Officer  
 Name Yashwant Singh Meena  
 Designation ADO (L.N)

DI. CFO/NDZ

  
 C.F.P.  
 24/11/2024  
 Director  
  
 01/11/24  
 P.T.O