

C-18

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110 001.**

No.F.6/DFS/MS/School/2024/SZ/283

Dated: 05/04/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Blooming Buds School**, C-10 & 11, Bhagwati Garden Extension, Dwarka Xing, Uttam Nagar, New Delhi-110059, comprised of basement, ground floor plus two upper floors but school running at ground and first floor only, was issued FSC by this department vide letter F6/DFS/MS/School/2015/SZ/517 dated 10.04.2015. The School building was re-inspected by the officer concerned of this department on 22.03.2024 in the presence of Sh. R.K. Dubey (Manager) and found that the school building have deemed complied the fire prevention and fire safety requirements in accordance with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the school building/ premises (**Ground and first floor only**) is fit for occupancy class "**Educational**" for a period of three years, subject to compliance of the conditions printed as below.

Issued on.....05/04/2024..... at New Delhi.

  
(Atul Garg)  
Director  
Delhi Fire Service  
2024

Copy to:-

1. The Principal, **Blooming Buds School**, C-10 & 11, Bhagwati Garden Extension, Dwarka Xing, Uttam Nagar, New Delhi-110059.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi - 110054.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

**INSPECTION REPORT**

1. Name & address of the building : Blooming Buds School, C-10 & 11, Bhagwati Garden Extn., Uttam Nagar, New Delhi-110059.
2. Building Comprised of : Ground plus two upper floors but school running at ground & 1<sup>st</sup> floor only
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2015/SZ/517 dated 10.04.15
6. Fire Safety directives letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01/03/2011
7. Date of inspection : 22.03.2024
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers  
From the building side : Smt. R.K. Dubey (Manager)
10. Year of Construction : 2010 (GF & FF) & Before 2018 (SF)
11. Applicant's letter No. : BBS/2024/14 dated 04.03.2024

	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per FSC dt. 10.04.15	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Accessible 06 mtr 4.5 mtrs N/A	Provided Directly accessible from road N/A	M/R M/R N/A
<b>2.</b>	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	02 No.'s N/A	02 No.'s N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basements</li> </ul>	150 cms N/A	92 & 94 cms N/A	MR, old case N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace			
		N/A	N/A	N/A
	e. Width of Corridor			
		150 cms.	125 cms	MR, old case
	f. Class Room Door Size			
		100 cms	100 cms	M/R
<b>3.</b>	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
<b>4.</b>	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	Required	Natural ventilation provided	M/R
<b>5.</b>	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	06 no's ABC/CO <sub>2</sub> type ISI marked	Provided Provided Provided	MR MR MR
<b>6.</b>	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 no. per floor 30 mtrs 5 mm	Provided Provided Provided	MR MR MR

7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	<b>MOEFA</b>			
9.	<b>Public Address System</b>			
10.	<b>Automatic Sprinkler System</b>			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	• Terrace level			
	➤ Pump House Access	N/A	N/A	N/A
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15.	<b>Exit Signage.</b>			
		N/A	N/A	N/A
16.	<b>Provision of Lifts.</b>			
		<b>No Lift</b>		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	<b>Standby power supply</b>			
		N/A	N/A	N/A
18.	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

N/TO

19.	Fire Control Room .			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2015/SZ/517 dated 10.04.15, renewal in accordance with the Circular No. F.16/Estate/CC/FireSafety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

**Note :-** As per undertaking (placed at C-16) School building comprised of ground plus two upper floors. School running at ground and 1<sup>st</sup> floor only. Second floor of the school only one hall is constructed. Such hall is not in use of the school and totally closed for all purpose. Photograph of the closed gate enclosed with undertaking.

*R.K. Yadav*  
 Signature of Inspecting Officer  
 Name:- R.K. Yadav  
 Designation:- ADO (JKP)

Divisional Officer (South West)  
*[Signature]*  
 28/05/24

*[Signature]*  
 28/05/24

*[Signature]*  
 28/05/24

*[Signature]*  
 ADO/JKP

*[Signature]*