

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No.F.6 DFS/MS/School/2024/SZ/287

Dated: 05/04/2024

**FIRE SAFETY CERTIFICATE**

Certified that **Poorna Prajna Public School, Sector - D, Pocket - 3, Vasant Kunj, New Delhi 110070** comprised of Ground plus Three upper floors owner/occupied by Udupi Sri Admar Mutt Education Council was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2021/SZ/436 Dated 06/07/2021. The said premise was re-inspected by officer concerned of this department on 28/03/2024 in presence of Sh. Sandeep Dahiya (Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational Building Group - B**" with effect from 05/04/2024 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 05/04/2024 at New Delhi by

  
**(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE**

Copy to: -

1. The Principal, Poorna Prajna Public School, Sector - D, Pocket - 3, Vasant Kunj, New Delhi - 110070
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

**Conditions for the validity of Fire Safety Certificate:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."



### INSPECTION REPORT

1	Name & Address of the Building	Poorna Prajna Public School, Sector - D, Pocket - 3, Vasant Kunj, New Delhi - 110070		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground + 3 Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2021/SZ/436 Dated 06/07/2021		
6	Fire Safety Directives Letter No	F.6/MS/DFS/BP/2011/242 Dated 09/02/2011		
7	Date of Inspection	28/03/2024		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Sandeep Dahiya (Principal)		
10	Year of construction	2000 & 2012		
11	Applicant letter No.	Email Dated 15/03/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	6 mtr	9 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>g) Number of Staircase</b>			
	➤ Upper floors.	Required	6 No's	M/R
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>h) Width of Staircase</b>			
	➤ Upper floors	1.50 mtr each	1.5 mtr each	M/R
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>i) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>j) No. of continuous staircase to terrace</b>	One	Two	MR
	<b>k) Width of corridor</b>	1.5 mtr	Provided	MR
	<b>l) Door size</b>	01 mtr	Provided	M/R
3	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	NA	-NA-
5	<b>Fire Extinguishers.</b>			
	• Total numbers	16 NO, s	20 No's	MR
	• Types	ABC/ Co2	ABC type	MR
	• ISI Marking	ISI Marked	Provided	MR
6	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	2 No's	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

7 Automatic fire detection & alarming system.				
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8	MOEFA	-NA-	NA	-NA-
9	Public Address System	-NA-	-NA-	-NA-
10 Automatic Sprinkler System				
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	NA	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11 Internal Hydrants.				
	• Size of Riser/Down-comer	-NA-	100 mm	-NA-
	• Number of Hydrant per floor	-NA-	One	-NA-
	• Hose box.	-NA-	One	-NA-
12 Yard Hydrants.				
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13 Pumping arrangements.				
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping.	-NA-	-NA-	-NA-
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	450 LPM	Provided	MR
	➤ Head of pump.	40 mtr	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14 Captive water storage for fire fighting.				
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	10,000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR



16	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17	<b>Standby Power Supply</b>	Required	Provided	MR
18	<b>Refuge Area</b>			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	<b>Fire Control Room.</b>			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2021/SZ/436 Dated 06/07/202, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly, DFA is put up for approval and signature please

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

DO (SD)

*Handwritten signature and date: 04/07/24*

*Handwritten signature and date: 2/11/2024*

*Handwritten signature and date: 2/07/24*

*As approved, F.T. letter is put up for signature*

*Handwritten signature and date: 04/07/24*

*Handwritten signature and date: 04/07/24*