



FIRE SAFETY CERTIFICATE

Certified that the **Rajkiya Sarvodaya Kanya /Bal Vidyalaya** located at **East Vinod Nagar, Delhi - 110091**, comprised of **Six Blocks (Ground plus one upper floor each)**, owned/occupied by **Rajkiya Sarvodaya Kanya /Bal Vidyalaya**, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2021/NDZ/406 dated 28/06/2021. The School building was re-inspected by the officer concerned of this department on 30/03/2024 in presence of Mrs. Rumajhuma Bhaumik (Principal) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with F16/Estate/CC/Fire Safety/2011/ 3298-3398 dated 01/03/2011 issued by Director of Education and the building premises is fit for occupancy of class **Group B "Educational Building"** for **ground plus one upper floor** with effect from 08/04/2024 for a period of **three years**, in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 08/04/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
o/k DELHI FIRE SERVICE
(u)

Copy to:-

1. The Dy. Director of Education, D - Block, Anand Vihar, Delhi-110091.
2. The Principal, Rajkiya Sarvodaya Kanya /Bal Vidyalaya located at East Vinod Nagar, Delhi - 110091.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Rajkiya Sarvodaya Kanya / Bal Vidyalaya located at East Vinod Nagar, Delhi - 110091.		
2	Building is comprised of	(Six Blocks) Ground plus one upper floor each		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/NDZ/2021/406 dated 28/06/2021.		
6	Fire safety directives letter no.	F16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011.		
7	Date of inspection	30/03/2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mrs. Rumajhuma BhaumiK(Principal)		
10	Year of construction	2011-2014		
11	Applicant's letter no.	Outdoor dairy no. 14469 dated 21/03/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement Circular	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	6.0 mtrs.	15 mtrs.	MR
B	Gate width	4.5 mtrs.	4.5 mtrs.	MR
C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	10 nos.	10 nos.	MR
	A- Block	01 no.	01 no.	MR
	B- Block	02 nos.	02nos.	MR
	C- Block	01 no.	01no.	MR
	D- Block	02 nos.	02 nos..	MR
	E- Block	03 nos.	03 nos.	MR
	F- Block	01 no.	01 no.	MR
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.50 mtrs	1.50 mtrs each.	MR
	A- Block	1.50 mtrs	1.50 mtrs.	MR
	B- Block	1.50 mtrs	1.30 mtrs.& 1.50 mtrs	MR
	C- Block	1.50 mtrs	1.50 mtrs	MR
	D- Block	1.50 mtrs	1.4 mtrs.& 1.50 mtrs	MR
	E- Block	1.50 mtrs	1.3 mtrs.& 1.4 mtrs & 1.50 mtrs	MR
	F- Block	1.50 mtrs	1.60 mtrs	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	N/A	N/A	N/A
E	Width of corridor	1.50 mtrs.	1.50 mtrs	MR
F	Door size	1.0 mtr.	1.0 mtr	MR
3	Compartmentation:			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

5.	Fire Extinguisher:					
	A	Total numbers	26 nos.	26 nos.	MR	
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR	
	C	ISI marking	ISI marked	ISI marked	MR	
6	First-Aid-Hose Reel:					
	A	Total numbers of each floor	N/A	N/A	N/A	
	B	Length of hose reel hose	N/A	N/A	N/A	
	C	Nozzle diameter	N/A	N/A	N/A	
7	Automatic Fire Detection and Alarming System:					
	A	Type of detectors	N/A	N/A	N/A	
	B	Location of main panel	N/A	N/A	N/A	
	C	Location of repeater panel	N/A	N/A	N/A	
	D	Alternate source of power	N/A	N/A	N/A	
	E	Hooters	N/A	N/A	N/A	
8	MOEFA:		N/A	N/A	N/A	
9	Public Address System:		N/A	N/A	N/A	
10	Automatic Sprinkler System:					
	A	Basement	N/A	N/A	N/A	
	B	Upper floor	N/A	N/A	N/A	
	C	Sprinkler above false ceiling	N/A	N/A	N/A	
11	Internal Hydrants:					
	A	Size of riser/down-comer	N/A	N/A	N/A	
	B	Number of hydrants per floor	N/A	N/A	N/A	
	C	Hose box	N/A	N/A	N/A	
12	Yard Hydrants:					
	A	Total number of hydrants	N/A	N/A	N/A	
	B	Hose box	N/A	N/A	N/A	
13	Pumping Arrangements:					
	1	Ground level				
		A	Discharge of main pump	N/A	N/A	N/A
		B	Head of main pump	N/A	N/A	N/A
		C	Number of main pumps	N/A	N/A	N/A
		D	Jockey pump out put	N/A	N/A	N/A
		E	Jockey pump head	N/A	N/A	N/A
		F	Standby pump out put	N/A	N/A	N/A
		G	Standby pump head	N/A	N/A	N/A
		H	Auto starting /manual stopping	N/A	N/A	N/A
		I	Pump house access	N/A	N/A	N/A
	2	Terrace Level				
		A	Discharge of pump	N/A	N/A	N/A
		B	Head of the pump	N/A	N/A	N/A
C		Power supply	N/A	N/A	N/A	
	D	Auto starting of pump	N/A	N/A	N/A	

N/22

Rajkiya Sarvodaya Kanya / Bal Vidyalaya located at East Vinod Nagar, Delhi-110091.

14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	N/A	N/A
15	Exit Signage:			
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	Standby Power Supply:			
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			




The fire protection systems provided in the school building were tested, checked at random and found functional at the time of inspection.

Keeping in view of the compliance of minimum standards of fire prevention and fire safety measures required as per Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011, under the rules the FSC issued vide letter no. F6/DFS/MS/School/NDZ/2021/406 dated 28/06/2021, renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended to be renewed.


01/4/2024


Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (L.N)

~~DY.CFO (NDZ)~~


C.F.O.

Director
3/4/2024

A DO (L.N)

F.7 Letter is put up for sign. Please


Director
5/4/24
K 1


5/4/2024