

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/2024/SZ/196

Dated: 18/04/2024

To

The Executive Engineer (E)
Electrical Division No -11,
Press Building First Floor,
DDA, Vikas Sadan,
New Delhi 110023.

Sub: Regarding issuance of Fire Safety Certificate in r/o EWS Housing at Plot No 14, Kalkaji, New Delhi (for Cluster 04)

Sir,

This has reference to your letter No F3(188)EE(E)/ELD-11/DDA/2023-24/435 dated 05/01/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 01/02/2024 in the presence of Md. Sahid to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire check door not provided.
2. First aid hose reel hose not provided.
3. MOEFA not provided.
4. Internal Hydrant not provided.
5. Electrician Fire Pump capacity 1620 LPM, Diesel Engine Pump 1620 LPM and Jockey Pump 180 LPM not provided.
6. Overhead fire fighting tank capacity 25000 ltrs not provided.
7. Exit signage not provided at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours Faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE