



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/CNG/SZ/2024/ 237

Dated: 19 / 04 / 2024

FIRE SAFETY CERTIFICATE

Certified that M/s **Indraprastha Gas Ltd. Retail Outlet** (CNG Pump) located at Brar Square, Ring Road, New Delhi, comprised of Ground Floor only having 02 Cascade (at roof of the office building), 02 Compressor units & 05nos Dispensing units was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/2021/CNG/232 dated 22/04/2021. The premises was re-inspected by the officer concerned of this department on 08/04/2024 in the presence of Sh. Yashpal Singh (Sr. Manager) and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class **Hazardous** (CNG Pump) with effect from the date of issue of this certificate for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 of Delhi Fire Service Rules, 2010 and subject to compliance of the conditions mentioned below.

Issued on 19/04/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
01/08/24

Copy to: -

1. Sh. Ajay Khatri, General Manager (Fire & Safety), IGL Bhawan, Plot No. 4, Community Centre, R.K. Puram, Sector-9, New Delhi-110022
2. The Addl. Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N-14

INSPECTION REPORT

| 1 | Name & Address of the Building | Indraprastha Gas Limited Retail Outlet (CNG Pump), Brar Square, Ring Road, New Delhi | | |
|-----------|---|--|--|----------------|
| 2 | Type of Occupancy | Hazardous (CNG Pump) | | |
| 3 | Building Comprised of | Ground floor only (02 Cascades at roof of office bldg. 02 Compressor units & 05nos dispensing units) | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F.6/DFS/MS/2021/CNG/232 dated 22/04/2021 | | |
| 6 | Fire Safety Directives Letter No | F5(3A)/DFS/CNG/2001/278 dated 09/10/2001 | | |
| 7 | Date of Inspection | 08/04/2024 | | |
| 8 | Name of the Inspecting Officers | Santosh Kumar, ADO (SJ) | | |
| 9 | Name & Designation of Officers from the building side | Sh. Yashpal Singh (Sr. Manager) | | |
| 10 | Year of construction | 2001 | | |
| 11 | Applicant letter No. | Outdoor Diary No. 13773 dated 01/03/2024 | | |
| S. No. | Minimum standards on Fire Prevention and Fire Safety U/R 33 | Requirements/ Existing Fire Protection System | Provided at Site | Remarks MR/NMR |
| 1 | Access to Building. | | | |
| | • Road width | 9m | 12m | MR |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | NA | NA | NA |
| 2 | Number, width, type & arrangement of exits. | | | |
| | a) Number of Staircase | | | |
| | ➤ Upper floors. | One | One | MR |
| | ➤ Basement. | NA | NA | NA |
| | b) Width of Staircase | | | |
| | ➤ Upper floors | 0.90m | 1.1m | MR |
| | ➤ Basement | NA | NA | NA |
| | c) Protection of exits | | | |
| | ➤ Fire check door | NA | NA | NA |
| | ➤ Pressurization | NA | NA | NA |
| | d) No. of continuous staircase to terrace | NA | NA | NA |
| | e) Width of corridor | NA | NA | NA |
| | f) Door size | 1m | 1m | MR |
| 3 | Compartmentation. | | | |
| | • Fire check door. | NA | NA | NA |
| | • Sealing of electrical shafts. | NA | NA | NA |
| | • Fire rating of shaft door. | NA | NA | NA |
| | • Water curtain | NA | NA | NA |
| | • Fire dampers. | NA | NA | NA |
| 4. | Smoke Management system. | | | |
| | • Basement | NA | NA | NA |
| | • Upper floors | NA | NA | NA |
| 5. | Fire Extinguishers. | | | |
| | • Total numbers | 20nos | 28nos | MR |
| | • Types | CO ₂ & DCP | DCP (75kg)-06, (10kg)-17 & CO ₂ (4.5kg)-05nos | MR |
| | • ISI Marking | ISI marked | Provided | MR |
| 6. | First Aid Hose Reels. | | | |
| | • Total numbers on each floor. | NA | NA | NA |
| | • Length of hose-reel hose. | NA | NA | NA |
| | • Nozzle Diameter | NA | NA | NA |

SR

| | | | | |
|-----|--|----|--|----|
| 19. | Fire Control Room. | | | |
| | • Detector system panel. | NA | NA | NA |
| | • Flow switch panel. | NA | NA | NA |
| | • PA system panel. | NA | NA | NA |
| | • Battery backup. | NA | NA | NA |
| | • Building floor plan. | NA | NA | NA |
| 20. | Special Fire Protection System for the Protection of special Risk, if any. | NA | CO ₂ flooding system connected through detectors provided in each compressor unit | NA |

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/2021/CNG/232 dated 22/04/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Santosh Kumar
09.04.24
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

~~DO/SD~~
~~Munir~~
~~10/4/24~~
~~cto~~
~~12/4/2024~~
~~Director~~
~~12/04/24~~
~~ADDO/SJ~~

Sir, F.T letter is put up for your sig. pl

Santosh Kumar
18.04.24

~~Director~~
~~18/04/24~~
~~mu~~