



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/CNG/SZ/2024/236

Dated: 19/04/2024

FIRE SAFETY CERTIFICATE

Certified that M/s **Indraprastha Gas Ltd. Retail Outlet (CNG Pump)** located at NH-8, Near Palam Airport, New Delhi, comprised of Ground Floor only having 01 Cascade (at roof of the office building), 02 Compressor units & 06nos Dispensing units was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/2021/CNG/229 dated 22/04/2021. The premises was re-inspected by the officer concerned of this department on 08/04/2024 in the presence of Sh. Rahul Kirar (Dy. Manager-F&S) and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class **Hazardous (CNG Pump)** with effect from the date of issue of this certificate for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 of Delhi Fire Service Rules, 2010 and subject to compliance of the conditions mentioned below.

Issued on 19/04/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE


Copy to: -

1. The Addl. Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049
2. Sh. Ajay Khatri, General Manager (Fire & Safety), IGL Bhawan, Plot No. 4, Community Centre, R.K. Puram, Sector-9, New Delhi-110022

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N-13

INSPECTION REPORT

1	Name & Address of the Building	Indraprastha Gas Limited Retail Outlet (CNG Pump), NH-8 Near Palam Airport, New Delhi		
2	Type of Occupancy	Hazardous (CNG Pump)		
3	Building Comprised of	Ground floor only (01 Cascades at roof of office bldg. 02 Compressor units & 06nos dispensing units)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/2021/CNG/229 dated 22/04/2021		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	08/04/2024		
8	Name of the Inspecting Officers	Santosh Kumar, ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. Rahul Kirar (Dy. Manager-F&S)		
10	Year of construction	2004		
11	Applicant letter No.	Outdoor Diary No. 13122 dated 14/02/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements/ Existing Fire Protection System	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	9m	12m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	One	One	MR
	➤ Basement.	NA	NA	NA
	b) Width of Staircase			
	➤ Upper floors	0.70m	0.70m	MR
	➤ Basement	NA	NA	NA
	c) Protection of exits			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	d) No. of continuous staircase to terrace	NA	NA	NA
	e) Width of corridor	NA	NA	NA
	f) Door size	1m	1m	MR
3	Compartmentation.			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers.			
	• Total numbers	20nos	22nos	MR
	• Types	CO ₂ & DCP	DCP (75kg)-04, (10kg)-14 & CO ₂ (4.5kg)-04	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	NA	NA	NA
	• Length of hose-reel hose.	NA	NA	NA
	• Nozzle Diameter	NA	NA	NA

88

7.	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Gas & Flame in compressors	Provided & portable gas detector with staff	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		Required	Technician room	MR
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground floor. Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	NA	NA	NA
		NA	NA	NA
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	No Smoking Signage.	Required	Provided in Hindi & English	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby Power Supply	NA	Provided DG Set	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	NA	NA	NA
		NA	NA	NA

N-15

19.	Fire Control Room.			
	• Detector system panel.	NA	NA	NA
	• Flow switch panel.	NA	NA	NA
	• PA system panel.	NA	NA	NA
	• Battery backup.	NA	NA	NA
	• Building floor plan.	NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any.	NA	CO ₂ flooding system connected through detectors provided in each compressor unit	NA

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/2021/CNG/229 dated 22/04/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

S. Kumar
05.04.24

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD)

Mull
10/4/24

Ch
12/4/2024

Director
12/4/24

Am 18/4/24

Sir, F.T letter is put up for your sing. pl

Director
10/4/24

S. Kumar
18.04.24