

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/2024/SZ/ 244

Dated: 19/04/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Delhi Tamil Sangam** located at Tamil Sangam Marg, Sector-5, R.K Puram, New Delhi 110022 comprised of 02 Block:- Basement Ground & Two upper floors and Second Block- Basement, Ground Mezzanine, First & Second Floor (Basement & Ground floor is common for both blocks) owned/occupied by Delhi Tamil Sangam was issued FSC by this department vide letter no. F6/DFS/MS/2016/SZ/875 dated 26/05/2016. The premise was re-inspected by the officers concerned of this department on 01/04/2024 in the presence of Mr. Sakti Perumal and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for **Mixed occupancy (Mercantile, Assembly & Business)** with effect from 19/04/2024 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Rules 2010.

Issued on 19/04/2024 at New Delhi by

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The President, Delhi Tamil Sangam at Tamil Sangam Marg, Sector-5, R.K Puram, New Delhi 110022.

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. This fire safety certificate may not be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The basement shall be used as per the provisions of UBBL-2016 /NBC Part- IV.
6. The owner/occupier shall submit a declaration every year in form 'K' provided in the First schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

M/24

**INSPECTION REPORT**

1. Name & address of the building : Delhi Tamil Sangam, Tamil Sangam Marg, Sector-5, R.K Puram, Delhi 22
2. Type of Occupancy : Mixed Occupancy (Mercantile Assembly & Business)
3. Type of Case : Renewal
4. Comprised of : 02 Blocks, old block, Basement Ground plus two upper floors & New Block Basement, Ground, Mezzanine plus two upper floors.
5. Details of Previous NOC : F6/DFS/MS/2016/SZ/875 dated 26/05/2016
6. Fire Safety directives letter No : F6/MS/DFS/83/Auditorium/213 dated 03/07/1983  
F6/DFS/MS/84/786 dated 09/08/1984
7. Date of inspection : 01/04/2024
8. Name of Inspecting Officer : DO (South) & ADO (BCP)
9. Name and designation of officers  
From the building side : Mr. Sakti Perumal
10. Year of Construction : 1990 & 1997
11. Applicant's letter No. : Outdoor diary no 14541 dated 22/03/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	9m 5m NA	Provided Provided NA	MR MR NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> </ul>	02 Nos	Old Block is served by a single staircase which is common with new block upto first floor, New Block- 03 Nos including common staircase	MR
		02 Nos	03 Nos Provided	MR
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	1.25m 1.5m	Old block- Ground floor to first floor- 1.37m 1 <sup>st</sup> & 2 <sup>nd</sup> floor-1.25m , New Blk- 1.40m, 1.37m, 1.37m	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	Required -NA-	Provided -NA-	MR -NA-
	d. No. of continuous staircases to terrace	02 Nos	02 Nos	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1.5m for Auditorium & 1m for others	1.53m, 1.52m, 1.40m, 1.40m, Balcony- 1.37m, 1.37m	MR old case
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Required Required Required -NA- -NA-	Provided Provided Provided -NA- -NA-	MR MR MR -NA- -NA-
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	Provided Provided	MR MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	42 No's ABC/W. CO <sub>2</sub> /CO <sub>2</sub> ISI	42 No's Provided Yes	MR MR MR
6.	<b>First Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	02 Nos 30m 5mm	Provided Provided Provided	MR MR MR
7.	<b>Automatic fire detection and alarming system</b>			

A



N/25

	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Smoke & Heat Ground Floor -NA- Required Required	Provided Provided -NA- Provided Provided	MR MR -NA- MR MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required -NA- -NA-	Provided -NA- -NA-	MR -NA- -NA-
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100mm 01 Nos 01 Nos	Provided Provided Provided	MR MR MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	04 Nos 04 Nos	Provided Provided	MR MR
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> <li>Pump House Access</li> </ul> </li> </ul>	2280LPM 60m 01 No 450 LPM 40m 900 LPM 60m Required Required	Provided Provided Provided Provided Provided Provided Provided Provided Provided	MR MR MR MR MR MR MR MR MR
	<ul style="list-style-type: none"> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	900 LPM 54 m Required Required	Provided Provided Provided Provided	MR MR MR MR
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	1,00,000 Lts Required Required Required Required 30,000 Lts.	Provided Provided Provided Provided Provided Provided	MR MR MR MR MR MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
17.	<b>Standby power supply</b>	Required	Provided	MR
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	-NA- -NA-	-NA- -NA-	-NA- -NA-
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> </ul>	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-

N/A


	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-


The fire protection system provided in the building were randomly checked and found functional at the time of inspection.



Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 4338 dated 14/12/2023.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/2016/SZ/875 dated 26/05/2016, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

  
Signature of the Inspection Officer  
Name: Sh. Manoj Kumar Sharma  
Design: DO (South)



  
Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)



CFO (HQ)  
  
  
Director


होना यह confirm हो  
कि खले पत्रों की  
सही file कर दी गई है

As order has been issued  
first com first serve, unless  
otherwise

  
A/A/2A

CFO (HQ)   


DO (SO)   


  
We are strictly follow up the  
order and emphasising the file disposal