



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2024/WZ/ 230

Dated: 18/04/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s M.B. Fashion Inc. located at A-103/1, Block-A, Wazirpur Industrial Area, New Delhi-110052 comprised of Basement, Ground plus three upper floors owned/occupied by M/s M.B. Fashion Inc. have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on 09/04/2024 in the presence of Sh. Surender Singh Mor (JE, Bldg.) & Sh. Shyam Manohar Bajaj (Owner/ Occupier) and that the said premise is fit for occupancy under "Class Industrial Building Group G" with effect from 18/04/2024 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/04/2024 at New Delhi by


(Atul Garg)
Director
Ph. 011-23414000


Conditions for the validity of Fire Safety Certificate:

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able at the time of emergency.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

Copy to :-

1. M/s M.B. Fashion Inc., located at A-103/1, Block-A, Wazirpur Industrial Area, Delhi-110052.
2. MCD Online ID - 10072236.

Name & address of the building :

INSPECTION REPORT

M/s M.B. Fashion Inc. located at A-103/1, Block A, Wazirpur Industrial Area, New Delhi-110052.
 Industrial.
 Basement, Ground plus Three upper floors.
 New Case
 N/A
 F6/DFS/MS/BP/2020/36 Dated- 31/01/2020
 09/04/2024
 R.K.Sinha, ADO (BW)
 Sh. Sh. Surender Singh Mor (J.E. Bldg.) & Sh. Shyam Manohar (Owner)
 2021-22
 Online ID 10072236

2. Type of Occupancy
3. Building Comprised of
4. Type of Case
5. Details of Previous NOC
6. Fire Safety directives letter No
7. Date of inspection
8. Name of Inspecting Officer
9. Name and designation of officers From the building side
10. Year of Construction
11. Applicant's letter No.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Directive issued	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	02	Provided	MR
	b. Width of staircases			
	• Upper Floor	1.5 m each	Provided	MR
	• Basements	1.5 m each	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.5 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	12 Nos.	16 Nos.	MR
	• Types	ABC,Co2 Type	Provided	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA

7

10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	25,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA

M-11

• Building Floor Plans	NA	NA	NA
Special Fire Protection System for Protection of special Risks, if any:	Required 2 ABC type fire extinguishers near electrical panel	Provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter no. F6/DFS/MS/WZ/2022/989 dated 06/05/2022.

Keeping in view of satisfactory compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules, 2010.

ADO (B.W.)
10/4/24

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

Dy CPO (WZ)

10/4/2024

~~SET Case~~. Re examine & put up on 12.4.2024.

CFO
10/4/2024

~~799~~
Dated... 10/4/2024

~~Director~~ *Dy CPO (WZ)*

Examined & found OK.

Re-submitted please

15/4/2024

CFO
16/4/2024

~~Director~~

~~799~~
Dated... 15/4/2024

Any problem. RT letter is put for compliance

ADO (B.W.)
16/4/24

~~Director (DFS)~~