



No. F6/DFS/MS/Cinema/NDZ/2024/242

Dated: 19/04/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Moon Shine Entertainment Limited (Chand Cinema) located at Trilok Puri, Delhi - 110091 of the building comprised of three basement, ground plus four upper floors only owned /occupied by M/s Moon Shine Entertainment Limited, have complied with the Fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 12.04.2024 in the presence of Mr. Vikas Tyagi (Manager) of the building and found that the building have deemed complied with the fire prevention and fire safety requirement in accordance with the (4) of Rule 4 Schedule II of the Delhi Cinematograph rules 2008 and recommendations along with approved plans issued vide letter no. F6/DFS/MS/BP/2019/113 dated 15.03.2019 and that the building is fit for Multiplexes Class D-6 "Assembly Building" (Without Cineplex) with effect from 19/04/2024 for a period of three years, subject to conditions, printed below.

Issued 19/04/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR
o/c DELHI FIRE SERVICE

Copy to:-

1. The Commissioner, MCD, 419, F.I.E. Udyog Sadan, Patparganj, Delhi – 110096
2. The Manager, Moon Shine Entertainment Limited (Chand Cinema) located at Trilok Puri, Delhi - 110091.

Conditions for the validity of Fire Safety Certificate

1. This FSC valid for three basements, ground plus four upper floors without multiplex.
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and construction deviation in building etc .may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. Basement shall be used as per NBC/UBBL.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Moon Shine Entertainment Limited (Chand Cinema) located at Trilok Puri, Delhi - 110091.				
2	Building is comprised of	03 Basement, Ground + 04 upper floors only.				
3	Type of occupancy	Multiplex/Mercantile (Mixed Occupancy)				
4	Type of case	New Case				
5	Details of previous FSC	Nil				
6	Fire safety directives letter no.	F6/DFS/MS/BP/2019/113 dated 15.03.2019				
7	Date of inspection	12.04.2024				
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)				
9	Name of the designation of officer from the building side	Mr. Vikas Tyagi (Manager)				
10	Year of construction	2020				
11	Applicant's letter no.	MCD Portal ID no. 10060702 dated 05/04/2024				
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR		
1	Access to Building:					
	A	Road width	30 mtrs.	30 mtrs.	MR	
	B	Gate width	6.0 mtrs.	6.0 mtrs.	MR	
	C	Width of internal road	9.0 mtrs.	9.0 mtrs.	MR	
2	Number, Width, Type and Arrangement of Exits:					
	A	Number of staircases				
		a	Upper floor	04 nos.	04 nos.	MR
		b	Basement	03 nos.	03 nos. + 01 no. ramp	MR
	B	Width of staircases				
		a	Upper floor	2.0 mtrs.	2.0 mtrs.	MR
		b	Basement	2.0 mtrs.	2.0 mtrs. (Ramp 7.30 mtrs.)	MR
	C	Protection of exits				
		a	Fire check door	Required	Provided	MR
		b	Pressurization	Required	Provided	MR
	D	No. of continuous staircases to terrace				
				02 nos.	04 nos.	MR
	E	Width of corridor				
				Required	Provided	MR
	F	Door size				
				2.0 mtrs. & 1.50 mtrs.	Provided	MR
3	Compartmentation:					
	A	Fire check door				
				Required	Provided	MR
	B	Sealing of electrical shafts				
				Required	Sealed	MR
	C	Fire rating of shaft door (02 hrs)				
				Required	Provided	MR
	D	Water curtain				
				Required	Provided	MR
	E	Fire dampers				
				Required	Provided	MR
4	Smoke Management System:					
	A	Basement				
				30 a/c per hrs	Provided	MR
	B	Upper floor				
				12 a/c per hrs	Provided	MR

u

2) 8

5. Fire Extinguisher:				
A	Total numbers	40 nos.	52 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI Marked	ISI Marked	MR
6 First-Aid-Hose Reel:				
A	Total numbers of	All Basements - 03nos Ground floor -04 nos. First & third each floors - 11 nos. Second & fourth each floor- 03 nos. Terrace - 03 nos.	Provided	MR
B	Length of hose reel hose	30 mtrs.	Provided	MR
C	Nozzle diameter	05 mm	Provided	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	Smoke & Heat	Provided	MR
B	Location of main panel	Ground floor entry gate no. 01	Provided	MR
C	Location of repeater panel	In main building control room	Provided	MR
D	Alternate source of power	Batter & DG Set	Provided	MR
E	Hooters location	Staircase	Provided	MR
8	MOEFA:	Required	Provided	MR
9	Public Address System:	Required	Provided	MR
10 Automatic Sprinkler System:				
A	Basement	Required	Provided	MR
B	Upper floor	Required	Provided	MR
C	Sprinkler above false ceiling	Required	Provided	MR
11 Internal Hydrants:				
A	Size of riser/down-comer	150 mm	Provided	MR
B	No. of hydrants per floor	Required	Provided	MR
C	Hose box	Required	Provided	MR
12 Yard Hydrants:				
A	Total number of hydrants	05 nos.	05 nos.	MR
B	Hose box	05 nos.	05 nos.	MR
13 Pumping Arrangements:				
1 Ground level				
A	Discharge of main pump	2850 LPM	2850 LPM	MR
B	Head of main pump	120 M	120 M	MR
C	Number of main pumps	02 nos.	02 nos.	MR
D	Jockey pump out put	180 LPM	180 LPM	MR
E	Jockey pump head	120 M	120 M	MR
F	Standby pump out put	2850 LPM	2850 LPM	MR
G	Standby pump head	120 M	120 M	MR
H	Water Curtain Pump	900 LPM	900 LPM	MR
I	Auto starting /manual stopping	Auto	Provided	MR
J	Pump house access	Required	Provided	MR
2 Terrace Level				
A	Discharge of pump	N/A	N/A	N/A
B	Head of the pump	N/A	N/A	N/A
C	Power supply	N/A	N/A	N/A
D	Auto starting of pump	N/A	N/A	N/A

W


50 /

N/09

14 Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	2,00,000 Liters	2,00,000 Liters	N/A
B	Draw-off connection	Required	Provided	MR
C	Fire service inlet	Required	Provided	MR
D	Access to tank	Required	Provided	MR
E	Overhead tank capacity	20,000 liters	20,000 liters.	MR
15 Exit Signage:		Required	Provided	MR
16 Provision of Lifts:				
A	Pressurization of lift shaft	Required	Provided	MR
B	Pressurization of lift lobby	Required	Provided	MR
C	Communication in lift car	Required	Provided	MR
D	Firemen's grounding switch	Required	Provided	MR
E	Lift signage	Required	Provided	MR
17 Standby Power Supply:		Required	Provided	MR
18 Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19 Fire Control Room:				
A	Detector system panel	Required	Provided	MR
B	Flow switch panel	Required	Provided	MR
C	PA system panel	Required	Provided	MR
D	Battery backup	Required	Provided	MR
E	Building floor plans	N/A	N/A	N/A
20 Special Fire Protection systems for protection of special Risks, if any:		Required for HT/LT Panels	Provided in all HT & LT Panels	MR

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The earlier shortcomings issued vide letter no. F6/DFS/MS/Cinema/NDZ/2024/126 dated 15.03.2024 by this department have been rectified by the management.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.


 15/4/2024
 Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (L.N)

Online joint inspection case.

~~DY. CFO/NDZ~~

Line
16/04/24

c.f.o.

18/4/24

Director

18/04/24

ADO/LN

D.T.O