



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2024 / WZ / 231

Dated: 18/04/2024

FIRE SAFETY CERTIFICATE

Certified that the **Park Meadows Farm House** located at Kh. No. 445, 446 & 447, **Village Hiranki, Delhi-110036** comprised of Ground Floor only was issued Fire Safety Certificate vide letter no. **F6/DFS/MS/FH/2021/WZ/255 dated 13/05/2021**. The premise was re-inspected by the officer concerned of this department on 09/04/2024 in the presence of Sh. Rajeev Rana and found that the said farm house building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building premise is fit for occupancy under "Assembly" with effect from **18/04/2024**..... for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on **18/04/2024**..... at New Delhi, by

(Atul Garg)
Director
Ph. 011-23414000

Atul Garg

Conditions for the validity of Fire Safety Certificate:

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able at the time of emergency.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Copy to:-

1. The Assistant Engineer (Bldg.), Delhi Municipal Corporation, Narela Zone, Delhi.
2. M/s Park Meadows Farm House located at Kh. No. 445, 446 & 447, Village Hiranki, Delhi-110036.

INSPECTION REPORT

1. Name & address of the building : Park Meadows Farm House located at Kh. No. 445, 446 & 447, Village Hiranki, Delhi-110036.
2. Type of Occupancy : Assembly
3. Building Comprised : Ground Floor
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/FH/2021/WZ/255 dated 13/05/2021
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 09.04.2024
8. Name of Inspecting Officer : ADO R.K. Sinha
9. Name and designation of officers
From the building side : Sh. Rajeev Rana
10. Year of Construction : -----
11. Applicant's letter No. : Outdoor diary No. 248 Dated 05.04.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ Requirement letter dated 13/05/2021	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9 m 5 m NA	Provided Provided NA	MR MR NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	NA NA	NA NA	NA NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	NA NA	NA NA	NA NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA	NA NA NA NA	NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA Required	NA Natural Ventilation	NA MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	06 ABC & Co2 Yes	10 Provided Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 30 m 5 mm	Provided 30 m 5 mm	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel 	NA NA	NA NA	NA NA

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power 	NA	NA	
		NA	NA	
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	Provided	NA
		NA	01	NA
		NA	01	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	01	NA
		NA	01	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump house Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	Provided	MR
		40 m	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 ltrs	Provided	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	NA	NA	NA
		NA	NA	NA

2

19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection system provided in the building were tested/ checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/FH/2021/WZ/255 dated 13/05/2021 under rule 37 of the Delhi Fire Service Rules, 2010.

(Signature)
12/4/24

Signature of the Inspecting officer
Name : Rajeev Kumar Sinha
Designation : ADO/BW

br. no previous file is pending column

(Signature)
12/4/24

(Signature)
15/4

(Signature)
16/4/2024

(Signature)
16/4/24

(Signature) for letter in pursuance

(Signature)
18/4/24

(Signature)
18/4/24

DCFO/.....827.....
Dated: 15/4/2024