



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/Incl./ 220

Dated: 12/04/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Swiss Auto Products located at Plot No 18, Rajasthani Udhog Nagar, G.T. Karnal Road, Delhi-110033 comprised of Basement, ground & 02 upper floor only owned/occupied by M/s Swiss Auto Products issued Fire Safety Certificate by this department vide this office letter no. F6/DFS/MS/2021/167 dated 12.03.2021. The premise was inspection by the officer concerned of this department on 04.04.2024 in presence of Sh. Sunil Sharma (Attendant) and observed that all the fire prevention and fire safety arrangements as provided found in good working condition, premises have deemed complied with the requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and building premises is fit for occupancy class "G-2 Industrial building" with effect from..12/04/2024..... for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..12/04/2024..... at New Delhi


(Atul Garg)
Director
Ph:-011-23414000
ecg

Copy to :-

1. The Authorized Signatory, M/s Swiss Auto Products located at Plot No 18, Rajasthani Udhog Nagar, G.T. Karnal Road, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M/s Swiss Auto Products at Plot No. 18, Rajasthani Udhyog Nagar, G.T. Karnal, Road, Delhi-110033.
2. Type of Occupancy : Industrial Building
3. Type of Case : Renewal
4. Composition of building : Basement, Ground & 02 upper floors only
5. Details of previous NOC : F6/DFS/MS/2021/167 dated 12.03.2021
6. Fire Safety directives letter No : F.6/DFS/MS/BP/2013/1575 Dated: 12.06.2013
7. Date of inspection : 04.04.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Sh. Sunil Sharma (Attendant)
10. Year of Construction : 1999-2013
11. Applicant's letter No. : Letter No. Nil & DFS Dairy No.14515 Dated-22.03.2024

S.no.	Minimum Standards on fire prevention and fire safety U/R 33	Directives dated 12.06.2013/ Rules 35 (6)	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	12m	24m	MR
	• Gate width	4.5m	05 m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	03	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	1.5m	1.50m each & 85cm	MR
	• Basements	1.5m	1.5m each	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	Provided (Roof is made of Tin shade)	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	S/C Door -1.50m	1.50m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	31nos	31nos	MR

		ABC/CO2	ABC-25/Co2-06	MR
	<ul style="list-style-type: none"> Types ISI marking 	ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke/ Heat	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	NA	Provided	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants			
	• Total number of hydrants	02	Provided	MR
	• Hose Box	02	Provided	MR
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	2280 LPM	2280 LPM	MR
	➤ Head of Main pump	60m	60m	MR
	➤ Number of main pumps	01	01	MR
	➤ Jockey Pump out put			
	➤ Jockey pump head	180LPM	180 LPM	MR
	➤ Standby Pump out put	60m	60m	MR
	➤ Standby Pump Head			
	➤ Auto Starting/ Manual stopping	2280LPM (Diesel operative) 60m	2280 LPM (Diesel operative) 60m	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the pump	40mtr	Provided	MR
➤ Power Supply	Required	Provided	MR	
➤ Auto Starting of pump	Required	Provided	MR	

14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	1,00,000 LTR	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 LTR	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts. One open goods lift is provided			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked and found in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. F6/DFS/MS/2021/167 dated 12.03.2021 under rule 37 of the Delhi Fire Service Rules 2010.

Dy. Chief Fire Officer (WZ)

Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO/RN

Kindly Mention that no case is pending before it.

Ans (er) Sir There is no file pending before

05/04/2024
 8/4