

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No.F.6 DFS/MS/School/2024/SZ/312

Dated: 15/04/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **MCD Nigam Pratibha School** located at **DDA Slum-1, Kalkaji, New Delhi 110019** comprised of ground plus Two upper was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2021/SZ/173 Dated 03/03/2021. The said premises was re-inspected by officer concerned of this department on 05/04/2024 in presence of Ms. Reshma Madan (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational Building Group - B**" with effect from 15/04/2024 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 15/04/2024 at New Delhi by

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Principal, MCD Nigam Pratibha School at DDA Slum-1, Kalkaji, New Delhi 110019.
2. The Director of Education, MCD, Civic Centre Minto Road, New Delhi 110002

**Conditions for the validity of Fire Safety Certificate:-**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."



N/26

## INSPECTION REPORT

1	Name & Address of the Building	MCD Nigam Pratibha Vidyalaya, DDA, Slum -1, Kalkaji New Delhi 110019 (ID 195873)		
2	Type of Occupancy	Educational, Building Group-B		
3	Building Comprised of	Ground plus two upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2021/SZ/173 Dated 03/03/2021		
6	Fire Safety Directives Letter No	DOE Circular dated 01/02/2011		
7	Date of Inspection	05/04/2024		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side			
10	Year of construction	1998		
11	Applicant letter No.	Email Dated 14/03/2024		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Circular Requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	Accessible	6mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	Two	Two	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.50 m / 0.75 m	1.42 m each	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	One	Two	MR
	<b>e) Width of corridor</b>	1.5 m	2.1 m provided	MR
	<b>f) Door size</b>	1 mtr	1 mtr	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	<b>Smoke Management system.</b>			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	09Nos	09 Nos	MR
	• Types	ABC / Co2	ABC Type	MR
	• ISI Marking	ISI mark	Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	Two nos	Provided	MR
	• Length of hose-reel hose.	30m	30m	MR
	• Nozzle Diameter	5mtr	5mtr	MR
7	<b>Automatic fire detection &amp; alarming system.</b>			





A-

1-

- Flow switch panel.
- PA system panel.
- Battery backup.
- Building floor plan.

-NA-

-NA-

-NA-

-NA-

-NA-

-NA-

-NA-

-NA-

-NA-

-NA-

-NA-

-NA-

20. Special Fire Protection System for the Protection of special Risk, if any.

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/School/2021/SZ/173 Dated 03/03/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Handwritten signature and date: 9/4/2024*

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

*DO/SD  
Kumar*

*व्ययम*

*CP  
10/4/2024*

*Director*

*Handwritten signature and date: 14/4/24*

*Handwritten signature and date: 14/4/24*

As approved, F-1 letter is forwarded for your signature pl

*Handwritten signature and date: 14/4/24*

*Director  
12/4/24*