

C-25



FORM 'H'  
 FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
 [Refer sub - rule (1) of rule 35]  
 GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
 HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
 NEW DELHI

No.F6/DFS/MS/SZ/2024/CC/22

Dated: 15/04/2024

**FIRE SAFETY CERTIFICATE**

Certified that the building of Coaching center Located at Ground, 1<sup>st</sup>, 2<sup>nd</sup>, & 3<sup>rd</sup> floor, Plot No. 47, Sector-12B, Dwarka, New Delhi – 110075, in a building comprised of Basement + Ground + 03 Upper Floors have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 28/03/2024 in the presence of Sh. Navin Kohli and found that the said building is fit for occupancy class "Educational Coaching Centre" Group B Sub Division B – 1 with effect from 15/04/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/04/2024 at New Delhi.

  
 (Atul Garg)  
 Director  
 Delhi Fire Service  
 15/04/24

Copy to:

1. Sh. Navin Kohli, Coaching center Located at Ground, 1<sup>st</sup>, 2<sup>nd</sup>, & 3<sup>rd</sup> floor, Plot No. 47, Sector-12B, Dwarka, New Delhi – 110075.
2. The Executive Engineer (Bldg.) HQ, Municipal Corporation of Delhi, 9<sup>th</sup> floor, Minto Road New Delhi – 110002.

**Following fire safety directives must be adhered to:-**

1. All the exits passage leading to stairs shall be kept clear and free from lock & keys.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. Basement shall be used strictly as per building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/9

**INSPECTION REPORT**

1. Name & address of the building: Coaching center Located at Ground, 1<sup>st</sup>, 2<sup>nd</sup>, & 3<sup>rd</sup> floor, Plot No. 47, Sector-12B, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Educational (Basement+ Ground +3 Upper Floors)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 28-03-2024
7. Name of the Inspecting Officer :DO/SW & ADO (DWK)
8. Name and designation of Officer  
from the building side : Sh. Navin Kohli
9. Year of Construction : 2015
10. Applicant's letter No. : Email, dated 13/03/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per NBC	Provided at site	Remarks MR/NMR
1.	<b>Access of building</b>			
	• Road width	06mtrs	Provided	MR
	• Gate width	6 mtrs	On Road	MR
	• Width of internal road	NA	NA	NA
2.	<b>Number, width, Type &amp; Arrangements of exits</b>			
	a. Number of staircases			
	• Upper floors	02 Nos.	3 Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5m	2x1.5m & 1x1.35m Provided	MR
	• Basements	1.5m	Provided	MR
	c. Protection of exits			
	• Fire check door	Required in basement	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	01 mtr	Provided	MR
3.	<b>Compartmentation</b>			
	• Fire check door	Required in basement	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke managements System</b>			
	• Basements	30 a/c charge per hour	Provided	MR
	• Upper floors	12 a/c charge per hour	Natural ventilation	MR

N/10

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	10 nos. ABC & CO <sub>2</sub> ISI marked	Provided DCP, CO <sub>2</sub> & Water Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 No. 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Required Required Required Required Required	Provided Provided Provided Provided Provided	MR MR MR MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required NA NA	Provided NA NA	MR NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	NA NA NA NA NA NA NA NA NA NA NA 450 lpm 30Mtr Required Required	NA NA NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR

N/11

14. Captive water Storage for fire fighting:			
• Underground tank capacity	NA	NA	NA
➤ Draw off connection	NA	NA	NA
➤ Fire service inlet	Required	Provided	MR
➤ Access to tank	NA	NA	NA
• Overhead Tank capacity	10,000 L	Provided	MR
15. Exit Signage	Required	Provided	MR
16. Provision of Lifts			
➤ Pressurization of Lift Shaft	NA	NA	NA
➤ Pressurization of lift lobby	NA	NA	NA
➤ Communication in lift Car	Required	Provided	MR
➤ Fireman's Grounding Switch	Required	Provided	MR
➤ Lift Signage	Required	Provided	MR
17. Standby power supply	Required	DG Set	MR
18. Refuge Area			
➤ Total area	NA	NA	NA
➤ Location	NA	NA	NA
19. Fire control room			
1. Detector system panel	NA	NA	NA
2. Flow Switch Panel	NA	NA	NA
3. PA System Panel	NA	NA	NA
4. Battery backup	NA	NA	NA
5. Building Floor Plans	NA	NA	NA
20. Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010. If approved, the FSC may be issued.

*[Signature]*  
11/4/24

Sign of Inspecting Officer  
Name: Sh. Vedpal  
Designation : DO/SW

*[Signature]*  
28/3/24

Sign of Inspecting Officer  
Name: Udai vir Singh  
Designation: ADO/DWK

CFO (S2)  
*[Signature]*  
2/11/2024

~~Director~~  
*[Signature]*

Kindly confirm final.  
no case record before  
this is pending always  
*[Signature]*

CFO (S2)  
*[Signature]*  
5/11/2024  
Director

*[Signature]*