



No. F6/DFS/MS/School/NDZ/2024/318

Dated: 18/04/2024

FIRE SAFETY CERTIFICATE

Certified that the **Ryan International School, Located at Sec-B, Kondli Gharoli Complex, Mayur Vihar Phase - III, Delhi - 110096**, building comprised of **basement, ground plus three upper floors** was granted owned/occupied by **Ryan International School**, was issued FSC vide letter No. F6/DFS/MS/School/NDZ/2021/103 dated 05/02/2021. The School building was re-inspected by the officer concerned of this department on 05/04/2024 in presence of Mrs. Rajini Kumar (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **"Educational Building" (Group-B)** with effect from 18/04/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 18/04/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, Government of NCT Delhi, Old Sect., Delhi-110054.
2. The Principal, Ryan International School, Located at Sec-B, Kondli Gharoli Complex, Mayur Vihar Phase - III, Delhi - 110096.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. Basement shall be used strictly as per Building By-Laws 1983.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

4/20

INSPECTION REPORT

01.	Name & address of the building	Ryan International School, Located at Sec-B, Kondli Gharoli Complex, Mayur Vihar Phase-III, Delhi-110096.
02.	Building is comprised of	Basement, Ground plus Three upper floors
03.	Type of occupancy	Educational Building
04.	Type of case	Renewal
05.	Details of previous FSC	F6/DFS/MS/School/NDZ/2021/103 dated 05/02/2021.
06.	Fire safety directives letter no.	Nil
07.	Date of inspection	05/04/2024
08.	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)
09.	Name of the designation of officer from the building side	Mrs. Rajini Kumar (Principal)
10.	Year of construction	2002
11.	Applicant's letter no.	Outdoor Diary no.13789 dated 04/03/2024

S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
------	--	-------------	------------------	----------------

01.	Access to Building:			
	A	Road width	6.0 mtrs.	18 mtrs. ✓ MR
	B	Gate width	6.0 mtrs	6.0 mtrs ✓ MR
	C	Width of internal road	NA	NA NA

02.	Number, Width, Type and Arrangement of Exits:				
	A	Number of staircases			
		a	Upper floor	03 nos.	03 nos. ✓ MR
		b	Basement	03 nos.	03 nos. ✓ MR
	B	Width of staircases			
		a	Upper floor	1.50 mtrs or less	1.47 mtrs, 1.46 mtrs & 1.42 mtrs ✓ MR
		b	Basement	1.50 mtrs or less	1.47 mtrs, 1.46 mtrs & 1.42 mtrs ✓ MR
	C	Protection of exits			
		a	Fire check door	NA	NA NA
		b	Pressurization	NA	NA NA
	D	No. of continuous staircases to terrace	02 nos.	03 nos. ✓ MR	
	E	Width of corridor	1.50 mtrs. or less	1.80 mtrs. ✓ MR	
	F	Door size	01 mtrs	01 mtrs ✓ MR	
G	No. of Doors	02 nos	02 nos ✓ MR		

03.	Compartmentation:			
	A	Fire check door	NA	NA NA
	B	Sealing of electrical shafts	NA	NA NA
	C	Fire rating of shaft door	NA	NA NA
	D	Water curtain	NA	NA NA
	E	Fire dampers	NA	NA NA

04.	Smoke Management System:			
	A	Basement	NA	NA NA
	B	Upper floor	NA	NA NA

W

05.	Fire Extinguisher:				
	A	Total numbers	22 nos.	25 nos.	MR
	B	Types	ABC/CO ₂	ABC/CO ₂	MR
	C	ISI marking	ISI marked	Provided	MR
06.	First-Aid-Hose Reel:				
	A	Total numbers of each floor	02 nos	03 nos	MR
	B	Length of hose reel hose	30 mtrs	Provided	MR
	C	Nozzle diameter	05 mm	Provided	MR
07.	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
08.	MOEFA:				
09	Public Address System:				
			N/A	N/A	N/A
10.	Automatic Sprinkler System:				
	A	Basement	Required	Provided	MR
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants:				
	A	Size of riser/down-comer	100 mm	Provided	MR
	B	Number of hydrants per floor	02 nos	Provided	MR
	C	Hose box	02 nos	Provided	MR
12.	Yard Hydrants:				
	A	Total number of hydrants	04 nos	Provided	MR
	B	Hose box	04 nos	Provided	MR
13.	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	900 LPM	900 LPM	MR
	B	Head of main pump	40 m	40 m	MR
	C	Number of main pumps	01 no	01 no	MR
	D	Jockey pump out put	220 LPM	220 LPM	MR
	E	Jockey pump head	40 m	40 m	MR
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	Required	Provided	MR
	I	Pump house access	Required	Provided	MR
2	Terrace Level				
	A	Discharge of pump	N/A	N/A	N/A
	B	Head of the pump	N/A	N/A	N/A
	C	Power supply	N/A	N/A	N/A
	D	Auto starting of pump	N/A	N/A	N/A

W

SO

14.	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	50,000 liters	50,000 liters	MR
B	Draw-off connection	Required	Provided	MR
C	Fire service inlet	Required	Provided	MR
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	15,000 liters	15,000 liters	MR
15.	Exit Signage:			
		N/A	N/A	N/A
16.	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17.	Standby Power Supply:			
18.	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19.	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20.	Special Fire Protection systems for protection of special Risks, if any:			
		NA	N/A	N/A

The fire protection systems provided in the school building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/School/NDZ/2021/103 dated 05.02.2021, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed.

No file is pending with me before disposal of this case,



9/4/2024

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (L.N)

DY. CFO/NDZ

C.F.O.

Dir
09/04/24

10/04/2024

Director
10/04/24

Sig
F.T

Director

Letter is kept for sign. Please



15/4/2024