



No. F6/DFS/MS/School/NDZ/2024/317

Dated: 18/04/2024

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya No. 2, Mansarover Park, Shahdara, Delhi - 110032, building comprised of (New Building Two separate Block – C, Ground plus three upper floors) & (Old Building Block - A & B Ground plus one upper floor), owned / occupied by Sarvodaya Kanya Vidyalaya No. 2, was issued FSC vide letter No. F6/DFS/MS/School/2020/NDZ/342 dated 11/09/2020 (Old Building Block - A & B Ground plus one) & F6/DFS/MS/School/2018/ 117 dated 22.01.2018 (New Building Two separate Block - C Ground plus three). The School building was re-inspected by the officer concerned of this department on 01/04/2024 in presence of Mrs. Sunita Rao (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class “Educational Building” (Group-B) with effect from 18/04/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 18/04/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Principal, Sarvodaya Kanya Vidyalaya No.2, located at Mansarover Park, Shahdara, Delhi - 110032.
2. The Joint Director of Education, B- Block, Yamuna Vihar, Delhi-110053.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

M/25

INSPECTION REPORT

01.	Name & address of the building	Sarvodaya Kanya Vidyalaya No.2, located at Mansarovar Park, Shahdara, Delhi - 110032.
02.	Building is comprised of	Old Building Block A,B (Ground + 01 floor) & New Building Two separate Block C (Ground + 03 floors)
03.	Type of occupancy	Educational Building
04.	Type of case	Renewal
05.	Details of previous FSC	F6/DFS/MS/School/2020/NDZ/342 dated 11/09/2020 (Block A & B G + 1) F6/DFS/MS/School/2018/ 117 dated 22.01.2018 (Block C G + 3)
06.	Fire safety directives letter no.	NBC Part - IV
07.	Date of inspection	01/04/2024
08.	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)
09.	Name of the designation of officer from the building side	Mrs. Sunita Rao (Principal)
10.	Year of construction	1998 & 2006 & 2017
11.	Applicant's letter no.	Email dated 27/02/2024

S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
01.	Access to Building:			
A	Road width	6.0 mtrs.	6 mtrs. ✓	MR
B	Gate width	4.5 m	4.5 m ✓	MR
C	Width of internal road	N/A	N/A	N/A
02.	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
A	Upper floor Two separate blocks New Building(G+3)	(3+2) nos.	(4+2) nos. ✓	MR
B	Upper floor Old Building (G+1)	2 nos.	4 nos. ✓	MR
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor Old Building (G+1)	1.5 mtrs.	1.57 mtrs & 1.40 mtrs (Block A) & 1.5 mtrs & 1.57 mtrs. (Block B)	MR
	Upper floor Two separate blocks New Building(G+3)	1.5 mtrs.	1.72 mtrs. each ✓	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace			
	Old Building (G+1)	01 no.	01 no. ✓	MR
	Two separate blocks New Building(G+3)	01 no in each block	01 no in each block	MR
E	Width of corridor			
	Old Building (G+1)	1.5 mtrs.	1.5 mtrs (Block A) & 1.5 mtrs (Block B)	MR
	Two separate blocks New Building(G+3)	1.5 mtrs each block	1.5 mtrs each block ✓	
F	Door size			
	Old Building (G+1)	01 mtrs.	01 mtr	MR
	Two separate blocks New Building(G+3)	1.5 mtrs each block	1.77 mtrs each block ✓	
03.	Compartmentation:			
A	Fire check door	N/A	N/A	N/A
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
04.	Smoke Management System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

3

05. Fire Extinguisher:				
A	Total numbers Old Building (G+1)	08 nos.	08 nos.	MR
	Two separate Total numbers blocks New Building (G+3)	30 nos.	30 nos.	MR
B	Types	ABC/CO ₂	ABC/CO ₂	MR
C	ISI marking	ISI Marked	ISI Marked	MR
06. First-Aid-Hose Reel for : C Block				
A	Total numbers of each floor Block A, B (G+3)	(3+1) nos.	Provided	MR
B	Length of hose reel hose	30 mtrs.	Provided	MR
C	Nozzle diameter	05 mm	Provided	MR
07. Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
08.	MOEFA:	N/A	N/A	N/A
09	Public Address System:	N/A	N/A	N/A
10. Automatic Sprinkler System:				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11. Internal Hydrants:				
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
12. Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13. Pumping Arrangements:				
1 Ground level				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2 Terrace Level				
A	Discharge of pump Two separate blocks New Building (G+3)	450 LPM in each block	450 LPM in each block	MR
B	Head of the pump	40M	40M	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

14. Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity (Two separate blocks New Building (G+3))	10,000 liters.	10,000 liters.	MR
		Required	Provided	MR
15. Exit Signage:				
16. Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	NA	N/A	N/A
17. Standby Power Supply:				
18. Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19. Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20. Special Fire Protection systems for protection of special Risks, if any:				

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The earlier shortcomings issued vide letter no. F6/DFS/MS/School/NDZ/2021/167 dated 30/03/2021 by this department have been rectified by the management.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/DFS/MS/School/2020/NDZ/342 dated 11/09/2020 (Block A & B) G+1 & F6/DFS/MS/School/2018/117 dated 22.01.2018 (Block C) G + 3, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed.



31/4/2024

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (L.N)

DY. CFO/NDZ

King
24/04/24

C.F.O.

- spoken with CFO on 05/04/24
- Write for an undertaking that no file is pending before disposal off this case.

King