

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2024/SZ/325

Dated: 19/04/2024

FIRE SAFETY CERTIFICATE

Certified that the **New S.D.M. Public School**, located at 177F/10, Ward No 2, Mehrauli, New Delhi 1100030 comprised of Ground floor only owned/ occupied by Shanti Devi Educational & Charitable Society, Regd. was issued NOC by this department vide letter No. F6/MS/DFS/2006/1347 Dated 19-06-2006. The said premise was re-inspected by officer concerned of this department on 04/04/2024 in presence of Mr. Gajender Yadav (Manger) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No 262-362 dated 17/01/2005 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational Building Group - B**" with effect from 19/04/2024 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 19/04.2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Principal, New S.D.M. Public School, located at 177F/10, Ward No 2, Mehrauli, New Delhi 1100030
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/2

INSPECTION REPORT

| | | | | |
|--------|---|---|------------------|----------------|
| 1 | Name & Address of the Building | New S.D.M. Public School, (By Shanti Devi Educational & Charitable Society, Regd.) at 177F/10, Ward No 2, Mehrauli, New Delhi 1100030 | | |
| 2 | Type of Occupancy | Educational, Group-B (School) | | |
| 3 | Building Comprised of | at Ground floor only | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F6/MS/DFS/2006/1347 Dated 19-06-2006 | | |
| 6 | Fire Safety Directives Letter No | Nil | | |
| 7 | Date of Inspection | 04/04/2024 | | |
| 8 | Name of the Inspecting Officers | Sh. Rajesh Kumar ADO (BCP) | | |
| 9 | Name & Designation of Officers from the building side | Mr. Gajender Yadav (Manager) | | |
| 10 | Year of construction | 2005 | | |
| 11 | Applicant letter No. | Outdoor diary no 14270 dated 15/03/2024 | | |
| S. No. | Minimum standards on Fire Prevention and Fire Safety U/R 33 | Old NOC requirements | Provided at Site | Remarks MR/NMR |
| 1. | Access to Building. | | | |
| | • Road width | Required | Accessible | MR |
| | • Gate width | -NA- | -NA- | -NA- |
| | • Width of internal road | -NA- | -NA- | -NA- |
| 2. | Number, width, type & arrangement of exits. | | | |
| | a) Number of Staircase | | | |
| | ➤ Upper floors. | -NA- | -NA- | -NA- |
| | ➤ Basement floor. | -NA- | -NA- | -NA- |
| | b) Width of Staircase | | | |
| | ➤ Upper floors | -NA- | -NA- | -NA- |
| | ➤ Basement floor | -NA- | -NA- | -NA- |
| | c) Protection of exits | | | |
| | ➤ Fire check door | -NA- | -NA- | -NA- |
| | ➤ Pressurization | -NA- | -NA- | -NA- |
| | d) No. of continuous staircase to terrace | -NA- | -NA- | -NA- |
| | e) Width of corridor | -NA- | -NA- | -NA- |
| | f) Door size | 1m | Provided | MR |
| 3. | Compartmentation. | | | |
| | • Fire check door. | -NA- | -NA- | -NA- |
| | • Sealing of electrical shafts. | -NA- | -NA- | -NA- |
| | • Fire rating of shaft door. | -NA- | -NA- | -NA- |
| | • Water curtain | -NA- | -NA- | -NA- |
| | • Fire dampers. | -NA- | -NA- | -NA- |
| 4. | Smoke Management system. | | | |
| | • Basement | 30 ACPH | -NA- | -NA- |
| | • Upper floors | 12 ACPH | NA | NA |
| 5. | Fire Extinguishers. | | | |
| | • Total numbers | Required | 02 Nos | MR |
| | • Types | ABC / CO2 | ABC & CO2 | MR |
| | • ISI Marking | ISI marked | Provided | MR |
| 6. | First Aid Hose Reels. | | | |
| | • Total numbers on each floor. | -NA- | -NA- | -NA- |
| | • Length of hose-reel hose. | -NA- | -NA- | -NA- |
| | • Nozzle Diameter | -NA- | -NA- | -NA- |
| 7. | Automatic fire detection & alarming system. | | | |
| | • Type of detectors | -NA- | -NA- | -NA- |

~


N

M/3



| | | | | |
|-----|---|----------|----------|------|
| | <ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 8. | MOEFA | -NA- | -NA- | -NA- |
| 9. | Public Address System | -NA- | -NA- | -NA- |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 11. | Internal Hydrants. | | | |
| | <ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. | NA | -NA- | NA |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 12. | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants. Hose box. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 13. | Pumping arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 14. | Captive water storage for fire fighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 17. | Standby Power Supply | -NA- | -NA- | -NA- |
| 18. | Refuge Area | | | |
| | <ul style="list-style-type: none"> Total area Location | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 19. | Fire Control Room. | | | |
| | <ul style="list-style-type: none"> Detector system panel. Flow switch panel. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |

2

| | | | |
|--|------|------|------|
| <ul style="list-style-type: none"> • PA system panel. • Battery backup. • Building floor plan. | -NA- | -NA- | -NA- |
| | -NA- | -NA- | -NA- |
| | -NA- | -NA- | -NA- |
| 20. Special Fire Protection System for the Protection of special Risk, if any. | | | -NA- |
| <p>The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/MS/DFS/2006/1347 Dated 19-06-2006, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.</p> <p>Accordingly DFA is put up for approval and signature please.</p> <div style="text-align: right;">  Signature of the Inspecting Officer Name: Sh. Rajesh Kumar Design: ADO (BCP) </div> | | | |

DO (SD)

~~merish~~
~~9/4/24~~

~~cfo~~ ~~Vingh~~
~~12/4/2024~~

~~Director~~ ~~[Signature]~~
~~12/04/24~~

~~Amrinder~~

As approved, F.T. letter is put up
for your signature P1

1/5
14/4/24

~~Director~~ ~~[Signature]~~
~~10/04/24~~
~~m~~