



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

c/19



No. F-6/DFS/MS/WZ/2024/ E/H | 145

Dated:- 19/04/2024

To,

Sh. Baboo Walia,
M/s. Vardaan Sandoz
A Unit of JB Decore Pvt. Ltd.,
Hall No. 1, Dilli Haat, Pitampura,
Delhi- 110034.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Vardaan Sandoz (A Unit of JB Decore Private Limited) located at Hall No. 1, Dilli Haat, Pitampura, Delhi- 110034.

Sir,

Please refer to MHA application ID 2024031903245 dated 20.03.2024 on the subject cited above. In this connection it is to inform you that the above said assembly hall was inspected by the officer concerned of this department on 15.04.2024 in presence of Sh. Baboo Walia to check the fire safety measures provided in the building.

During the course of inspection it has been observed that fire safety arrangements such as fire extinguishers, hose reels, hydrants etc found provided, However the following shortcomings have been observed:-

- 1 First Aid Hose reel provided but not functional.
- 2 Internal Hydrant found provided but not functional.
- 3 Terrace fire pump found provided but not functional.

In View of the above, the application for issuance of Fire Safety Certificate is not considered at this stage and rejected. You are requested to re-apply on MHA portal as and when site is ready for inspection.

Yours faithfully

(Atul Garg)

Director

Ph: 011-23414000

Copy to:-

1. The Joint Commissioner of Police, Licensing Unit, 1st Floor, Police Station, Defence Colony, New Delhi- 110049.
2. MHA Portal ID No. 2024031903245.