

219

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No: F.6/DFS/MS/School/WZ/2024/322

Dated: 18/04/2024

FIRE SAFETY CERTIFICATE

Certified that the Akhil Bhartiya Netrahin Sangh (Regd.), Located at B-3 Block, Baba Ramdev Marg, Raghbir Nagar, New Delhi-110027, is running at Ground & First floor in a building comprised of ground + 02 upper floor (2nd floor is using as hostel). The premises was inspected by the officer concerned by this department on 11/03/2024 in the presence of Sh. Devender Singh (General Secretary) and found that the all the fire safety arrangements provided in the premises found in good working condition. The premises have complied with the fire prevention and fire safety requirements in accordance DOE Circular 262-362 dated 17/01/2005 and that the premises is fit for occupancy class "Education" (Group-B) with effect from ..18/04/2024.....for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010. Condition mentioned below.

Issued on ...18/04/2024... at New Delhi.


(Atul Garg)
Director

Copy to: -

1. The Principal, Akhil Bhartiya Netrahin Sangh (Regd.), Located at B-3 Block, Baba Ramdev Marg, Raghbir Nagar, New Delhi-110027 .
2. Director of Education, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building	Akhil Bhartiya Netrahin Sangh (Regd.), Located at B-3 Block, Baba Ramdev Marg, Raghbir Nagar, New Delhi-110027.
2. Type of Occupancy	Educational
3. Type of Case	New
4. Details of previous NOC	Nil
5. Fire Safety directives letter No	DOE circular 262-362 dated 17/01/2005
6. Date of inspection	11/03/2024
7. Name of the Inspecting Officers	Sarabjeet Singh, ADO (MN)
8. Name and designation of officers from the building side	Sh. Devender Singh (General Secretary)
9. Year of Construction	1961-1962
10. Applicant's letter No.	letter dated: 03/01/2024, outdoor diary no. 11505 dated 03/01/2024

* The said school is running at Ground & First floor in a building comprised of ground + 02 upper floor (2nd floor is using as hostel)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE circular 262-362 dated 17/01/2005	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	If one staircase is less than 1.5m then alternate staircase is not less than 0.75m.	(1 x 1.4m, 1 x 1.3m & 1 x 1m Separated by brickwall)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	1.5m	Provided	MR
	g. Door Size	1 m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	10 Nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

h 28

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:			
		NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

ADD/MN
03/2024
1/04/2024

~~Dy CPO (w/2)~~

~~SP~~
19/3/2024

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

It is a fresh case

Where is 'I' form & school performa?

Sl. No. 148
dated 20/3/2024
5/4/2024

~~ADO (MN)~~

~~SP~~
20/3/2024

Sl. No. I. Form & School performa has placed at C-17 & C-16.

resubmitted pls.
many file pending

~~SP~~
04/04/2024

~~Dy CPO (w/2)~~

~~SP~~
05/4

Sl. No. 148
dated 01/4/2024

cfo / 9/4/2024
Director
ADP

ADD/MN