

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/2024/ 248

Dated 23/04/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **GHALIB INSTITUTE AUDITORIUM** located at AIWAN -E, Galib Marg, Mata Sundari Lane, New Delhi, comprised of basement, Ground floor and auditorium at ground floor, was earlier granted FSC by this department vide letter No. F6/DFS/MS/2021/130 dated 19/02/21. Now, the premises was re-inspected by the officer concerned of this department on 15/04/24 in the presence of Mr. Idresh and found that said auditorium has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly building Group - D (Auditorium) only with effect from 23/04/2024.....for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 23/04/2024.....at New Delhi by.

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Joint Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi.
2. GALIB INSTITUTE AUDITORIUM located at AIWAN -E, Galib Marg, Mata Sundari Lane, New Delhi,

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

## INSPECTION REPORT

1.	Name & address of the building	GALIB Institute Auditorium located at AIWAN -E, Galib Marg , Mata sundari Lane , New Delhi
2.	Type of occupancy:-	Assembly building , group D , Basement , ground floor ( auditorium )
3.	Type of case:-	Renewal
4.	Details of previous FSC:-	No. F6/DFS/MS/2021/130 dated 19/02/21.
5.	Fire safety directives No.-	N/A
6.	Date of inspection:-	15.04.2024
7.	Name of the inspecting officer:-	Sh. Ravinder Singh (ADO/CC)
8.	Name & designation of officer From the building side:-	<u>Mr. Idresh</u>
9.	Year of construction:-	1982 old building
10.	Applicant's letter No:-	letter no. A.G.D/13 dated 03.04.2024

Old case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	09	12 mtr. ✓	MR
	2) Gate width	4.5m	4.5m ✓	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	04 Nos.	04 Nos. ✓	MR
	2. Basements	01 No.	01 No.	MR
	<b>B. Width of staircase</b>			
	1. Upper floors	1.5mtr.	02 of 1.5 mtr & ✓ 02 of 1.30 mtr. ✓	MR
	2. Basements	.90mtr	.90 mtr.	MR(old)
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.5 mtr.	02 nos 1.30mtr ,02 nos 1.5mtr ,02 nos 1.75mtr & 2.0 mtr ✓	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	12 ACPH	Mechanical	MR



N/62

	2) Upper floors	12 ACPH	Natural	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	20 Nos.	20 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number at each floor	02	02	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors( beam type )	Required	Provided	MR
	2) Location of main panel	Ground	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided	MR
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	Required	Provided	MR
	2) Upper floors ( stage )	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	100mm	Provided	MR
	2) Number of hydrants per floor	02 Nos	Provided	MR
	3) Hose box	02 Nos	Provided	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	02 Nos	Provided	MR
	2) Hose box	02 Nos	Provided	MR
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	1620 LPM	1620 LPM	MR
	b) Head of main pump	25mtr	25mtr	MR
	c) Number of main pump	01	01	MR
	d) Jockey pump out put	280 LPM	280 LPM	MR
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	50,000liter	50,000liter	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	20,000 ltr.	20,000 ltr.	MR


N/62

	Exit Signage.	Required	Provided	MR
15.	Provision of Lifts.			
16.	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided ✓	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: DCP & CO <sup>2</sup>			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter No. No. F6/DFS/MS/2021/130 dated 19/02/21, under rule 35(6) of the Delhi Fire Service Rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer



Name :- Ravinder Singh  
Designation :- ADO (CC)

D.A.C.B.  
Red  
18/4/24  
Dy. CCS (Ops 2) 18/04/24  
C.F.O. 19/4/2024  
Director 19/4/24  
Director 20/4/24  
As per copy of FSC put up for kind perusal and signature  
Director 20/4/24