




No. F6/DFS/MS/School/NDZ/2024/ 297

Dated: 10/04/2024

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Girls Sr. Sec. School at Brahampuri, Delhi-110053**, comprised **Ground plus three upper floors Only (Block C & D)** owned / occupied by **Govt. Girls Sr. Sec. School**, was issued FSC vide letter No. F6/DFS/MS/School/2017/NDZ/1865 dated 27/12/2017. The School building was re-inspected by the officer concerned of this department on 01/04/2024 in presence of Mrs. Amita Verma (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **“Educational Building” (Group-B)** with effect from 10/04/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 10/04/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
o/c DELHI FIRE SERVICE
①

Copy to:-

1. The Principal, Govt. Girls Sr. Sec. School at Brahampuri, Delhi-110053
2. The Dy. Director of Education, North-East, Block, Yamuna Vihar, Delhi-110053.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

| | | | | |
|------|---|--|----------------------------------|---------------------------------------|
| 01. | Name & address of the building | Govt. Girls Sr. Sec. School at Brahampuri, Delhi-110053. | | |
| 02. | Building is comprised of | Ground plus three upper floors Only (Block C & D) | | |
| 03. | Type of occupancy | Educational | | |
| 04. | Type of case | Renewal | | |
| 05. | Details of previous FSC | F6/DFS/MS/School/2017/NDZ/1865 dated 27/12/2017 | | |
| 06. | Fire safety directives letter no. | NBC Part-IV | | |
| 07. | Date of inspection | 01/04/2024 | | |
| 08. | Name of the inspecting officers | Yashwant Singh Meena ADO (L.N) | | |
| 09. | Name of the designation of officer from the building side | Mrs. Amita Verma (Principal) | | |
| 10. | Year of construction | 2017 | | |
| 11. | Applicant's letter no. | Email dated 14/03/2024 | | |
| S.No | Minimum standard of fire prevention and fire safety U/R 33 | NBC Part-IV Requirement | Provided at site | Remarks MR/NMR |
| 01. | Access to Building: | | | |
| | A | Road width | 6.0 mtrs. | 6.0 mtrs. MR |
| | B | Gate width | N/A | N/A |
| | C | Width of internal road | N/A | N/A |
| 02. | Number, Width, Type and Arrangement of Exits: | | | |
| | A | Number of staircases | | |
| | a | Upper floor | 02 nos. (01 no in each block) | 02 nos. ✓ (01 no in each block) MR |
| | b | Basement | N/A | N/A |
| | B | Width of staircases | | |
| | a | Upper floor | 1.50 mtrs each block | 1.82 mtrs each block ✓ MR |
| | b | Basement | N/A | N/A |
| | C | Protection of exits | | |
| | a | Fire check door | N/A | N/A |
| | b | Pressurization | N/A | N/A |
| | D | No. of continuous staircases to terrace | 01 no in each block | 01 no in each block ✓ MR |
| | E | Width of corridor | 1.50 mtrs each block | 1.76 mtrs each block MR |
| | F | Door size | 1.0 mtr | 1.0 mtr ✓ MR |
| 03. | Compartmentation: | | | |
| | A | Fire check door | N/A | N/A |
| | B | Sealing of electrical shafts | N/A | N/A |
| | C | Fire rating of shaft door | N/A | N/A |
| | D | Water curtain | N/A | N/A |
| | E | Fire dampers | N/A | N/A |
| 04. | Smoke Management System: | | | |
| | A | Basement | N/A | N/A |
| | B | Upper floor | N/A | N/A |

(W)

| | | | | |
|------------|--|--------------------------------|----------------------------------|-----|
| 05. | Fire Extinguisher: | | | |
| A | Total numbers | 18 nos. | 20 nos. ✓ | MR |
| B | Types | ABC/CO ₂ | ABC/CO ₂ | MR |
| C | ISI marking | ISI Marked | ISI Marked | MR |
| 06. | First-Aid-Hose Reel: | | | |
| A | Total numbers of each floor | 02 nos. 01 no in each block | 02 nos. ✓ 01 no in each block | MR |
| B | Length of hose reel hose | 30 mtrs. | 30 mtrs. | MR |
| C | Nozzle diameter | 05 mm | 05 mm | MR |
| 07. | Automatic Fire Detection and Alarming System: | | | |
| A | Type of detectors | N/A | N/A | N/A |
| B | Location of main panel | N/A | N/A | N/A |
| C | Location of repeater panel | N/A | N/A | N/A |
| D | Alternate source of power | N/A | N/A | N/A |
| E | Hooters | N/A | N/A | N/A |
| 08. | MOEFA: | N/A | N/A | N/A |
| 09 | Public Address System: | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System: | | | |
| A | Basement | N/A | N/A | N/A |
| B | Upper floor | N/A | N/A | N/A |
| C | Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants: | | | |
| A | Size of riser/down-comer | N/A | N/A | N/A |
| B | Number of hydrants per floor | N/A | N/A | N/A |
| C | Hose box | N/A | N/A | N/A |
| 12. | Yard Hydrants: | | | |
| A | Total number of hydrants | N/A | N/A | N/A |
| B | Hose box | N/A | N/A | N/A |
| 13. | Pumping Arrangements: | | | |
| 1 | Ground level | | | |
| A | Discharge of main pump | N/A | N/A | N/A |
| B | Head of main pump | N/A | N/A | N/A |
| C | Number of main pumps | N/A | N/A | N/A |
| D | Jockey pump out put | N/A | N/A | N/A |
| E | Jockey pump head | N/A | N/A | N/A |
| F | Standby pump out put | N/A | N/A | N/A |
| G | Standby pump head | N/A | N/A | N/A |
| H | Auto starting /manual stopping | N/A | N/A | N/A |
| I | Pump.house access | N/A | N/A | N/A |
| 2 | Terrace Level | | | |
| A | Discharge of pump | 450 LPM | 450 LPM x 2 ✓ | MR |
| B | Head of the pump | 40 m | 40 m ✓ | MR |
| C | Power supply | Required | Provided ✓ | MR |
| D | Auto starting of pump | Required | Provided ✓ | MR |

(u)

| | | | | |
|---|------------------------------|------------------------------|---------------------------------|-----|
| 14. Captive Water Storage for Fire Fighting: | | | | |
| A | Underground tank capacity | N/A | N/A | N/A |
| B | Draw-off connection | N/A | N/A | N/A |
| C | Fire service inlet | N/A | N/A | N/A |
| D | Access to tank | N/A | N/A | N/A |
| E | Overhead tank capacity | 10,000 liters. In each Block | 10,000 liters. In each Block. ✓ | MR |
| 15. Exit Signage: | | Required | Provided | MR |
| 16. Provision of Lifts: | | | | |
| A | Pressurization of lift shaft | N/A | N/A | N/A |
| B | Pressurization of lift lobby | N/A | N/A | N/A |
| C | Communication in lift car | N/A | N/A | N/A |
| D | Firemen's grounding switch | N/A | N/A | N/A |
| E | Lift signage | N/A | N/A | N/A |
| 17. Standby Power Supply: | | NA | N/A | N/A |
| 18. Refuge Area: | | | | |
| A | Total area | N/A | N/A | N/A |
| B | Location | N/A | N/A | N/A |
| 19. Fire Control Room: | | | | |
| A | Detector system panel | N/A | N/A | N/A |
| B | Flow switch panel | N/A | N/A | N/A |
| C | PA system panel | N/A | N/A | N/A |
| D | Battery backup | N/A | N/A | N/A |
| E | Building floor plans | N/A | N/A | N/A |
| 20. Special Fire Protection systems for protection of special Risks, if any: | | NA | N/A | N/A |

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The shortcomings issued vide letter no. F6/DFS/MS/School/2020/773 dated 14/12/2020 by this department has been rectified by the management.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/DFS/MS/School/2017/NDZ/1865 dated 27/12/2017, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed.


2/4/2024

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (L.N)

DY. CFO/NDZ

C.F.O.

live
03/04/24

4/4/2024

Director

4 CFO (NDZ)

CFO/NDZ
5/4/2024

confirm that one case
should be for this case
is pending with you
ATC