



No. F6/DFS/MS/School/NDZ/2024/ 326

Dated: 19/04/2024

FIRE SAFETY CERTIFICATE

Certified that the **Mother's Global School Located at C-Block, Preet Vihar, Vikas Marg, Delhi - 110092**, comprised of three blocks, whereas two blocks having basement, ground plus two upper floors and one block is ground plus two upper floors only. Owned/occupied by **Mother's Global School** was issued Fire Safety Certificate vide letter no. F6/DFS/MS/School/2021/NDZ/234 dated 18/03/2021. The School building was re-inspected by the officer concerned of this department on 04/04/2024 in presence of Mr. Ashok Kumar Jethy (Chairman) of the school and found that the school building two blocks having basement, ground plus two upper floors and one block is ground plus two upper floors only is fit for occupancy class "**Educational Building**" Group B for with effect from 19/04/2024 for a period of **three years**, in accordance with the Rule 36 unless renewed under Rules 37 of sooner cancelled under Rule 40 and subject to compliance of the conditions under Rules 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed below.

Issued on 19/04/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Joint Director of Education, (Land & Estate), Directorate of Education, Lucknow Road, Delhi-110054.
2. The Chairman, Mother's Global School Located at C - Block, Preet Vihar, Vikas Marg, Delhi - 110092.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. Basement shall be used as per NBC/UBBL
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Mother's Global School Located at C - Block, Preet Vihar, Vikas Marg, Delhi - 110092.		
2	Building is comprised of	(Two Blocks B + G + 2) & (One Block G + 2)		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal ✓		
5	Details of previous FSC	F6/DFS/MS/School/2021/NDZ/234 dated 18.03.2021. ✓		
6	Fire safety directives letter no.	NBC Part - IV		
7	Date of inspection	02.04.2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. Ashok Kumar Jethy (Chairman)		
10	Year of construction	1995		
11	Applicant's letter no.	Outdoor dairy No.14444 dated 20/03/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	5.0 mtrs.	20 mtrs. ✓	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	02 nos.	02 nos. each block	MR
b	Basement	02 nos.	02 nos.	MR
B	Width of staircases			
a	Upper floor	1.50 mtrs.	(Two Blocks 1.50 mtrs & 1.10 each) (One block 1.35 mtrs x 2)	MP.
b	Basement	1.50 mtrs	1.50 mtrs & 1.0 mtr ✓	MR
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	01 no.	01 no each block	MR
E	Width of corridor	1.50 mtrs.	1.50 mtrs. ✓	MR
F	Door size	1.0 mtr.	1.0 mtr. ✓	MR
3	Compartmentation:			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
A	Basement	N/A	Ventilated	MR
B	Upper floor	N/A	N/A	N/A

5.	Fire Extinguisher:				
	A	Total numbers	25 nos.	26 nos. ✓	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	ISI Marked	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	01 no.	01 no each block ✓	MR
	B	Length of hose reel hose	30 mtrs	30 mtrs ✓	MR
	C	Nozzle diameter	5 mm	5 mm /	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	Required	Provided ✓	MR
	E	Hooters	Required	Ground floor ✓	MR
8	MOEFA:		Required	Provided ✓	MR
9	Public Address System:		Required	Provided ✓	MR
10	Automatic Sprinkler System:				
	A	Basement	Required	Provided	MR
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	Required	100 mm each block	MR
	B	Number of hydrants per floor	01 no.	01 no. ✓	MR
	C	Hose box	01 no.	01 no. ✓	MR
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	450 LPM	450 LPM each block ✓	MR
	B	Head of the pump	40 mtrs	40 mtrs ✓	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	50,000 liters ✓ MR
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	10,000 liters each block	10,000 liters each block ✓ MR
15	Exit Signage:		Required	Provided MR
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A N/A
	B	Pressurization of lift lobby	N/A	N/A N/A
	C	Communication in lift car	N/A	N/A N/A
	D	Firemen's grounding switch	N/A	N/A N/A
	E	Lift signage	N/A	N/A N/A
17	Standby Power Supply:		Required	Provided MR
18	Refuge Area:			
	A	Total area	N/A	N/A N/A
	B	Location	N/A	N/A N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A N/A
	B	Flow switch panel	N/A	N/A N/A
	C	PA system panel	N/A	N/A N/A
	D	Battery backup	N/A	N/A N/A
	E	Building floor plans	N/A	N/A N/A
20	Special Fire Protection systems for protection of special Risks, if any:		N/A	N/A N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/DFS/MS/School/2021/NDZ/234 dated 18.03.2021, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed

No. file is pending with me before disposal of this case

Signature of the Inspecting Officer
 Name- Yashwant Singh Meena
 Designation- ADO (L.N)

DY. CFO/NDZ

C.F.O.

10/04/24

15/4/2024

Directed by

16/04/24

Am L.N