



C-41

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2024 / School / WZ / 334

Dated 19/04/2024

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya located at A- Block, Sawda (Ghevra) Delhi-110081 comprised of Two Blocks (Ground plus First floor) owned/occupied by Sarvodaya Kanya Vidyalaya was issued FSC by this department vide letter No F6 /DFS/MS/2021/School/WZ/399 dated 23.06.2021. The premises was re-inspected by the officer concerned of this department on 16.04.2024 in the presence of Sh. K.P. Singh (Estate Manager), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/premise is fit for occupancy Group B Educational with effect from ...19.04.2024 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 19.04.2024 at New Delhi by


(Atul Garg)
Director
Ph. 011-23414000

Copy to:-

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054
2. The Principal, SKV Sawda, Ghevra, A - Block, Delhi-110081.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. Electric Panel and electric meter under the staircase must be removed within a period of three months from the date of issuance of the Fire Safety Certificate. Failing to do so the Fire Safety Certificate will be null and void.

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya located at A Block, Sawda Ghevra, Delhi- 110081.
2. Type of Occupancy : Educational
3. Building Comprised of : Two Blocks (Ground plus First floor)
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/2021/School/WZ/399 dated 23/06/2021
6. Fire Safety directives letter No : DOE circular No. 3298-3398 dated 01/03/2011
7. Date of inspection : 16/04/2024
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
From the building side : Sh. K.P. Singh (Estate Manager)
10. Year of Construction : 2007 & 2013
11. Applicant's letter No. : E Mail ID dated 10/04/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Block A- 01 Block B- 02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50 m each	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Naturally Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	16	28	MR
	• Types	ABC/ CO2 Type	Provided	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA

N-35

				entr	Det	Flo	PA
	• Hooters' Location	NA	NA		NA	NA	NA
8.	MOEFA	NA	NA		NA	NA	NA
9.	Public Address System	NA	NA				
10.	Automatic Sprinkler System				NA		
	• Basement	NA	NA		NA		
	• Ground Floor	NA	NA		NA		
	• Sprinkler above false ceiling	NA	NA				
11.	Internal Hydrants				NA		
	• Size of riser/down-comer	NA	NA		NA		
	• Number of hydrants per floor	NA	NA		NA		
	• Hose Box	NA	NA				
12.	Yard Hydrants				NA		
	• Total number of hydrants	NA	NA		NA		
	• Hose Box	NA	NA				
13.	Pumping Arrangements						
	• Ground Level				NA		
	➤ Discharge of main Pump	NA	NA		NA		
	➤ Head of Main pump	NA	NA		NA		
	➤ Number of main pumps	NA	NA		NA		
	➤ Jockey Pump out put	NA	NA		NA		
	➤ Jockey pump head	NA	NA		NA		
	➤ Standby Pump out put	NA	NA		NA		
	➤ Standby Pump Head	NA	NA		NA		
	➤ Auto Starting/Manual Stopping	NA	NA		NA		
	➤ Pump House Access	NA	NA		NA		
	• Terrace level						
	➤ Discharge of pump	NA	NA		NA		
	➤ Head of the pump	NA	NA		NA		
	➤ Power Supply	NA	NA		NA		
	➤ Auto Starting of pump	NA	NA		NA		
14.	Captive Water Storage for fire fighting						
	• Underground tank capacity	NA	NA		NA		
	➤ Draw-off connection	NA	NA		NA		
	➤ Fire service inlet	NA	NA		NA		
	➤ Access to tank	NA	NA		NA		
	• Overhead Tank capacity	NA	NA		NA		
15.	Exit Signage.	Required	Provided		MR		
16.	Provision of Lifts.						
	• Pressurization of Lift Shaft	NA	NA		NA		
	• Pressurization of Lift lobby	NA	NA		NA		
	• Communication In lift Car	NA	NA		NA		
	• Fireman's Grounding Switch	NA	NA		NA		
	• Lift Signage	NA	NA		NA		
17.	Standby power supply	NA	NA		NA		
18.	Refuge Area.						
	➤ Total Area	NA	NA		NA		
	➤ Location	NA	NA		NA		

Control Room			
•	Detector System Panel	NA	NA
•	Flow Switch Panel	NA	NA
•	PA System Panel	NA	NA
•	Battery backup	NA	NA
•	Building Floor Plans	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: Electric meter and electrical panel installed under the staircase have to be removed to a safer place.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01/03/2011, it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/2021/School/WZ/399 dated 23/06/2021.

Sir, No previous letter pending with the

Rajeev Kumar Sinha
16/4/24

Director
16/4/24

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

[Signature]
16/4

DCFO/.....843.....
Dated.....16/04/2024

C/o *[Signature]*
18/4/2024

Director
[Signature]
18/04/24

Sir, G.T letter in photo is sign please!

[Signature]

[Signature]
19/4/24

Director
[Signature]
19/04/24