

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE

C-38

[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI

No. F6/DFS/MS/School/2024/SW/330

Dated: 19/04/2024

FIRE SAFETY CERTIFICATE

Certified that the building of St. Mary's Sr. Secondary School Located at Sector - 19, Dwarka, New Delhi - 110075, comprised of Basement + Ground + 02 Upper Floor was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2019/SZ/290, dated 05/02/2019. The premises was re inspected by the officer concerned of this department on 08/04/2024 in the presence of Ms. Seema Bali (V.Pricipal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Educational" with effect from 19/04/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/04/2024 at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service.

OK
19/04/24
18/4/24

Copy to: -

1. The Principal, St. Mary's Sr. Secondary School at Sector - 19, Dwarka, New Delhi - 110075.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building by laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expired.

INSPECTION REPORT

1. Name & address of the building: St. Mary's Sr. Secondary School Located at Sector - 19, Dwarka, New Delhi - 110075.
2. Type of Occupancy : Educational (Basement + Ground+ 2 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2019/SZ/290, dated 05/02/19
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/97/56, dated 15/01/1997
6. Date of inspection : 08/04/2024
7. Name of the Inspecting Officer : Sh. Uday vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side: Ms. Seema Bali (V.Pricipal)
9. Year of Construction : 2003
10. Applicant's letter No. : Nil dated 22/03/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/6, N/7 & N/8	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 mtr	Provided	MR
	• Gate width	5.5 mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04 Nos.	Provided	MR
	• Basements	04 Nos.	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr each	Provided	MR
	• Basements	1.5 m each	Provided	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	04 Nos.	Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1.2 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Natural ventilation	MR
5.	Fire Extinguishers			

(Handwritten signature)


N/14

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	04 nos. each floor ABC & CO ₂ ISI marked	Provided ABC & CO ₂ ISI marked	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 Nos. 30 mtr 05 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto starring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		2x900 lpm	Provided	MR
		40 mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	50,000 ltr	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		25,000 ltr	Provided	MR



5	Exit Signage	Required	Provided	MR
6.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 & ABC, Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2019/SZ/290, dated 05/02/2019 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved FSC may be issued.


 Sign of Inspecting Officer
 Name Uday K. Singh
 Designation ADP/DCS


10/4/24


12/4/2024

12/4/24

