

C-61

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/GH/2024/SZ/95

Dated: 19/04/2024

FIRE SAFETY CERTIFICATE

Certified that the Guest House in the Name & Style of **M/s Hotel R.S. Residency** located at Plot No A-151 /152, Road No 4, Mahipalpur Extension, New Delhi - 110037 comprised of Lower Ground Floor, Upper Ground Floor & 1st Floor (others Property), **2nd Floor (11 Guest Room), 3rd Floor (11 Guest Room) Total 22 Guest Rooms**, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/GH/2021/SZ/113 dated 26.02.2021. The premise was re-inspected by the officer concerned of this department on 15/04/2024 in the presence of Mr. Ritesh Sehrawat and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Residential & Lodging, Group-A**" (Guest House) and **validity upto 31/03/2027** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/04/2024 at New Delhi by

(ATUL GARG)
DIRECTOR

Delhi Fire Service

Copy to: -

1. The Addl. Commissioner of Police (Lic.), 1st Floor, P.S. Defence Colony, New Delhi-110049 (Ref. MHA Portal ID 2024033103900 Dated: 31.03.2024)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

N/B

INSPECTION REPORT

- 1 Name & address of the building : M/s Hotel R. S. Residency, Plot No – A- 151 & 152, Street No- 9, Road, No 4, Mahipalpur Extn. New Delhi-110037.
- 2 Type of Occupancy : Residential (Group- A) Guest House
- 3 Type of Case : Renewal (Lower ground, upper ground plus 03 upper floors)
- 4 Details of previous NOC : F6/DFS/MS/GH/2021/SZ/113 dated 26.02.2021
- 5 Fire Safety directives letter No : NBC Part- IV
- 6 Date of inspection : 15.04.2024
- 7 Name of the Inspecting Officers : DO (South) & ADO (BCP)
- 8 Name and designation of officers : Sh. Ritesh Sehrawat
from the building side
9. Year of Construction : 2011
10. Applicant's letter No. : MHA Portal ID 2024033103900 Dated: 31.03.2024

	Minimum Standards on fire prevention and fire safety U/R 33	NBC BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	01	01	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.25m	1.45- 1.50 m	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	c. Protection of exits	Required	Provided	MR
	• Fire check door	NA	NA	NA
	• Pressurization			
	d. No. of continuous staircases to terrace	01	01	MR
e. Width of Corridor	NA	NA	NA	
f. Door Size	1m	1.40 m (final exit)	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5	Fire Extinguishers			

1

2/14

	<ul style="list-style-type: none"> Total numbers Types ISI marking 	06nos	08nos	MR
		ABC & Co2	06- ABC & 02-Co2	MR
		Yes	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01	01	MR
		30 m	30 m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Co. Mo. Det.	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8	MOEFA	NA	NA	NA
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450LPM	450LPM	MR
		30m	30m	MR
		Required	Provided	MR
		Required	Provided	MR

N/15

14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	• Draw-off connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 ltr	10,000ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total Area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection system provided in the premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No F6/DFS/MS/GH/2021/SZ/113 dated 26.02.2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Sh. Manoj Kumar Sharma
Signature of the Inspection Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

Sh. Rajesh Kumar
Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

CFO (HQ)

Sh. Manoj Kumar Sharma
18/11/2021
Director

Sh. Rajesh Kumar
18/11/21
ADO BCP

As approved, F-1 letter is put up for your signature as Director
Sh. Manoj Kumar Sharma
18/11/21

Sh. Rajesh Kumar
18/11/21
Sub-Inspector