



No. F6/DFS/MS/WZ/School/2024/ 337

Dated:- 24/04/2024

FIRE SAFETY CERTIFICATE

Certified that the **ST. Rosier Public School**, Located at **CD-4, Shalimar Bagh, Delhi-110088**, comprised of **Ground + 03 Upper Floors** owned/occupied by **ST. Rosier Public School**, was issued Fire Safety Certificate by this department Vide Letter No. **F6/DFS/MS/WZ/School/2019/174** dated **24/01/2019**. The said premise was re-inspected by the officer concerned of this department on **23/03/2024** in the presence of **Sh. I. C. Gupta (Manager)** and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with **D.O.E. Cr. No. 3298-3398** dated **01/03/2011** and that the premises/building is fit for occupancy class **"Educational Building" Group B** with effect from **24/04/2024** for a period of **three years** in accordance with Rule 36 unless renewal under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the DFS Rules, 2010, printed below.

Issued on **24/04/2024** at New Delhi by.


(Anil Garg)
Director

Tel. No. 011-23414000

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, ST. Rosier Public School, CD-4, Pitampur, Delhi-110088.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.


24/04/24

INSPECTION REPORT

1. Name and address of the building: **ST. Rosier Public School Located at CD-4, Shalimar Bagh, Delhi-110088**
2. Type of Occupancy : Educational, (Ground + 03 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/School/2019/174 dated 24/01/2019
5. Fire Safety directives Letter No. : D.O.E. Cr. No. 3298-3398 dated 01/03/2011
6. Date of inspection : 23/03/2024
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. I. C. Gupta (Manager)
9. Year of Construction : 2005
10. Applicant's letter No. : SRPS/2024-25/015 dated 04/03/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Cr. No. 3298-3398 dated 01/03/2011 Requirements/as per FSC dated 24/01/2019	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Provided Provided NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m each	1.6 m x 1 & 1.7 m x 1	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.5 m	1.77 m	MR
	f. Door Size	1.9 m	1.20 m	MR
3.	Compartmentation		NA	
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	12 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm & 180 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 ltrs.	Provided	MR
		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply			
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room > Detector system panel > Flow Switch Panel > PA System Panel > Battery backup > Building Floor Plans	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Cr. No. 3298-3398 dated 01/03/2011 renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/WZ/School/2019/174 dated 24/01/2019 is recommended.

Accordingly DFA is put up for approval please.

Amit
 26/03/24
 Aman Kumar Lathar
 ADO (JWP)

~~DFA (WZ)~~

dy
 28/3/2024

727
 28/3/2024

~~CFD~~ Please speak
WZ
 29/3/2024

~~Dy CFD (WZ)~~

spoken today.
 you mention that no previous file is pending
 with you & put up.

dy
 18/4/2024

727
 19/04/2024

~~ADO (JWP)~~

no file pending before this, with undersign.

~~DFA (WZ)~~

dy
 22/4

Amit
 22/04/24
 ADO (JWP)

~~CFD~~
WZ
 22/4/2024

~~Director~~
WZ
 22/04/24

Amit
 22/4/24