

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No.F.6 DFS/MS/School/2024/SZ/354

Dated: 26/04/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Govt. Girls Senior Secondary School** located at Harkesh Nager, New Delhi (**School ID 1925341**) Comprised of 03 blocks- G +1 upper floor & 02 Block- G + 03 upper floors, **G + 2 (One floor add in old block) not in use for school purpose** owned/occupied by Directorate of Education, Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2017/SZ/1588 Dt. 08/11/2017. The said premises was re-inspected by officer concerned of this department on 22/04/2024 in presence of Ms. Sheetal (Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational Building Group - B**" with effect from 26/04/2024 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 26/04,2024 at New Delhi by

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Principal, Govt. Girls Senior Secondary School located at Harkesh Nager, New Delhi (School ID 1925341)
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054

**Conditions for the validity of Fire Safety Certificate:-**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."



N/25

## INSPECTION REPORT

|       |   |  |   |                |
|-------|---|--|---|----------------|
| 1     | Name & Address of the Building                              | Govt. Girls Senior Secondary School, Harkesh Nager, New Delhi (School ID 1925341)  |   |                |
| 2     | Type of Occupancy   | Educational, Group-B (School)  |   |                |
| 3     | Building Comprised of                                       | 03 blocks- G + 1 upper floor & 02 Block- G + 3 upper floors, G + 2 (One floor add in old block) not in use for school purpose. |   |                |
| 4     | Type of Case  | Renewal  |   |                |
| 5     | Details of Previous NOC                                     | F6/DFS/MS/School/2017/SZ/1588 Dt. 08/11/2017   |   |                |
| 6     | Fire Safety Directives Letter No                            | F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011   |   |                |
| 7     | Date of Inspection  | 22/04/2024   |   |                |
| 8     | Name of the Inspecting Officers                             | Sh. Rajesh Kumar ADO (BCP)   |   |                |
| 9     | Name & Designation of Officers from the building side       | Ms. Sheetal (Principal)  |   |                |
| 10    | Year of construction  | 2005, 2016 & 2020  |   |                |
| 11    | Applicant letter No.  | GGSSSHN/85/2024 Dated 06/04/2024   |   |                |
| S. No | Minimum standards on Fire Prevention and Fire Safety U/R 33 | DOE Circular /NBC Part -IV   | Provided at Site  | Remarks MR/NMR |
| 1     | <b>Access to Building.</b>                                  |  |   |                |
|       | • Road width  | Required   | 6 mtr   | MR             |
|       | • Gate width  | -NA-   | 4 mtr   | -NA-           |
|       | • Width of internal road                                    | -NA-   | -NA-  | -NA-           |
| 2     | <b>Number, width, type &amp; arrangement of exits.</b>      |  |   |                |
|       | <b>a) Number of Staircase</b>                               |  |   |                |
|       | ➤ Upper floors.   | G+1 bks- 2 nos each<br>G+3, 1 <sup>st</sup> bk- 3 Nos<br>G+3, 2 <sup>nd</sup> bk- 2Nos   | G+1 bks- 2 nos each<br>G+3, 1 <sup>st</sup> bk- 3 Nos<br>G+3, 2 <sup>nd</sup> bk- 2Nos                                    | MR             |
|       | ➤ Basement floor.   | -NA-   | -NA-  | -NA-           |
|       | <b>b) Width of Staircase</b>                                |  |   |                |
|       | ➤ Upper floors  | 1.50 m / 0.75 m  | G+1 bks- 1.6 & 1.4 m, 1.6 & 1.4 m & 1.5 m x 2<br>G+3, 1 <sup>st</sup> bk- 1.8 m x 3<br>G+3, 2 <sup>nd</sup> bk- 1.8 m x 2 | MR             |
|       | ➤ Basement floor  | -NA-   | -NA-  | -NA-           |
|       | <b>c) Protection of exits</b>                               |  |   |                |
|       | ➤ Fire check door   | -NA-   | -NA-  | -NA-           |
|       | ➤ Pressurization  | -NA-   | -NA-  | -NA-           |
|       | <b>d) No. of continuous staircase to terrace</b>            | Required   | 02 in each block  | MR             |
|       | <b>e) Width of corridor</b>                                 | -NA-   | -NA-  | -NA-           |
|       | <b>f) Door size</b>   | 1 mtr  | 1 mtr   | MR             |
| 3     | <b>Compartmentation.</b>                                    |  |   |                |
|       | • Fire check door.  | -NA-   | -NA-  | -NA-           |
|       | • Sealing of electrical shafts.                             | -NA-   | -NA-  | -NA-           |
|       | • Fire rating of shaft door.                                | -NA-   | -NA-  | -NA-           |
|       | • Water curtain   | -NA-   | -NA-  | -NA-           |
|       | • Fire dampers.   | -NA-   | -NA-  | -NA-           |
| 4.    | <b>Smoke Management system.</b>                             |  |   |                |
|       | • Basement  | -NA-   | -NA-  | -NA-           |
|       | • Upper floors  | -NA-   | -NA-  | -NA-           |
| 5.    | <b>Fire Extinguishers.</b>                                  |  |   |                |
|       | • Total numbers   | 40 no's  | 48 Nos  | MR             |
|       | • Types   | ABC / co2  | ABC & co2 Type  | MR             |
|       | • ISI Marking   | ISI mark   | Provided  | MR             |
| 6.    | <b>First Aid Hose Reels.</b>                                |  |   |                |





12/27

|  |   |      |      |      |
|--|---|------|------|------|
|  | <ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>  | -NA- | -NA- | -NA- |
| 19.  | <b>Fire Control Room.</b>   | -NA- | -NA- | -NA- |
|  | <ul style="list-style-type: none"> <li>Detector system panel.</li> <li>Flow switch panel.</li> <li>PA system panel.</li> <li>Battery backup.</li> <li>Building floor plan.</li> </ul> | -NA- | -NA- | -NA- |
| 20.  | <b>Special Fire Protection System for the Protection of special Risk, if any.</b>   | -NA- | -NA- | -NA- |
| <p>The school Building is comprised of G +1 upper floor (03 Blocks) and two blocks comprised of ground plus three upper floors each was issued FSC by this department vide letter even no 1588 dated 08/11/2017. But school management additional of 2<sup>nd</sup> floor in the building now the building is Ground plus two upper floors but school management not use the Ground plus two upper floor block for school purpose.</p> <p>The fire protection system provided in the building were randomly checked and found functional at the time of inspection.</p> <p>Further, the party has complied all the observation / Shortcoming already issued &amp; communicated by this department vide letter of even no 130 dated 22/03/2024, except G+2 Bldg Block.</p> <p>Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2017/SZ/1588 Dt. 08/11/2017, renewal under rule 35(6) of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p> |   |      |      |      |
| <p><i>(Signature)</i><br/>24/4/24</p> <p>Signature of the Inspecting Officer<br/>Name: Sh. Rajesh Kumar<br/>Design: ADO (BCP)</p>  |   |      |      |      |

DO (SD)

*(Signature)*  
24/4/24

*(Signature)*  
24/4/24

*(Signature)*  
24/4/24

*(Signature)*  
24/4/24

As approved, F.T. letter is put up for your signature

*(Signature)*  
24/4/24

*(Signature)*  
24/4/24

*(Signature)*  
25/4/2024