

C41

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

No.F.6/DFS/MS/School/2024/SZ / 363
NEW DELHI-110 001.

Dated: 29/04/2024

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Kanya Vidyalaya, SPS Block, A-Block, Janak Puri, New Delhi-110058, comprised of ground floor plus three upper floors, having total 40 rooms (including class rooms, Labs, Office & Store etc.), owned/occupied by Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/School/2020/SZ/471 dated 05.11.2020. The School building was re-inspected by the officer concerned of this department on 22.04.2024 in the presence of Sh. Jai Bhagwan (Estate Manager) and found that Govt. Sarvodaya Kanya Vidyalaya, SPS Block, have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Educational" for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....29/04/2024..... at New Delhi.


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Principal, Govt. Sarvodaya Kanya Vidyalaya, SPS Block, A-Block, Janak Puri, New Delhi- 110058.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Govt. Sarvodaya Kanya Vidyalaya, A-Block, Janak Puri, New Delhi-58
 2. Building comprised of : New Building SPS Block having Ground plus three upper floors.
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC : F.6/DFS/MS/School/2020/SZ/471 dated 05/11/2020
 6. Fire Safety directives letter No : N/A
 7. Date of inspection : 22.04.2024
 8. Name of Inspecting Officer : A.D.O. R.K.Yadav
 9. Name and designation of officers
 From the building side : Sh. Jai Bhgwan (Estate Manager)
 10. Year of Construction : 2017
 11. Applicant's letter No. : GSKV/AB/K/JP/2024/355 dated 18.04.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 mtrs 4.5 m N/A	12 m 06 m N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 No.'s N/A	02 No.'s N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 m N/A	1.65 & 1.72 m N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Two	M/R
	e. Width of Corridor	1.50 m	1.75 m	M/R
	f. Door Size	1.0 m	1.15 m (Double door)	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floors 	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers at each floor Types IS marking 	06 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Two 30 m 5 mm	Provided Provided Provided	M/R M/R M/R

7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM (02 no.'s)	M/R
	➤ Head of the pump	40 mtrs	Provided	M/R
	➤ Power Supply	Required	Provided	M/R
	➤ Auto Starting of pump	Required	Provided	M/R
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10000 ltrs	Provided	M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.			
		No Lift		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A

18.	Refuge Area.			
	> Total Area	N/A	N/A	N/A
	> Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:		N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings issued vide letter No. F6/DFS/MS/School/2023/SZ/502 dated 25.10.2023 has been complied.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC was issued vide letter no. F.6/DFS/MS/School/2020/SZ/471 dated 05/11/2020, renewal under the Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav
 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation:- Asstt. Divisional Officer

DO (South West)

25/11/24
 CFO (S2)
26/11/2024
 Director
24/11/24
 Now/ R.K.Y