

C10

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. D6/DFS/MS/SZ/2024/School/339

Dated: 26/04/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Kid's Castle School Located at H-4/77, Bengali Colony, Mahavir Enclave, New Delhi – 110045, comprised of Ground + 1 Upper Floor was issued FSC vide Letter No. F6/DFS/MS/School/SZ/2016/695, dated: 04/05/2016. The premises was re inspected by the officer concerned of this department on 15/04/2024 in the presence of Mr. Rohit Sharma and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298 – 3398 Dated 17-01-2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 26/04/2024 for a period of three years.

Issued on 26/04/2024 at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. The Principal, Kid's Castle School Located at H-4/77, Bengali Colony, Mahavir Enclave, New Delhi – 110045.
2. Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

N/7

INSPECTION REPORT

1. Name & address of the building: Kid's Castle School Located at H-4/77, Bengali Colony, Mahavir Enclave, New Delhi – 110045.
2. Type of Occupancy : Educational Building (G+ 1 UF having 5 rooms (including office) at ground floor & 5 class rooms at 1st floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/SZ/2016/695, dated:04/05/16
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 15-04-2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Rohit Sharma
9. Year of Construction : 2009
10. Applicant's letter No. : Email dated 22/03/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/4, N/5 & N/6	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06mtr	6mtrs	MR
	• Gate width	4.5m	Directly accessible from road	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1 No. if less then 1.5m 02 Nos. is required	Provided	MR
	• Basements	N/A	N/A	NA
	b. Width of staircases			
	• Upper floors	1.5mtr&75cm	1m & 0.75m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.01m	1.5m	MR
	f. Door Size	1 mtr	80cm to 1m	MR(Old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA



14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.
 In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/SZ/2016/695, dated: 04/05/2016 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Office
 Name *Uday Kumar Singh*
 Designation *AD/DWR*

15/4/22
AD/DWR
15/4/22
Director
15/4/22