



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/SZ/2024/346

Dated: 26/04/2024

FIRE SAFETY CERTIFICATE

Certified that the **Poornima Public School at Shahbad Mohd Pur, New Delhi-110061**, building comprised of ground plus one upper floor, was issued fire safety certificate by this department vide letter No. F6/DFS/MS/School/SZ/2016/1541 dated 19/10/2016. The premise was re-inspected by the officer concerned of this department on 16/02/2024 in the presence of Mrs. Poonam Saini (HOS) and found that the premise have deemed complied with the fire prevention and fire safety requirements in according with Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building/premises is fit for occupancy class "**Educational**" (Group-B) with effect from 26/04/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/04/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
ACG

Copy to: -

1. The Principal, Poornima Public School at Shahbad Mohd. Pur, New Delhi-110061
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The foam is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

N-3

INSPECTION REPORT

1.	Name & address of the building	Poornima Public School at Shahabad Mohd. Pur, New Delhi-110061		
2.	Type of Occupancy	Educational		
3.	Building Comprised of	Ground plus One upper floor.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F6/DFS/MS/School/SZ/2016/1541 dt. 19/10/2016		
6.	Fire Safety directives Letter No.	DOE Circular No. 3298-3398 dated 01/03/2011		
7.	Date of inspection	16/02/2024		
8.	Name of the Inspecting Officer	Santosh Kumar (ADO/SJ)		
9.	Name and designation of Officer from the building side	Mrs. Poonam Saini (HOS)		
10.	Year of Construction	1997		
11.	Applicant's letter No	Outdoor Diary No. 12872 dated 08/02/2024		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	DOE Circular Dated 01/03/2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	5 mtr	MR (Old case)
	• Gate width	N/A	3.5m	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	One	Two	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50m & if less than another of 0.75m	0.95m & 0.80m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.00 mtr	1.00 mtr	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	04 nos	04 nos	MR
	• Types	ABC/CO ₂	ABC & CO ₂	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA

88

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note: As per the approval of worthy Director, DFS at N/1, the file is re-created and submitted for further course of action please.

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection. The shortcomings earlier communicated vide this department letter No. F6/DFS/MS/School/SZ/2021/230 dated 27/04/2021 found complied.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under DOE Circular dated 01.03.20211, the Fire Safety Certificate issued vide letter No. F6/DFS/MS/School/SZ/2016/1541 dated 19/10/2016, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Santosh Kumar
18.04.21

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO(SD)

Murthy
28/4

cto *Mugh*
22/4/2021

Director

Murthy
27/4/21

ADO (SJ)

Sir,

F.T letter is put up for your sig. pl

Director *Murthy*
28/4/21

Murthy

Santosh Kumar
24.04.21