



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001




No. F6/DFS/MS/2024/School/371

Dated: 30/04/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Akash Deep Model School located at Gali No-11, Fauji Colony, Mukundpur, Part-II, Delhi-110084 comprised of Ground floor only owned/occupied by Akash Deep Model School was granted FSC by this department vide letter No.F6/DFS/MS/2018/School/987 dated 10.05.2018. The premises was inspected by the officer concerned of this department on 24.04.2024 presence of Mrs. Asha (Manager) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class 'Group B Educational' with effect from ...30/04/2024.. for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ...30/04/2024... at New Delhi

  
(Anil Garg)  
Director  
Ph:-011-23414000  
etc

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 110054.
2. The Principal, Akash Deep Model School located at Gali No-11, Fauji Colony, Mukundpur, Part-II, Delhi-110084.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

**INSPECTION REPORT**

1. Name & address of the building : Akash Deep Model School at Gali No-11, Fauji Colony, Mukund Pur, Part-II, Delhi-110084.
2. Type of Occupancy : Educational
3. Composition of building : Ground floor only
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2018/School/987 dated 10.05.2018
6. Fire Safety directives letter No : Nil
7. Date of inspection : 24.04.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers  
from the building side : Mrs. Asha (Manager)
10. Year of Construction : 2015
11. Applicant's letter No. : Online e-mail dated 15.04.2024

	Minimum Standards on fire prevention and fire safety U/R 33	Director of education circular dated 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	06m	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	<b>b. Width of staircases</b>			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	<b>c. Protection of exits</b>			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			

		N/6	03nos	04nos	
<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>		ABC/Co2	Yes	ABC--04	Yes
6	<b>First-Aid Hose Reels.</b>				
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	NA	NA	NA	NA
7	<b>Automatic fire detection and alarming system</b>				
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>				
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA	NA
11	<b>Internal Hydrants</b>				
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA	NA	NA
12	<b>Yard Hydrants.</b>				
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA	NA
13	<b>Pumping Arrangements.</b>				
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A	N/A
14	<b>Captive Water Storage for fire fighting.</b>				

	<ul style="list-style-type: none"> <li>&gt; Draw-off connection</li> <li>&gt; Fire service inlet</li> <li>&gt; Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> <li>&gt; Total Area</li> <li>&gt; Location</li> </ul>	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/2018/School/987 dated 10.05.2018.

Dy. Chief Fire Officer (N2)  
(NWB)

Signature of the Inspecting Officer  
Name:- C.L. Meena  
Designation:- ADO/RN

There is no pending file before renewal of this file.

BCFO/848-NW2  
Date: 24/04/2024

24/4/2024  
25/4/2024  
Director 28/04/2024

24/04/2024

ADO/RN