

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/CGHS/SZ/2024/ 267

Dated: 30/04/2024

**FIRE SAFETY CERTIFICATE**

Certified that the building of Pragatisheel Bairwa CGHS. Ltd Located at Plot no-5-C, Sector-11, Dwarka New Delhi -110075 having 02 blocks comprised of Basement + stilt/ground + 10 Upper Floors was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/CGHS/09/1053 date 21/04/2009. The premise was re inspected by the officer concerned of this department on 18/04/2024 in the presence of. Sh. R.K Mishra (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Residential Building" Group A-4 with effect from 30/04/2024 for a period of five years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/04/2024 at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service  
OK

Copy to:

1. The President, Pragatisheel Bairwa CGHS. Ltd Located at Plot no-5-C, Sector-11, Dwarka New Delhi -110075.
2. The Joint Director (Building) DDA, Vikas Sadan, INA, Delhi-110023.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building: Pragatisheel Bairwa CGHS. Ltd Located at Plot no-5-C, Sector-11, Dwarka New Delhi -110075.
2. Type of Occupancy : Residential Building "A" (Apartment)
3. Type of Case : (Two blocks, Basement+ ground/stilt + Ten upper floors) *Renewal*
4. Details of previous NOC : F6/DFS/MS/CGHS/09/1053 date 21/04/2009
5. Fire Safety directives L. No. : F6/ DFS /MS/CGHS/2001/1712 dated 22/08/01
6. Date of inspection : 18/04/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer  
from the building side : Sh. R.K Mishra (Manager)
9. Year of Construction : 2001
10. Applicant's letter No. : Pragatisheel/CGHS/Fire/24 Dated-30/03/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/06 & N/07	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 mtrs	Provided	MR
	• Gate width	5 mtrs	Provided	MR
	• Width of internal road	6 mtrs	4.7m to 6m	MR(Being old case)
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 each block	Provided	MR
	• Basements	03 stair+2 ramp	Provided	MR
	b. Width of staircases			
	• Upper floors	1.25 m & 1m	2X125cm	MR
	• Basements	1.25m	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	02 Nos.	Provided	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	02 nos. each floor	Provided	MR
	• Types	CO <sub>2</sub> & WCO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR

*[Handwritten Signature]*

6.	First – Aid Hose Reels			MR
	• Total numbers on each floor	01 each block	Provided	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			N/A
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	
10.	Automatic Sprinkler System			N/A
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants	Required	Provided	MR
	• Size of riser/down- comer	01	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box			
12.	Yard Hydrants	Required	Provided	MR
	• Total number of hydrants	Required	Provided	MR
	• Hose Box			
13.	Pumping Arrangements			N/A
	• Ground Level	N/A	N/A	N/A
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby Pump out put	N/A	N/A	N/A
	• Standby Pump Head	N/A	N/A	N/A
	• Auto Staring/Manual stopping	N/A	N/A	N/A
	• Pump House Access	900 LPM	Provided	MR
	• Terrace level	40 mtrs	Provided	MR
	• Discharge of pump	Required	Provided	MR
	• Head of the pump	Required	Provided	MR
	• Power supply			
	• Auto starting of pump			
14.	Captive water Storage for fire fighting			MR
	• Under ground tank capacity	2,00000ltrs Required	Provided	MR
	• Draw of connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead Tank capacity	30,000 ltr each block	Provided	MR
15	Exit Signage	Required	Provided	MR

*(Handwritten signature and initials)*

16.	Provision of Lifts		
	➤ Pressurization of Lift Shaft	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A
	➤ Communication in lift Car	Required	Provided
	➤ Fireman's Grounding Switch	Required.	Provided
	➤ Lift Signage	Required	Provided
17.	Standby power supply	Required	DG Set
18.	Refuge Area		
	➤ Total area	N/A	N/A
	➤ Location	N/A	N/A
19.	Fire control room		
	➤ Detector system panel	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A
	➤ PA System Panel	Required	Provided
	➤ Battery backup	Required	Provided
	➤ Building Floor Plans	Required	Provided
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC fire extinguisher provided near electric panel

The fire protection systems provided in the building were test checked and found functional at the time of inspection.  
 In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F6/DFS/MS/CGHS/09/1053 date 21/04/2009 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

*[Signature]*  
 Signature of the Inspecting Officer  
 Name *Uday V/S Singh*  
 Designation *ASD/MS*

*[Signature]*  
 CFO (S2) *Ward*  
 23/4/2011  
 Director *[Signature]*  
 24/4/2011

*[Signature]*  
 AND WORK

Sir PP. letter is put after sign

*[Signature]*  
 DIRECTOR *[Signature]*  
 24/4/2011

*[Signature]*  
 22/4/2011