

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/2024/ 277

Dated : 03/05/2024

FIRE SAFETY CERTIFICATE

Certified that the **All India Women's Conference, Sarojni House** Located at 6, Bhagwan Das Road, New Delhi comprised of **Basement + Ground + 06 Upper floors** was earlier issued FSC by this department vide letter No.F6/DFS/MS/2021/NDZ/117 dated 12/02/2021. Now, the premises was re-inspected by the officer concerned of this department on 25/04/24 in the presence of Mr. Vinay Bhardwaj and found that the said building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Hostel Building with effect from 03/05/2024 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 03/05/2024...at New Delhi by.

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

- 1) Smt. Kalyani Raj Presedent, All India Women's Conference, 6, Bhagwan Das Road, New Delhi.
2. The Chairman, NDMC, Palika Kendra, New Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

N/47
INSPECTION REPORT

1. Name & address of the building : All India Women's Conference at Sarojini House, 6, Bhagwan Dass Road, New Delhi B+Gr.+6th upper floor
2. Type of occupancy : Residential (hostel)
3. Type of case:- : Renewal(12 points)
4. Details of previous FSC : F6/DFS/MS/2021/NDZ/117 dated 12/02/2021.
5. Fire safety directives No. : N/A
6. Date of inspection:- 25/04/2024
7. Name of the inspecting officer : Sh. Ravinder Singh ADO/CC
Sh. Rajinder Atwal DO /CD
8. Name & designation of officer : Mr. Vinay Bhardwaz
From the building side
9. Year of construction : 1977
10. Applicant's letter No : letter no. nil dated 31.01.2024

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Approach to Building			
	1) Road width	06 mtr.	12 mtr. ✓	MR
	2) Gate width	06 mtr.	6 mtr. ✓	MR
	3) Width of internal road	N/A	6 mtr. ✓	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	04	04 ✓	MR
	2. Basements	02	02 ✓	MR
	B. Width of staircase			
	1. Upper floors	100cms	02 of 125cms each & 2 of 90cms each. ✓	MR
	2. Basements	100cms.	Two staircases 170 cms each	MR
	C. Protection of exits			
	1. Fire check door(fire escape)	Required	Provided	MR
	2. Pressurization	NA	NA	NA
	D. No. of continuous staircase to terrace	03	03 ✓	MR
	E. Width of corridor	190 cms & 140 cms	Provided	MR
	F. Door size	NA	NA	NA
3.	Compartmentation			
	1) Fire check door (fire escape)	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided ✓	MR
	3) Fire rating of shaft door	NA	NA ✓	NA
	4) Water curtain	NA	NA	NA

A S

N/48

	5) Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	1) Basements	30 ACPH	Exhaust fan. ✓	MR
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	36 Nos.	50 ✓	MR
	2) Types	ABC, CO2, W.CO2 & DCP	ABC, CO2, W.CO2 & DCP	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number	3 nos	Provided	MR
	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke	Provided	MR
	2) Location of main panel	Gr. Floor	Provided	MR
	3) Location of repeater panel	NA	NA	NA
	4) Alternate source of power	UPS	Provided	MR
	5) Hooter's Location	Near gate	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	NA	NA	NA
	3) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 MM	100MM ✓	MR
	2) Number of hydrants per floor	03 nos.	03 nos. ✓	MR
	3) Hose box each floor	Required	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	04nos	N/A
	2) Hose box	N/A	04nos	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2280 LPM	Provided ✓	MR
	b) Head of main pump	70 mtr.	Provided ✓	MR
	c) Number of main pump	01	Provided	MR
	d) Jockey pump out put	180 LPM	Provided ✓	MR
	e) Jockey pump head	70 mtr.	Provided	MR
	f) Stand by pump output	2280 LPM	Provided	MR
	g) Stand by pump head	70mtr.	Provided ✓	MR
	h) Auto starting/Manual stopping	Required	Provided	MR

50/

	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	1,00,000 ltr. ✓	Provided	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	10,000 ltr.	Provided ✓	MR
15.	Exit Signage.	Required	Provided ✓	MR
16.	Provision of Lifts.	03 Nos. Lift		
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided ✓	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided ✓	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Required	Provided at G.F. ✓	MR
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	Required	Provided at G.F. ✓	MR
	d) Battery backup	Required	Provided ✓	MR
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter No. F6/DFS/MS/2021/NDZ/117 dated 12/02/2021, under rule 35(6) of the Delhi Fire Service Rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of Inspecting Officer

Rajinder Atwal
29/4/24

Name:- Rajinder Atwal
Designation : DO/CD

Signature of the Inspecting Officer

Ravinder Singh
29/4/24

Name:- Ravinder Singh
Designation:- ADO (CC)

Rajinder Atwal
C.F.O.
30/4/2024

Ravinder Singh
30/4/24

Rajinder Atwal
30/4/24

Rajinder Atwal