



No. F6/DFS/MS/School/NDZ/2024/ 379

Dated: 03/05/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Greenway Modern School** located at **Between Pocket A & D, Dilshad Garden, Delhi - 110095** comprised of basement, ground plus four upper floors only owned/occupied by **Greenway Modern School** was issued FSC vide letter No. F6/DFS/MS/School/2020/NDZ/58 dated 21/01/2021. The School building was re-inspected by the officer concerned of this department on 10/04/2024 in presence of Mr. Mohit Sachdeva (Principal) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rules 33 of the Delhi Fire Service Rules, 2010 and observed that the school building is fit for class **“Educational Building” (Group-B)** with effect from 03/05/2024 for a period of **three years** in accordance with Rule 36 unless renewal under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the DFS Rules, 2010 printed overleaf.

Issued on 03/05/2024 at New Delhi by.

(ATUL GARG)  
DIRECTOR

o/DELHI FIRE SERVICE

**Copy to:-**

1. The Principal, Greenway Modern School located at Between Pocket A & D, Dilshad Garden, Delhi-110095.
2. The Dy Director of Education, B-Block, Yamuna Vihar, Delhi-110053.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. Basement shall be used as per NBC/UBBL
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N) 24  
**INSPECTION REPORT**

01.	Name & address of the building	Greenway Modern School located at Between Pocket A & D, Dilshad Garden, Delhi-110095.
02.	Building is comprised of	Basement, Ground plus Four upper floors
03.	Type of occupancy	Educational Building
04.	Type of case	Renewal
05.	Details of previous FSC	F6/DFS/MS/School/2020/NDZ/58 dated 21/01/2021.
06.	Fire safety directives letter no.	F.6/DFS/MS/BP/2010/3019 dated 27/10/2010
07.	Date of inspection	10/04/2024.
08.	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)
09.	Name of the designation of officer from the building side	Mr. Mohit Sachdeva (Principal)
10.	Year of construction	2005 & 2010
11.	Applicant's letter no.	Outdoor dairy no.10 dated 01/04/2024

S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
01.	<b>Access to Building:</b>			
	A Road width	6.0 mtrs.	15 mtrs. ✓	MR
	B Gate width	4.50 mtrs	6.0 mtrs ✓	MR
	C Width of internal road	NA	4.50 mtrs ✓	MR
02.	<b>Number, Width, Type and Arrangement of Exits:</b>			
	<b>A Number of staircases</b>			
	a Upper floor	05 nos.	05 nos. ✓	MR
	b Basement	02 nos.	02 nos. ✓	MR
	<b>B Width of staircases</b>			
	a Upper floor	1.50 mtrs	1.50 mtrs each ✓	MR
	b Basement	1.50 mtrs	1.50 mtrs each 01 Ramp (04 mtrs) ✓	MR
	<b>C Protection of exits</b>			
	a Fire check door	NA	NA	NA
	b Pressurization	NA	NA	NA
	D No. of continuous staircases to terrace	02 nos.	02 nos. ✓	MR
	E Width of corridor	1.50 mtrs.	1.80 mtrs. ✓	MR
	F Door size	01 mtrs	01 mtrs ✓	MR
	G No of door in class room	02 nos	01 no & 02 nos.	MR
03.	<b>Compartmentation:</b>			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	Required	Provided ✓	MR
	C Fire rating of shaft door	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
04.	<b>Smoke Management System:</b>			
	A Basement	Required	Exhaust fans ✓	MR
	B Upper floor	NA	NA	NA

(u)

<b>05. Fire Extinguisher:</b>				
A	Total numbers	22 nos.	25 nos.	MR
B	Types	ABC/CO <sub>2</sub>	ABC/CO <sub>2</sub>	MR
C	ISI marking	ISI Marked	ISI Marked	MR
<b>06. First-Aid-Hose Reel:</b>				
A	Total numbers of each floor	02 no.	02 no.	MR
B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
C	Nozzle diameter	05 mm	05 mm	MR
<b>07. Automatic Fire Detection and Alarming System:</b>				
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters	NA	NA	NA
08.	<b>MOEFA:</b>	Required	Provided	MR
09	<b>Public Address System:</b>	Required	Provided	MR
<b>10. Automatic Sprinkler System:</b>				
A	Basement	Required	Provided	MR
B	Upper floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
<b>11. Internal Hydrants:</b>				
A	Size of riser/down-comer	100 mm	100 mm	MR
B	Number of hydrants per floor	02 no.	02 no.	MR
C	Hose box	02 no.	02 no.	MR
<b>12. Yard Hydrants:</b>				
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
<b>13. Pumping Arrangements:</b>				
<b>1 Ground level</b>				
A	Discharge of main pump	NA	NA	NA
B	Head of main pump	NA	NA	NA
C	Number of main pumps	NA	NA	NA
D	Jockey pump out put	NA	NA	NA
E	Jockey pump head	NA	NA	NA
F	Standby pump out put	NA	NA	NA
G	Standby pump head	NA	NA	NA
H	Auto starting /manual stopping	NA	NA	NA
I	Pump house access	NA	NA	NA
<b>2 Terrace Level</b>				
A	Discharge of pump	900 LPM	900 LPM X 02	MR
B	Head of the pump	40 mtrs.	40 mtrs.	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

N) 26


Greenway Modern School located at Between Pocket A&B, Dilshad Garden, Delhi-110095

<b>14. Captive Water Storage for Fire Fighting:</b>				
A	Underground tank capacity	NA	NA	NA
B	Draw-off connection	NA	NA	NA
C	Fire service inlet	Required	Provided	MR
D	Access to tank	Required	Provided	MR
E	Overhead tank capacity	25,000 liters.	25,000 liters.	MR
<b>15. Exit Signage:</b>		Required	Provided	MR
<b>16. Provision of Lifts:</b>				
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	Required	Provided	MR
D	Firemen's grounding switch	Required	Provided	MR
E	Lift signage	Required	Provided	MR
<b>17. Standby Power Supply:</b>		Required	Provided	MR
<b>18. Refuge Area:</b>				
A	Total area	NA	NA	NA
B	Location	NA	NA	NA
<b>19. Fire Control Room:</b>				
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	PA system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
<b>20. Special Fire Protection systems for protection of special Risks, if any:</b>		NA	NA	NA

The fire protection systems provided in the school building were tested, checked at random and found functional at the time of inspection.


Keeping in view of above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC / FSC was issued vide letter no. F6/DFS/MS/School/2020/NDZ/58 dated 21/01/2021 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

No file is pending with me before disposal of this case.

  
 24/4/2024  
 Signature of the Inspecting Officer  
 Name: - Yashwant Singh Meena  
 Designation: - ADO (L.N)

DY. CFO /NDZ

  
 26/04/24

C.F.O.  
  
 29/4/2024

Director  
  
 29/04/24

str.

F.T Letter is Auto for sign. Already

